



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", तिसरी मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र  
Regional Office : "Narang Tower", 3<sup>rd</sup> Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra  
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला  
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/NH-361/MIDC-Butibori/UT-74/2021 816

Date: 21.06.2021

22

### Invitation of Public Comments

**Sub:** Proposal for grant of permission for laying 33 KV overhead line and UG cable from Ch. 518 to Ch. 522 at Addl. Butibori Industrial area - Reg.

**Ref.:** (i) PD, PIU-Yawatmal Lr.No.NHAI/PIU/YTL/NH-361/YW/MIDC-Butibori/2021/1166, dated 11 June 2021.

(ii) Dy. Engineer, MIDC E&M Sub Division, Butibori Lr. No. EE/E&M/NGP/B-93816, Dtd. 14.08.2020.

\*\*\*

It is to inform all concern that M/s Maharashtra Industrial Development Corporation vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Yawatmal has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that M/s Maharashtra Industrial Development Corporation along on Wardha-Butibori Section of NH-361 in the State of Maharashtra is as follows:

- Underground 33 KV Cable from km Ch. 518 to Ch. 522 on NH-361.
- Alignment of the cable is along Wardha-Butibori Section on NH-361.
- Cable to be laid in Duct 1.8m below ground level.
- Crossing by HDD method at Chainage 517.870 & 522.400.

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 28.01.2016 due to above transmission line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 21.07.2021, beyond due date, no comments/ objections will be accepted.

**The Regional Officer,**  
Regional Office - Nagpur  
National Highways Authority of India,  
"Narang Towers", 3<sup>rd</sup> Floor,  
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),  
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra  
Tel : 0712-2520091  
Email : ronagpur@nhai.org

*N. Wadetiwar*  
21.06.2018  
(Naresh Y. Wadetiwar)  
General Manager (Tech.)  
NHAI, RO, Nagpur

Copy to: (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website  
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi - for uploading in Ministry's website  
[mansoor@nic.in]