

Government of India

Ministry of Road Transport & Highways

(Chief Engineer - Regional Office, Lucknow)

N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022

Ph.: (0522) - 2967112, 2738226 (Tele-Fax)

Dated: 16.07.2024

Invitation of public comments

Sub.: Proposal for NOC permission for Laying of 1000mm dia D.I. K-9 Sewer rising mainline on NH-96/330 from Ch. 153.330 to Ch. 154.000 under Mahakumbh 2024-25 in the state of Uttar Pradesh- Reg.

Uttar Pradesh Jal Nigam (Urban), Prayagraj has submitted the proposal for laying underground Sewer rising mainline on subject cited chainages of NH-96/330 in the State of Uttar Pradesh to Executive Engineer, NH Division, PWD, Prayagraj for consideration.


2. The above proposal has been examined in this office in light of Ministry guidelines issued vide OM no.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016 & NH-36094/01/2022-S&R (P&B) dated 24.04.2023. The application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application (checklist enclosed) is invited to the below mentioned address:

The Chief Engineer - Regional Officer,
Ministry of Road Transport & Highways,
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,
Vikas Nagar, Lucknow - 226 022.

Encl.: As above.

Yours faithfully,


(Ritesh Yadav)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

Copy to:

- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), Public Works Department, Nirman Bhavan, 96, M. G. Marg, Lucknow - 226 001.


(Ritesh Yadav)

Assistant Executive Engineer
for Chief Engineer - Regional Officer

CHECK-LIST

NH-330/96

Guidelines for Executive Engineer PWD of ~~NH-30/220~~ for processing the proposal of laying Sewer line by public utilities in the land along National Highways vested with NH-PWD.

Relevant circulars

1. Ministry Circular no. RW/NH-33044/27/2005/S&R(R) (Pt.)
Dated 6/8/2018

- Check list for getting approval for laying of Sewer line on PWD-NH land .

S.N o.	Item	Information/ Status	Remarks
1.	General Information		
1.1	Name and Address of the applicant	Executive Engineer ,Construction Division-1, UPJN(U) Prayagraj ...	
1.2	National Highway Number	NH-30 NH-330/96	
1.3	State	Uttar Pradesh	
1.4	Location	Between Balson ChaurahaToUniversityChaurahaTowardsMumfordganj	
1.5	(Chainage in Km.)	<u>Ch.154.000 To Ch. 153.330 Km -0.670Km</u>	
1.6	Length in Meters	<u>670 m</u>	
1.7	Width of available median of Road	<u>0.5 m</u>	
(a)	Left side from center line towards Increasing chainage /Km. direction	<u>11 m</u>	
(b)	Right side from center towards	11 m	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D
Prayagraj

Inspector
Construction Division-1 (First)
U.P. Prayagraj
Prayagraj

	Increasing chainage /Km. direction		
1.8	Proposal to lay the Sewer Pipe	<u>1000 mm dia-670.00 M.</u>	
(a)	Left side from center line towards Increasing chainage /Km. direction	No.	
(b)	Right side from center towards Increasing chainage /Km. direction	<u>11 m</u>	
1.9	Proposal to acquire land	N/A	
	(a) Left side Form Center land	N/A	
	(b) Right side from center land	N/A	
1.10	Whether proposal is in same side where land is not to be acquired	Yes	
1.11	Details of already laid services, if any, along the proposed route.	N/A	
1.12	Number of lanes (2/4/6/8 lanes)existing	2Lane	
1.13	Proposed Number of Lanes (4 lane With Paved Shoulders 4/6/8 lanes)	Four lane with 1meter RCC drain	
1.14	Service road Existing or not	N/A	
	If Yes Then which Side	N/A	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

	(a) Left side from center land	N/A	
	(b) Right side from center land	N/A	
1.1 5	Proposal to acquire land	N/A	
	(a) Left side Form Center land	N/A	
	(b) Right side from center land	N/A	
1.1 6	Whether proposal to lay Sewer Pipe is after the I service road on between the service road and main carriage way	Out of Row	
1.1 7	The Permission for laying sewer shall be considered For approval /rejection	NA	
	(i) Where the ROW is more than 15 15m , then the duct cable shall be laid at the edge of right of way within the utility corridor of 2 m width, duly keeping in view the future widening	Yes	
	(ii) Where land yet to be acquired for 2 lining and the position of new carriageway	N/A	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
Construction Division
Prayagraj

	has been decided then the sewer shall be utility corridor of 2 m Width, on that side of existing carriageway Where Extra land is not proposed acquired or 2-lining.		
	(iii) Where the widening plan for 2-lining is not yet decides and available ROW is around 30m on less, a judicious decision would need to be taken foe permitting the laying of sewer.	Yes	
	This could be within 1.5m to 2m of utility corridor at the edge of existing ROW, duly keeping in view the possible widening plans.		
	(iv) Where Row is restricted and adequate only to accommodate the carriageway, central verge,	Sewer should be laid clear of the drain	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
Construction Division (I)
Prayagraj

Forward

	shoulders and drains (e.g. highway in Cutting through Hilly/rolling terrain), the sewer shall be laid clear of drain		
	(v) Where land strip for utility corridor cannot be conveniently earmarked (available ROW restricted to the toe of the embankment) for laying of sewer, the permission may be refused.	N/A	
1.1 8	No. of applicants on the same stretch		
1.1 9	Whether the case of multiple licenses	Unknown	
1.2 0	It so furnish a joint implementation programmer to lay their respective ducts within stipulated time frame	N/A	
1.2 1	If crossings of the road involved if yes if Shall only be through -less technology.	<u>Yes it will be done by trench less technology (Manual Jack Pushing method)</u>	
2.	Document/Drawings enclosed with	Yes	

Assistant Engineer
H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Cons. Engineer (First)
N. H. Division (U. S. A.)
Prayagraj

2.1	the proposal Cross section showing the size of trench for open trenching method.	Yes (Drawing Attached)	
2.2	Cross section showing the size of pit and location of Sewer for HDD method	N/A	
2.3	Strip plan/route plan showing the sewer line, chainage, width of ROW, distance of proposed, sewer line, from the edge of ROW, important mile stone, intersections, cross drainage works etc.	Yes (Drawing Attached)	
2.4	Methodology for laying of sewer pipe	open cut & Trench less method (as per drawing attached)	
2.4.1	Open trenching method. If yes, methodology of refilling of trench.	Refilling and compaction in layers not exceeding 30 cm depth at a time	
2.4.2	Horizontal Directional Drilling (HDD) Method	Yes	
2.4.3	Laying OFC through CD works and method of laying (whether to be hung outside parapet)	N/A	
3.	Draft license agreement signed by two witnesses	Yes	
4.	Performance Banks Guarantee		

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
Construction Division (P.W.D.)
Prayagraj

4.2	Confirmation of BG has been obtained as per NH-PWD guidelines.	BG shall be submitted as per Guidelines	
5.	Affidavit /Undertaking form the Applicant for		
5.1	Not to Damage to other utility, if damaged then		
	to pay the losses either to NH-PWD or to the concerned agency.	EE CD-1 UPJN U, Kydganj, Prayagraj.	
5.2	Renewal of Bank Guarantee	Yes	
5.3	Confirming all standard conditions of NH's guidelines	Yes	
5.4	Shifting of 132 KV Underground cable as and when required by NH-PWD	N/A	
5.5	<u>Shifting due to 2 laning/widening of NH</u>	N/A	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes	
5.7	Traffic movement during laying of sewer to be managed by the applicant	Yes	
5.8	If any claim is raised by the Concessionaries then the same has to be paid by the applicant	Yes	

Assistant Engineer,
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
Construction Division (Road)
UP Jal Nigam (URBAN)
Prayagraj

5.9	Certificate for 6-lanning from the applicant in following format "we do undertake than I will relocate service notwithstanding the permission granted within such time as will be stipulated by NH-PWD for future six lanning or any other development"	Yes	
6.	Power of Attorney in favor of authorized signatory	Yes	
7.	copy of DOT license	Yes	
8.	Certificate from the Executive Engineer	Yes	
8.1	<u>Certificate for confirming of all standard conditions issued vide Ministry Circular No. RW/NH/33044/17/2000-S&R dt. 29.09.2000 and Ministry's Circular No. RW/NH-33044/17/2000-S&R dated 21.03.2006</u>	Yes	
8.2	Certificate for 4-lanning from Ex. Engineer in the following format	Yes	

Assistant Engineer
H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Inspector of Police
Construction Division (P.W.D.)
U.P. Prayagraj (UPSA)
Prayagraj

	<p>(a) where feasibility is available " I do certify that there will be not hindrance to proposed six laning based on the feasibility report considering proposed structure at the said location.</p> <p>(b) In case feasibility report is not available "I do certify that sufficient ROW is available at site for accommodat ing proposed six-laning"</p>	Yes	
9.	The agreement fee of Rs. 1 shall be charged	Yes	
10.	If NH section proposed to be taken up by NH-PWD on Bot basis - a clause in para 17 to be inserted in the agreement. " the permitted highway on which licensee has been	Yes	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Chief Engineer
N. H. Division P.W.D. (N)
Prayagraj

	granted the right to lay cable/duct has also been granted as a right of way to the concessionaire under the concession agreement for up-gradation of 1section from km.....to km..... of NMH No.....on Build, Operate and Transfer Basis) and therefore, the licensee shall honour the same"		
11.	Who will supervision the work of laying of sewer pipe.	Construction Division-1, UPJN(U), Prayagraj	
12.	Who will ensure that the defects in road portion after laying Sewer Pipe are corrected and if not corrected then what action will be taken.	Construction Division-1, UPJN(U), Prayagraj	
13.	Who will pay the claims for damages done/disruption in working of Concessionaire if asked by the concessionaire.	Construction Division-1, UPJN(U), Prayagraj	
14.	A Certificate from Executive Engineer that the will enter the proposed permission in the register of records	Yes	

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Engineer
Construction Division-1
UPJN(U), Prayagraj

	of the permission in the prescribed Performa (copy enclosed) issued vide ministry Circular No. R/NH/33044/17/20 00-S&R dated 23.07.2003	
15.	If any previous approval is accorded for laying of cable then Photocopy of register of records of permission accorded as maintained by NH PWD (as per Ministry Circular No. R/NH/33044/17/20 00-S&R dated 23.07.2003) as referred in Para 13 above is enclosed or not.	N/A

Assistant Engineer
N. H. Div- P.W.D.
Prayagraj

Executive Engineer
N. H. Division P.W.D.
Prayagraj

Executive Construction
Construction Division-1,
U.P. Jal Nigam (Urban)
Prayagraj