

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
National Highways Authority of India

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
(Ministry of Road Transport & Highways, Government of India)

परियोजना क्रियान्वयन इकाई - बागपत

Project Implementation Unit, Baghpat

फ्रेंड्स कॉलोनी, निकट पी.डब्ल्यू.डी. गेस्ट हाउस, बरौत रोड, जिला-बागपत - 250609

Friends Colony, Near PWD Guest House, Baraut Road, District Baghpat - 250609

टेलीफोन: 0121-2222971, ई-मेल: plu.baghpat@gmail.com, plubaghpat@nhai.org Web: www.nhai.gov.in



NHAI/PIU-BPT/1041/709AD (Ch. 52+990)/2025/D-17377

Date: 30.06.2025

Invitation of Public Comments

Sub: Proposal for Overhead Crossing of 400kV D/C Meerut (765kV) - Shamli (400kV) D/C line under Turnkey basis on Shamli-Muzaffarnagar section of NH-709AD at Ch. 52+990 in village Raghunathpur, district Shamli - Reg.

The General Manager, Meerut Shamli Power Transmission Corporation Limited, Vasundhara, Ghaziabad (Uttar Pradesh) has submitted the proposal for the permission of Overhead Crossing of 400kV D/C Meerut (765kV) - Shamli (400kV) D/C line under Turnkey basis on Shamli-Muzaffarnagar section of NH-709AD at Ch. 52+990 in village Raghunathpur, district Shamli.

- From the submitted proposal, it is seen that Structures (Transmission Towers) on either side are being erected at distance of 85m (LHS) & 111m (RHS) from the National Highway boundary. Crossing span of structure is 250m. Further, the vertical clearance of 26.6 meter is to be maintained between the lowest conductor of the proposed line and the Finished Road Level as per the proposal submitted by Meerut Shamli Power Transmission Corporation Limited. Further, the proposed transmission line shall be crossing the National Highway at 81° 43' 26'' angle.
- As per the guidelines, issued by the Ministry vide OM no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).
- In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach this office within 30 days from the date of publication, beyond which no comments shall be entertained.

The Project Director,
National Highways Authority of India
Project Implementation Unit - Baghpat
Friends Colony, Near PWD Guest house,
Baraut Road, District Baghpat - 250609

Encl: As above.


(Satyam Seth)
Manager (Tech.)

Copy to:

- The Regional Officer, RO Delhi for kind information.
- Web Admin, NHAI HQ - with request to uploading on NHAI website.
- The Technical Director, NIC, Transport Bhawan, New Delhi - with request for uploading on Ministry's website.
- General Manager, Meerut Shamli Power Transmission Corporation Limited, Vasundhara, Ghaziabad (Uttar Pradesh) for information.