



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority Of India

(Ministry of Road Transport & Highways, Government of India)

परियोजना कार्यान्वयन इकाई / PROJECT IMPLEMENTATION UNIT

कार्यालय : म.न.-132, रेलवे स्टेशन के पास, पन्ना रोड, छतरपुर (म.प्र.) 471001

OFFICE : H.No. 132, Near Railway Station, Panna Road, Chhatarpur (MP) 471001

दूरभाष/Phone : 07682-292209 ई-मेल/E-mail : piuchhatarpur@nhai.org, piuchhatarpur5@gmail.com

CHHP/26010/19/UP Jal Nigam Mahoba/2022/ 10351



Date: 06.12.2022

Invitation of Public Comments

Sub: Proposal for permission for laying of pipe along and crossing National Highway NH-39 under Dhawarra Sijwaha and Lachura Kashipura Group of Villages water supply scheme in Distt. Mahoba (Based on Surface water) and relevant work including commissioning and operations & maintenance for 10 years.

The Authorized Signatory Er. S.S. Tomer, Executive Engineer Const. Div. (Civil) U.P. Jal Nigam Mahoba has submitted the proposal for grant of permission for laying of pipe along and across National Highway NH-39 under Dhawarra Sijwaha and Lachura Kashipura Group of Villages water supply scheme in Distt. Mahoba (Based on Surface water) and (Jal Jivan Mission) relevant work including commissioning and operations & maintenance for 10 years.

2. From the submitted proposal, it is seen that said proposal is for laying of water pipeline. i.e.

- Crossing of 90mm Dia HDPE pipe, 150 mm casing MS Pipe at ch. 82+600.
- Crossing of 100 mm Dia DI pipe, 200 mm casing MS Pipe at ch. 93+700.
- Crossing of 200 mm Dia DI pipe inside existing Box Culvert (102/2) at ch. 101+237 size 1x1x2,
- Along 90 mm Dia km. stone 79.500 to 82.600 LHS side (length 3100 mtr.)
- Along 100 mm Dia km stone 93+400 to 93+700 LHS side (Length 300 mtr.)

The ROW details as per schedule-A of concession agreement are 60m i.e. 30m each side, from km 82.600 to km 93.700 except five locations.

3. As per the guidelines, issued by the Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The General Manager cum Project Director,
National Highways Authority of India
Project Implementation Unit-Chhatarpur
132, Near Railway Station, Panna Road,
Chhatarpur, MP-471001

This issue with the approval of Competent Authority.

Encl: As above.


(Sanjay Sharma)
Dy. Manager (Tech)

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI Website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi-with request for uploading on the Ministry's website.
3. Regional Officer, RO (East)-Jabalpur (MP) for information.
4. The Authorized Signatory Er. S.S. Tomer, Executive Engineer Const. Div. (Civil) U.P. Jal Nigam Mahoba.

CHECK LIST

Guidelines for processing the proposal of crossing/ laying Water supply pipeline. by private parties in the land along National Highway with NHAI.

Relevant circular

Ministry Circular No. RW/NH-33044/29/2015/S&R Dated 22.11.2016.

Check-list for getting approval for laying and crossing of Water Supply Pipe line etc. on NHAI land

S.No.	Item	Information/Status	Remarks
1.	General information		
1.1	Name and Address of the applicant / Agency	Office of the Executive Engineer, U. P. Jal Nigam (Rural), Construction Division, Mahoba.	
1.2	National Highway Number	NH-39	
1.3	State	Uttar Pradesh	
1.4	Location	NH-39, Jhansi Khajuraho Highway <ul style="list-style-type: none">• Crossing of 90mm Dia HDPE Pipe, 150mm Casing MS Pipe at Ch.82.600.• Crossing of 100 Dia DI Pipe, 200mm Casing Dia MS Pipe at Ch.93.700.• Crossing of 200 Dia DI Pipe inside existing Box Culvert 100/2.• Along 90mm Dia Km.Stone 79.50 to 82.60left side.• Along 100mm Dia Km.Stone 93.40to 93.70left side. District Chhatarpur.	
1.5	Changes in KM)	NH-39, Jhansi Khajuraho Highway <ul style="list-style-type: none">• Crossing of 90mm Dia HDPE Pipe,	



SANJAY SHARMA
Dy. Manager (Tech)
NHAI PIU Chhatarpur (M.P.)


परियोजना निदेशक
Project Director
भा.रा.र.प्रा.प.का.ई. छतरपुर (म.प्र.)
NHAI, PIU-CHHATARPUR (M.P.)


Er. S.S. Tomar
Executive Engineer
Const. Div. (Civil)
U.P. Jal Nigam, Mahoba

		150mm Casing MS Pipe at Ch.82.600. • Crossing of 100 Dia DI Pipe, 200mm Casing Dia MS Pipe at Ch.93.700. • Crossing of 200 Dia DI Pipe inside existing Box Culvert 100/2. • Along 90mm Dia Km.Stone 79.50 to 82.60 left side. • Along 100mm Dia Km.Stone 93.40 to 93.70 left side. District Chhatarpur.	
1.6	Length in meters	3400meters Along &3 Number of Crossing	
1.7	Width of available ROW		
	(a) Left side from centre line towards increasing change/km direction	30m	
	(b) Right side from centre line towards increasing chainage/km direction	30m	

1.8	Proposal to lay the pipe line		
	(a) Left side from center line towards increasing change/km direction	• Along 90mm Dia Km.Stone 79.50 to 82.60 left side. • Along 100mm Dia Km.Stone 93.40 to 93.70 left side.	
	(b) Right side from center line towards increasing chainage /km direction	NA	
1.9	Proposal to acquire land		
	(a) Left side from center line.	NA	
	(b) Right side from center line.	NA	
1.10	Whether proposal is in the same side where land is not to be acquired	Not required	
	If not then where to lay the cable	Within available ROW	
1.11	Details of already laid the services, if	NO	


SANJAY SHARMA
Dy. Manager (Tech)
NHAI PIU Chhatarpur (M.P.)


Er. S.S. Tomar
Executive Engineer
Const. Div. (Civil)
U.P. Jal Nagam, Mahoba


	any, along the proposed route		
1.12	Number of lanes (2/4/6/8 lanes) Existing	4-lanes	
1.13	Proposed Number of lanes (2 lanes with pave shoulder/4/6/8 lanes)	Not Proposed	
1.14	Service road existing or not		
	If yes, then which side		
	(a) left side from center line	Yes	
	(b) Right side from center line.	Yes	
1.15	Proposed road existing or not		
	(a) left side from center line	Not Proposed	
	b) Right side from center line.	Not Proposed	
1.16	Whether proposal to lay water pipeline is after the service road or between the service road and main carriageway	No, at end of the RoW	
1.17	The permission for laying pipelines shall be considered for approval rejection	For approval	
	(i) Where the Row is more than 45m then the duct cable shall be laid at the edge of right of way within the utility corridor of 2m width, duly keeping in view the future widening.	Extreme edge of Row	
	(ii) Where land is yet to be acquired for 6-laning and the position of new carriageway has been decided then the cable shall be laid at the edge of right of way within the utility corridor of 2m width, in that side of existing carriageway where extra land is not proposal to be acquired for 4-laning.	Not required	
	(iii) Where the widening plan for 6- laning is not yet decided and available Row is around 30m or less, a judicious decision would need to be taken for permitting the laying of cable/duct. This could be within 1.5m to 2m of utility corridor at the edge of existing Row, duly keeping in view the possible widening plan.	4-laning has been completed.	
	(iv) Where Row is restricted and adequate only to accommodate the carriageway, central verge, shoulders and drains (e.g. Highways in currying	Plain terrain (Edge of Row)	


Sanjay
SANJAY SHARMA
 Dy. Manager (Tech)
 NHAI PIU Chhatarpur (M.P.)

[Signature]
 परियोजना निदेशक
 Project Director
 भा.रा.स.प्रा.प.का.ई. उत्तरपुर (म.प्र.)
 NHAI, PIU-CHHATARPUR (M.P.)

[Signature]
Er. S.S. Tomar
 Executive Engineer
 Const. Div. (Civil)
 U.P. Jal Nagam, Mahoba


	through hilly, rolling terrain) the cable shall be laid clear of the drain.		
	(v) Where land strip for utility corridor cannot be conveniently earmarked (available row restricted to the toe of the embankment) for laying of cable/ducts, the permission may be refused.	Available	
1.18	Number of applicants of the same stretch.	Single applicant	
1.19	Whether the case of multiple licenses.	Single	
1.20	If so, furnish a joint implement programmer to lay their respective ducts within stipulated time frame.	No	
1.21	If crossing of the road involved If yes, it shall only be through trench less technology	Yes, it shall only be through HDD method	
2	Document/drawing enclosed with the proposal.		
2.1	Cross section showing the size of trench for open trenching method (Is it normal size of 1.65m deep x0.5m wide)	Shown in drawing	
2.2	Cross section showing the size of pit location of cable for HDD method	NA	
2.3	Strip plan/ Route plan showing the OFC/cable, chainage, width of ROW, important mile stone, intersections, cross drainage works etc.	Shown in drawing	
2.4	Mythology of laying of PFC	Enclosed	
2.4.1	Open trenching method. If yes, methodology of refilling of trench	No	
2.4.2	Horizontal Directional drilling HDD method	Yes, through HDD	
2.4.3	Laying OFC/cable through CD works and method of laying (Whether to be hung outside parapet)	NA	
3.	Draft license agreement signed by two witnesses	Yes	
4.	Performance Bank Guarantee		
5.	Affidavit/ undertaking/ from the applicant for		
5.1	Not to damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.	Yes, enclosed	



 परियोजना निदेशक
 Project Director
 भा.रा.रा.प्रा.प.का.ई. छतरपुर (म.प्र.)
 NHAI, PIU-CHHATARPUR (M.P.)



 Er. S.S. Tomar
 Executive Engineer
 Const. Div. (Civil)
 U.P. Jal Nagam, Mahoba

Chhatarpur (M.P.)


5.2	Renewal of Bank Guarantee.	NA	
5.3	Confirmation all standard condition of NHAI,s guidelines.	Yes, enclosed	
5.4	Shifting of OFC/cable as and when required by NHAI.	Yes, enclosed	
5.5	Shifting due to 6-laning / widening of NH.	Yes, enclosed	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes, enclosed	
5.7	Traffic movement during laying of OFC/cable to be managed by the applicant	Yes, enclosed	
5.8	If any claim is raised by the concessionaries, then the same has to be paid by the applicant.	Yes, enclosed	
5.9	Certificate for 6-laning from the applicant in following format. "We do undertake that I will relocate service road/approach. Road/utilities at my own cost notwithstanding the permission granted within such time as will be stipulated by NHAI for future six-laning or any other development."	Yes, enclosed	
6.	Affidavit /Power of attorney in favor of authorized signatory.	Affidavit enclosed	
7.	Copy of DOT license	No	State Govt. project.
8.	Certificate from the Project Director	Yes, enclosed	
8.1	Certificate from confirming of all standard condition issued vide Ministry Circular no. RW/NH-33044/27/2005/S&R(R)(Pt.) dated 7/8/2013 & dated 22.11.2016	Yes	
8.2	Certificate for 6-laning from PD in the following format	Already 4-lane	
	(a) Where feasibility is available "I do certify that there will be no hindrance to proposed 6-laning base on the feasibility report considering proposed structure at the said location.	NA	
	(b) in case feasibility report is not available "I do certify that sufficient ROW is available at site for	NA	


SANJAY SHARMA
 Dy. Manager (Tech)
 NHAI PIU Chhatarpur (M.P.)



 परियोजना निदेशक
 Project Director
 भा.रा.स.प्रा.प.का.ई. छतरपुर (म.प्र.)
 NHAI, PIU-CHHATARPUR (M.P.)


Er. S.S. Tomar
 Executive Engineer
 Const. Div. (Civil)
 U.P. Jal Nagam, Mahoba

	accommodate proposed 6-laning".		
9.	As per guidelines licensee fee shall be charged.	Department will pay fee after issuing demand note	
10.	If NH section proposed to be taken up NHA1 on BOT basis-a clause in Para 17 to be inserted in the agreement. "The permitted Highway on which licensee has been granted the right of way to the concessionaire under the concession agreement for up-gradation of [... section from km.....to km..... of NHA1 no..... on Build, Operate and Transfer Basis]	NA	
11.	Who will supervise the work of laying of OFC/cable	Office of the Executive Engineer, U. P. Jal Nigam(Rural), Construction Division, Mahoba.	
12.	Who will ensure that the defects in road portion after laying of OFC/cable are corrected and if not corrected then what action will be taken.	Office of the Executive Engineer, U. P. Jal Nigam(Rural), Construction Division, Mahoba.	
13.	Who will pay the claims for damages/ done/disruption in working of concessionaire.	Office of the Executive Engineer, U. P. Jal Nigam (Rural), Construction Division, Mahoba.	
14.	A Certificate from PD that he will enter the proposed permission in the register of records of the permissions in the prescribed perform (copy enclosed) issued vide Ministry Circular RW/NH- 33044/27/2005/S&R(R)(Pt.) dated 7/8/2013	Yes	
15.	If any previous approval is accorded for laying of cable, then photocopy if register of records of permissions accorded as maintained by PD (as per ministry circular no. RW/NH- 33044/27/2005/S&R(R)(Pt.) dated 7/8/2013	NA	


SANJAY SHARMA
 Dy. Manager (Technical)
 NHAI PIU Chhatarpur (M.P.)


 परियोजना निदेशक
 Project Director


Er. S.S. Tomar
 Executive Engineer
 Const. Div. (Civil)
 U.P. Jal Nagam, Mahoba

मो.रा.रा.प्रा.प.का.ई. छतरपुर (म.प्र.)
 NHAI, PIU-CHHATARPUR (M.P.)