

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India) क्षेत्रीय कार्यालय-पश्चिम उ**०**प्र**0**, लखनऊ Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.) 3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Fliune : 0522-4900291, टेलीगेयल / Fax : 0522-4950880 ई-मेल / E-mail : rowestup@nhai.org, rowestup@gmail.com



Date: 17.02.2023

19001/1/RO-W-UP/NH-58/M-M/Ch.55.800-53.300/DFCCIL/1874
Invitation of Public Comments

Sub: Regarding NOC for 11kV feeder line through an underground Cable at NH-58 Ch.55.800 and overhead feeder line along the NH-58 from Km.55.800 to Km.53.300 for electrical connection to DFCCIL crossing station & New Partapur Station- reg.

The Authorized Signatory M/S DFCCIL, Meerut has submitted the proposal for granting NOC permission for 11kV feeder line through an underground Cable at NH-58 Ch.55.800 and overhead feeder line along the NH-58 from Km.55.800 to Km.53.300 for electrical connection to DFCCIL crossing station & New Partapur Station in the State of Uttar Pradesh.

- 2. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/ 2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safely and general public interest).
- 3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The General Manager cum Regional Officer, National Highways Authority of India Regional Office, UP-West, Lucknow 3/248, Vishal Khand, Gomti Nagar Lucknow-226 010

This is issues with the approval of RO-West (UP). **Encl:** As above.

N.P. Singh)
DGM (T)

For RO-West, UP

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.

2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.

3. The Authorized Signatory, M/s DFCCIL, Meerut for information.

4. The PD, PIU-Meerut for information.

प्रधान कार्यालय : जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075 ● दूरभाष : 91-11-25074100, 200 ● वेबसाइट : www.nhai.gov.in Corporate Office : G-5 & 6, Sector - 10, Dwarka, New Delhi - 110 075 ● Phone : 91-11-25074100/200 ● Website : www.nhai.gov.in

CHECK-LIST

Guidelines for processing the proposal for laying of Utility line in the land along National Highways vested with NHAI/PWD/BRO.

General Information

1. Name and Address of the

Applicant/Agency

: Exective Engineer, PVVNL EDD-I, Meerut, 250001

PVVNL

2. National Highway No.

NH-58

3. State

: Uttar Pradesh

4. Location

:Near Village Mehrauli, District- Meerut

5. Chainage No.

NH/Chainage 55/800

6. Length in m

: 48.5m

7. Width of available ROW in both sides

13.15+13.15 = 26.5m

8. Side of NII

(Left or right side of NH towards increasing

Chainage/Km direction)

Delhi to Muzaffarnagar

9. Name of Highway Authority of NHAI/PWD/BRO

NHAI(NH-58)

10. Highway Administration address

PIU-Meerut

R.O. -

Project Director
National Highways Authority of India
PIU - Meerut

| Sl. No | Item | Measurement. Observations as per site conditions | MORTH Norms | Whether complying with MORTH Norms |
|-----------|--|--|---|---|
| 1 | Details of already laid utility service, if any | Not applicable | Enclosed | Yes |
| 2 | Whether up gradation of the stretch in near future is proposed or not | No | | Yes |
| | (a) If yes, provision of utility adversely affects the plan of upgradation | | Not affect plan of up- gradation | Yes |
| 3 | Laying of the utility service along the National Highways. | | | |
| 3.1 | Location of proposed utility service along the stretch | Not applicable | Utility Duct/ beyond the toe line of the embankment and drains, and close to the extreme edge of the ROW. | Yes |
| 3.2 | Depth of top of utility service from ground level | Not applicable | 0.6 meter | Yes |
| 3.3 | Mechanism for crossing water channel | Not applicable | Through utility duct (if provision exists) or beneath the bed of water channel | Yes |
| 3.4 | Whether ROW is restricted in this stretch? | Not applicable | | Yes |
| 3.4.1 | If yes, whether provision of land acquisition is required to lay utility | Not applicable | | Yes |
| | (a) If yes, whether undertaking for land acquisition along with relevant L.A. details has been furnished | Not applicable | | Yes |
| 3.4.2 | Width of concrete duct, if utility services are proposed to be laid in concrete ducts | Not applicable | Not less than one lane | Yes |
| 4 | Laying of utility services across the NH | | | |
| 4.1 | Whether Existing drainage structures is allowed to carry the utility lines. | Not applicable | Not to be allowed | Yes |
| 4.2 | Proposed crossing of utility service | Perpendicular to NH | Perpendicular to NH | Yes |
| 4.3 | Type of casing pipe/conduit carrying the utility line. | Not applicable | Steel, cast iron, or reinforced cement concrete and have adequate strength | Yes |
| 4.4 | Whether ends of the casing/conduit pipe are sealed from the outside | Not applicable | Sealed | Yes |
| 4.5 | Length of casing/conduit pipe crossing NH. | Not applicable | Extend from drain to drain in cuts and toe to toe of slope in the fills | Yes |
| 4.6 | Depth of top of the casing/conduit pipe. | Not applicable | At least 1.2 m below the top of subgrade | Yes |

Project Director
National Highways Authority of India
PIU - Meerut

| 4.7 | Crossing method in case of CC pavement. | Not applicable | Only boring method (HDD) | Yes |
|-----|--|---|--|-----|
| 4.8 | Horizontal and vertical clearances in case utilities are allowed overhead, | Profile Enclosed (Through underground Caballing) | In accordance with IRC codes. | Yes |
| 5 | Document I Drawings enclosed with the proposal | | | |
| 5.1 | Cross-Section showing the size of trench for open trenching method | Not applicable | Enclosed, if applicable | Yes |
| | (a)Trench width | Not applicable | More than 30 cm and less than 60 Cm wider than the outer diameter of the utility pipe | Yes |
| | (b) Filling of trench | Not applicable | As per Ministry guidelines vide letter No. RW/NH-34044/ 29/2015/S&R (R) dated 22.11.2016 | |
| | (c) location of trench | Not applicable | extreme edge of the ROW | Yes |
| 5.2 | Cross section showing the size of pit and location of conduit for HDD method | Not applicable | Not applicable in case of Overhead transmission line. | Yes |
| 5.3 | Strip plan/ Route plan showing utility line, chainage, width of ROW, distance of proposed utility from the edge of ROW, important mile stone, intersections, cross drainage works etc. | Enclosed. As per annexure | Enclosed | Yes |
| 5.4 | Plan and profile drawing of stretch showing cross section of road at 20m distance along with ROW and proposed utility | Enclosed. As per Drawing(annexu re) | Enclosed | Yes |
| 6 | Methodology for laying of utility line. | Enclosed. As per annexure | Enclosed | Yes |
| 7 | Draft License Agreement is as per Ministry guidelines vide letter No. RW/NH-34044/29/2015/S&R (R) dated 22.11.2016 and signed by two witnesses | YES | Enclosed | Yes |
| 8 | License fees in Favor of NHAI | | As per Ministry vide circular no. RE/NH-33044/29/2015/S&(R)d ated 22.11.2016 | |
| 9 | Whether Bank Guarantee has been obtained | | As per Ministry vide circular no. RE/NH-33044/29/2015/S&(R)d ated 22.11.2016 | |
| | (a) If yes, whether Confirmation of BG has been obtained as per MoRTH/NHAI guidelines | Project Director | | M |

मेरढ

16

| 10 | Affidavit / Undertaking from the Applicant for | | | |
|------|---|-----|----------|-----|
| 10.1 | Undertaking for not to damage other existing utility, if damaged then to pay the losses to either to MoRTH/NHAI or to the concerned agency. | | Enclosed | Yes |
| 10.2 | Undertaking for renewal of Bank Guarantees and when asked by NHAI/ MoRTH | Yes | Enclosed | Yes |
| 10.3 | Undertaking for confirming all standard condition of MoRTH/NHAI guidelines. | Yes | Enclosed | Yes |
| 10.4 | Undertaking for shifting of utility as and when asked by MoRTH/NHAI within a month at their own cost. | YES | Enclosed | Yes |
| 10.5 | Undertaking for indemnity against all damages and claims. | YES | Enclosed | Yes |
| 10.6 | Undertaking for management of traffic movement during laying of utility line without hampering the traffic. | YES | Enclosed | Yeз |
| 10.7 | Undertaking that If any claim is raised by the Concessionaire/contractor then the same has to be paid by the applicant | YES | Enclosed | Yes |
| 10.8 | Undertaking that the applicant has obtained various safety clearances from the representative authorities such as directorate of Electricity, | Yes | Enclosed | No |
| | Chief controller of Explosives, Petroleum and Explosive Safety Organization, Oil Industry Safety Directorate, State/Central Pollution Control Board and any other statutory clearance s applicable, before applying to Highway Administration | | | |

The Right of the Way (ROW) of the National Highway available at the proposed location from the center line of divided carriageway is 30m (from center of ROW to edge of ROW towards proposed utility)

The above particulars along with the drawings and documents have been verified and certified as correct as per prevailing site conditions.

[Name Designation and signature of the authorized representative of applicant] National Highways Authority of Inature of Concerned field authority of NHAI/PWD/BRO

विद्युत वितरण खण्ड-प्रथम

(17)