



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", तिसरी मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office : "Narang Tower", 3rd Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur-440 001 Maharashtra
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला
सत्यमेव जयते

NHAI/RO-NAG/OFC/NH-361/HT Lines/Power Grid/Ut/2020/1265

Date : 05.10.2020

Invitation of Public Comments

Sub: Proposal for grant of permission for crossing of diversion of existing 400 KV D/C (Quad Bundle), Mouda Wardha Transmission Line (O/H Crossing), near Narayanpur, Tahsil-Deoli, Dist. Wardha of Power Grid Corporation of India Limited on Wardha-Yavatmal Section of NH- 361 – Reg.

Ref.: (i) PD, PIU, Yavatmal Lr.No.NHAI/PIU/YTL/NH-361/YW/Crossing/2019/2010/2010, dated 12.09.2020
(ii) Power Grid Lr.No.WR-1/WRD/AM/TMLM/MW/NH 361 Crossing/1175/811, dated 12.06.2019

* * *

It is to inform all concern that the Power Grid Corporation of India Limited, Deoli, Wardha vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Yavatmal has submitted the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by Power Grid Corporation of India Limited, Deoli, Wardha for crossing of 400 KV DC (Quad Bundle), Mouda – Wardha Transmission Line from Km.460.875 to Km.461.875 on Wardha-Yavatmal Section of NH- 361 is as detailed below:

- (i) Crossing of 400 KV DC (Quad Bundle) Mouda – Wardha Transmission Line (O/H Crossing) from Km.460.875 to Km.461.875 on Wardha-Yavatmal Section of NH361, near Narayanpur, Tahsil-Deoli, Dist. Wardha, Maharashtra.
- (ii) Height of the Vertical Clearance – 19.0m
- (iii) Distance of Horizontal Clearance - - 135m (from Centre to Tower No.337A) and 55.7m (from Centre to Tower No.338A)
- (iv) Angle of Crossing at 66° 56' 50" to the NH-361

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

Contd...2

- : 2 : -

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to crossing of 400 KV DC (Quad Bundle), Mouda – Wardha Transmission Line on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 04.11.2020, beyond due date, no comments/ objections will be accepted.

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

N. Wadtekar
05.10.20

(Naresh Y. Wadtewar)
General Manager (Tech.)
NHAI, RO, Nagpur

To

(i) Web Admn., NHAI, HQ, New Delhi
[web-admin@nhai.org]

- for uploading in NHAI's website

(ii) Director, NIC, New Delhi [mansoor@nic.in]

- for uploading in Ministry's website