

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण (सड़क परिवहन और राजमार्म मंत्रालय) National Highways Authority of India (Ministry of Road Transport & Highways) क्षेत्रीय कार्यालय, मदुरे / Regional Office, Madurai दूसरा व तीसरी तल, विजय कृष्ण प्लाज़, संख्या-1 लेक परिया, मेलूर मेन रोड, माइतावर्नी, मदूरे-625 107 2" & 3" floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



NHAI/15018/3.7.3/2019/RO Madurai/E:78728/1453

16th August 2021

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - Highway Administration - Operation and Maintenance of Madurai - Aruppukottai section from Km.138.800 to Km.266.865 of NH-45B in the State of Tamil Nadu - Erection of 33 KV Overhead Electrical Line along the road from Km.150+220 to Km.151+060 RHS by <u>M/sEnerjay Green Pvt Ltd</u>.

The proposal is regarding permission for Erection of 33 KV overhead electrical line along the road from NH from Km.150+220 to Km.151+060 RHS in Madurai - Aruppukottai section of NH-45B in the state of Tamil Nadu in accordance with Ministry's latest guideline dated 22.11.2016.

2. The alignment proposed by the Enerjay Green Pvt Ltd, Rajapalayamfor Erection of 33 KV overhead electrical line along the road NH fromKm.150+220 to Km.151+060 RHS in Madurai - Aruppukottai of NH-45 in the State of Tamil Nadu as detailed under:

SI. No	Description	Length in Meters	Width in meters	Name of Village	Remarks
Along the Road NH From Overhead Transmission line					
1	Km.150+220	840	1.0	Aviyur	Manual Erection of 33
	to				KV DC Tower Line
	Km.151+060				

3. The Right of Way is 60 m in the aforesaid stretch. The proposed Erection of 33 KV overhead electrical line along the road NH fromKm.150+220 to Km.151+060 in Madurai - Aruppukottai section of NH-45B. Further, the Enerjay Green Pvt Ltd, Rajapalayamhas given undertaking that the vertical clearance 12 from the Natural Ground level of the road which is in conformity with Ministry's latest guidelines dated 22.11.2016.

4. The applicant has furnished an undertaking that they will shift the erected electrical line in future when required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed erection of 33 KV overhead electrical line work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made

available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer National Highways Authority of India No.2nd& 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai - 625 107

Yours Faithfully,

(MS Chaithanya), Manager (Tech.),

То

- 1. NHAI Website.
- 2. The NIC, New Delhi For uploading in the Ministry's Website.
- 3. PD, PIU, Tuticorin.