

No. RO/Chennai/MoRTH/12017/NH-381/PER/056/2023-24

GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

Regional Office, Chennai.

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.

Email: cerochennaiomorth@gmail.com, Tele Off: 24919341.

Date: 03rd December 2024

Invitation of public comments

Subject:- Permission proposal for laying of 110KV, 1Cx630 sq.mm (3 Runs) underground Electrical Cable Line across the National Highways at Km 10/300 of NH-381(Avinashi-Tiruppur- Avinashipalayam Road) of Tiruppur District in the state of Tamil Nadu -Reg.

The proposal is regarding request for permission for laying of 110KV, 1Cx630 sq.mm (3 Runs) underground Electrical Cable Line across the National Highways at Km 10/300 of NH-381(Avinashi-Tiruppur- Avinashipalayam Road) of Tiruppur District in the state of Tamil Nadu by the Executive Engineer, Transmission line Construction, TANTRANSCO, Perundurai resubmitted to this office by the SE (NH), Salem vide letter No. 3322/2023/JDO/NH/ dated 14.11.2024. The proposal has been examined and the details are as under:

Stretch in Km	Length(m)	ROW (m)
Crossing (by HDD method) Electrical cable line with 200 dia mm MS casing pipe 3Nos & 40mm dia HDPE duct with 24F OFC.		
At Km. 10/300	22.80	22.80m

2. The Right of Way in the stretch of NH proposed for laying Electrical Cable line is 22.80m. The carriageway width of stretch at Km. 10/300 of NH-381 is 17.30m. The Executive Engineer, Transmission line Construction, TANTRANSCO, Perundurai has proposed to laying 110KV, 1Cx630 sq.mm (3 Runs) underground Electrical Cable Line across road by adopting trenchless method at a depth of 2.30m from the bottom of the road.

3. The Executive Engineer, Transmission line Construction, TANTRANSCO, Perundurai has furnished an undertaking to the effect that they will remove the laid Public Utility Electric cable line in future if required by NH Authorities/MoRTH, Government of India at any time for expansion of the NH at their own cost without claiming any compensation from NH Authorities/MoRTH, Government of India and any right on the NH land. Further, mentioned that, the Executive Engineer, Transmission line Construction, TANTRANSCO, Perundurai will also restore the ROW surfaces to its original condition soon after removal of the Public utility Electric cable lines. Also, certified that the proposed Public Utility work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

Handwritten signature
03/12/2024

5. In view of above, comments of the public are invited if there is any objection/claim^s (on ground of public inconvenience, safety and general public interest) on the above proposal to the below mentioned address:

The Regional Officer, Chennai,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090
E Mail. Id- rochennai.rth@gov.in

Yours Sincerely,

Dhanapalan
03/12/2024

(Dhanapalan.K)
Executive Engineer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The SE, NH Circle, Salem-for information please.

(Dhanapalan.K)
Executive Engineer
For Regional Officer