



No. RO/BBSR/Utility Services/NH-153B/SMBP/124/2025 - 2592

Date: 03rd Feb, 2026

Invitation of Public Comments

Sub: Proposal for laying of water pipeline along/across NH-153B on selected stretches from km 380 to 82/60 for “execution of Rural Piped Water Supply Project pertaining to 42 GPs of Rairakhol constituency of Sambalpur district including five years operation & maintenance under one package” - reg.

Superintending Engineer, National Highway Division, Sambalpur vide letter dated 20.01.2026 has submitted a proposal on the mentioned subject as detailed below:

Sl. No.	NH Chainage	Available RoW (m)	Dia of Pipe including casing (mm)	Carriageway width (m)	Depth of laying of utility from GL	Length (km)	Methodology
1	38/00 to 38/40 (BHS)	16.0	160	10.0	0.90 m	0.800	Open trench
2	41/60 to 44/00 (LHS)	16.0	90/160	10.0	0.90 m	2.400	Open trench
3	44/00 to 46/50 (RHS)	16 to 22	90	10.0	0.90 m	2.500	Open trench
4	46/50 to 48/00 (LHS)	19.0	200	10.0	0.90 m	1.500	Open trench
5	48/00 to 54/00 (BHS)	16 to 28	125/160/200	10.0	0.90 m	12.000	Open trench
6	54/00 to 75/00 (LHS)	19 to 27	150/200	10.0	0.90 m	21.000	Open trench
7	40 no crossings	20	-	-	1.20 m	0.800	HDD
	Total					41.000	

2. As per Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22nd November, 2016 the Highway Administrator will put out the application in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest, if any).

3. In view of the above, comments of public for claims/objections, if any, on the above proposal are invited online as well as in hard copy. The strip plan/location details are enclosed herewith. The same should reach to the below mentioned address within 30 days from the date of uploading it in the website, beyond which no objection will be considered.

Address:

Regional Officer,
Ministry of Road Transport & Highways,
Plot No -184, Near Fire Station Sq.,
Baramunda, Bhubaneswar - 751003.

Yours faithfully,

Encl: As above

2026-03-02
(Sudhansu Sekhar Sahu)
Senior Technical Assistant
For Regional Officer

Copy to:

- 1) The Senior Technical Director, NIC, Transport Bhawan, New Delhi - 110001- along with strip chart for uploading on the Ministry's website.
- 2) General public with request to furnish comments, if any, to the above mentioned address or by e-mail to “robsr.morth@gmail.com”

Copy for information to:

- 1) The Superintending Engineer, National Highway Division, Sambalpur.



**OFFICE OF THE SUPERINTENDING ENGINEER,
NATIONAL HIGHWAY DIVISION, SAMBALPUR**

At/Po/Dist.-Sambalpur (Brooks Hill), Pin-768001, E-mail Id: eenhsbp@yahoo.in

Letter No.: 303/WB

Date: 20.01.2026

To
**The Regional Officer,
MoRT&H, Bhubaneswar.**

बायरी संस्था
तारीख: 30/1/2026
संडक परिवहन अमर राजमार्ग मंत्रालय
क्षेत्रीय कार्यालय, भुवनेश्वर

Sub: Resubmission of proposal for "Execution of Rural Piped Water Supply Project Pertaining to 42 GPs of Rairakhol constituency of Sambalpur District including five years Operation & Maintenance under one package - Regarding approval of Methodology, Drawing, draft calculation sheet for License fees, Performance Security & Damaging Cost."

Ref: (i) Your good office letter no. RO/BBSR/Utility Services/NH-153(B)/SMBP/124/2025-1097 Dt. 25/08/2025.
(ii) Letter No.76, Dtd.15.01.2026 of SE RWS&S Division Sambalpur.


Sir,

With kind reference to the letters on the subject cited above, it is to submit herewith the proposal for "Execution of Rural Piped Water Supply Project Pertaining to 42 GPs of Rairakhol constituency of Sambalpur District including five years Operation & Maintenance under one package" as received from SE RWS&S Division Sambalpur vide letter u/r-(ii) along with the methodology & drawing. Accordingly revised draft calculation sheet for License fees, Performance Security & Damaging Cost has also been enclosed.

The aforesaid documents are submitted for your kind perusal and further necessary instruction.

Encl.: As above

Yours faithfully,


20/1/26
Superintending Engineer
NH Division, Sambalpur

Memo No.: 304 Dt.: 20.01.2026

Copy submitted to the Collector & District Magistrate, Sambalpur, for favour of kind information and necessary action.


20/1/26
Superintending Engineer
NH Division, Sambalpur

Memo No.: 305 Dt.: 20.01.2026

Copy submitted to Chief Construction Engineer, NH Western Circle, Sambalpur for favour of kind information and necessary action.


20/1/26
Superintending Engineer
NH Division, Sambalpur

Memo No.: 306 Dt.: 20.01.2026

Copy submitted to the Superintending Engineer, RWS&S Division, Sambalpur, for information and necessary action.


20/1/26
Superintending Engineer
NH Division, Sambalpur

Please enclose on priority.
21/01/26

Sr. TA

Memo No.: 307 Dt.: 20.01.2026

Copy submitted to the Executive Engineer, N.H. Sub-Division, Sambalpur/ JE, NH Section Naktideul & Rairakhol-I for information and necessary action.


20/1/26
Superintending Engineer
NH Division, Sambalpur



ଅଧିକାରୀ ଯନ୍ତ୍ରୀଙ୍କ କାର୍ଯ୍ୟାଳୟ,
ଶ୍ରୀମତୀ ପାତ୍ରମାତ୍ରା ପରିମଳ ଶାହ, ସମ୍ବଲପୁର
OFFICE OF THE SUPERINTENDING ENGINEER,
RWS&S DIVISION, SAMBALPUR

ମୋଟିଝର, କୁକୁରିଲ, ରୀ.ସ୍.ସ୍. ଖେଳପିଠା
ସମ୍ବଲପୁର, ୭୬୮୦୦୧
At-Motijharan , Brooks Hill in front of
VSS Stadium Main gate-768001
Email ID-eerwsssbp@gmail.com

Letter No. - ୭୬ /RWSS, Date - ୧୯. ୦୧. ୨୦୨୬

To

The Superintending Engineer,
NH Division, Sambalpur.

Sub: Submission of drawing of alignment & crossing of water supply pipeline (DI/HDPE) along and across the NH-153B in Nakideul block for the work "Execution of Rural Piped Water Supply Project Pertaining to 42 GPs of Rairakhol constituency of Sambalpur District including five years Operation and Maintenance under one package".

Ref: 1. This Office Letter no 372, Dt 03.03.2025
2. This Office Letter no 1196, Dt 25.07.2025
3. Letter No 203, Dt 19.11.2025 O/o the AEE, RWS&S Sub-Division, Rairakhol
4. This Office Letter no 2503, Dt 27.11.2025
5. Letter No 39, Dt 03.01.2026, O/o the Executive Engineer, NH Division, Sambalpur

Sir,

In continuation to this office Letter No 2503, Dated 27.11.2025, I am hereby submitting the revised chainage length details, Checklist, Joint site Inspection Report, Benchmark valuation report and Undertaking for the work "Execution of Rural Piped Water Supply Project Pertaining to 42 GPs of Rairakhol constituency of Sambalpur District including five years Operation and Maintenance under one package".

Therefore, you are hereby kindly requested to examine the submitted documents and accord necessary approval at the earliest so that the execution of the work may proceed without delay.

Yours faithfully

Encl: As Above

Re
15/01/26
Superintending Engineer
RWS&S Division, Sambalpur
Re
15/01/26

CC to:

- 1) The Addl. Chief Engineer RWSS Circle Sambalpur for kind information and necessary action.
- 2) The SDO, RWSS Sub-Division Rairakhol for information and necessary action.
- 3) The Project Manager M/s KEC-Kaveri JV for information.



ଓଡ଼ିଶା ୭୯୫୫

79AA 160014

We Office of the Superintending Engineer, Rural Water Supply & Sanitation Division, Sambalpur -768001 hereby agree that:

1. Office of the Superintending Engineer, Rural Water Supply & Sanitation Division, Sambalpur - 762001 shall be solely responsible / liable for full compensation / indemnification of concerned agency / aggrieved owners for any direct or indirect or consequential damage caused to them / claim or replacements bought for at cost and risk.
2. Pipeline would be laid keeping in mind future expanding lining of the NH. However, we also agree that we shall shift the cables / ducts within 30 days (or as specified by the respective agency / owner) from the date of issue of notice by the concerned owner to shift / relocate the pipeline in case it is required for the purpose of line improvement / widening of the road / route / highway or construction of flyover / bridge and restore the road / land to its original condition at our own cost and risk.
3. We will not violate the instruction of MORTH (Ministry of Road Transport & Highway) New Delhi.
4. It is undertaking that the pipeline will be carried out on the outside of railing / parapets of the bridge / culverts and supported by brackets and fixed outside of the bridge super-structure or as design approved by the Engineer in-charge.
5. Pipeline will be laid under link road by boring system.
6. The agency will notify the concerned Executive Engineer at least 15 days in advance before digging trenches along with the road.
7. Adequate arrangement for cautioning the traffic by way of caution board during daytime and danger light at night will be provided by the agency and we will manage the movement during laying of utility line without hampering the traffic.
8. Each day's the extent of digging trenches should be strictly regulated so that the pipeline is laid and trenches fills up before the close of work that day, the filling should be completed to satisfaction of Engineer in-charge.
9. The agency shall indemnify the road all the damages, if any, due to the digging of trenches for the laying of the pipeline.
10. That if any claim is raised by the concessionaire / contractor then the same must be paid by the applicant.
11. It is undertaking that we will renew the bank guarantees and when asked by MORTH / NH.
12. It is undertaking that we will follow all standard condition of MORTH / NH guidelines.

Authorized Signatory

Date:

Rel 15/10/2026
 Superintending Engineer
 RWS&S Division, Sambalpur

122

13.1.26

SOLD TO S. E. RWSS, SBL

NAME Ritesh Sahu

NO: 1111 NO

RESIDENT OF Dhankeli

Dhankeli DIST Sambalpur

G. S. Supra

**G. S. SUPRA
STAMP VENDOR
SAMBALPUR**

21 NOV 2025

RECEIVED BY TREASURY

Ritesh Sahu

Site inspection report for Road cutting permission for laying of pipeline along/across from km 37.900 to km 82.600 at NH-153B

Sl. No.	Chainage From	Chainage To	Length (in Km)	Side of laying (LHS/RHS/crossing)	Available ROW(ft)	Width of carriage way (mtr)	Embankment height (mtr)	Dia of proposed utility (mtr)	Methodology (Open Trench/HDD)	Depth of laying utility from ground level	Width of trench (open trench)	Remarks
1	38.00	38.40	0.4	LHS/RHS	16	10 mtr	3	160	Open Trench	900 mm	1000 mm	2L
2	41.60	43.00	1.4	LHS	16	10 mtr	3	90	Open Trench	900 mm	1000 mm	2L
3	43.00	44.00	1	LHS	16	10 mtr	3	160	Open Trench	900 mm	1000 mm	2L
4	44.00	46.00	2	RHS	16	10 mtr	3	90	Open Trench	900 mm	1000 mm	2L
5	46.00	46.50	0.5	RHS	22	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
6	46.50	48.00	1.5	LHS	19	10 mtr	3	125	Open Trench	900 mm	1000 mm	2L
7	48.00	50.00	2	RHS	22	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
8	48.00	50.00	2	LHS	22	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
9	50.00	51.00	1	RHS	16	10 mtr	3	125	Open Trench	900 mm	1000 mm	2L
10	50.00	51.00	1	LHS	16	10 mtr	3	160	Open Trench	900 mm	1000 mm	2L
11	51.00	52.00	1	RHS	19	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
12	51.00	52.00	1	LHS	19	10 mtr	3	160	Open Trench	900 mm	1000 mm	2L
13	52.00	54.00	2	RHS	28	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
14	52.00	54.00	2	LHS	28	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
15	54.00	55.00	1	LHS	26	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
16	55.00	56.00	1	LHS	19	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
17	56.00	57.00	1	LHS	25	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
18	57.00	60.00	3	LHS	26	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
19	60.00	63.00	3	LHS	26	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
20	63.00	65.00	2	LHS	27	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
21	65.00	66.00	1	LHS	20	10 mtr	3	200	Open Trench	900 mm	1000 mm	2L
22	66.00	67.00	1	LHS	20	10 mtr	3	150	Open Trench	900 mm	1000 mm	2L
23	67.00	69.00	2	LHS	24	10 mtr	3	150	Open Trench	900 mm	1000 mm	2L
24	69.00	71.00	2	LHS	24	10 mtr	3	150	Open Trench	900 mm	1000 mm	2L
25	71.00	75.00	4	LHS	27	10 mtr	3	100	Open Trench	900 mm	1000 mm	2L
26	75.00	77.00	2	LHS	Forest	10 mtr	3	100	Open Trench	900 mm	1000 mm	2L
27	77.00	82.60	5.6	LHS	Forest	10 mtr	3	100	Open Trench	900 mm	1000 mm	2L

Superintending Engineer
RWS&S Division, Sambalpur

eis
Sambalpur
RWS&S Division, Sambalpur

SITE INSPECTION REPORT

The proposal for permission regarding- "**Execution of Rural Piped Water Supply Project pertaining to 42 GPs of Rairakhol Block (constituency) of Sambalpur district including five years Operation & Maintenance" under One Package**" on EPC contract against LOA Letter No.: 330 Dated: 10-01-2022: Cutting & laying along NH-153B was inspected at the respective chainage in respect of the documents and layout plan submitted by the RWSS Division, Sambalpur. It was found that the aforesaid work is feasible and in order as per Ministry's Guideline dt.22.11.2016 as well as the amendment circular dt. 17.04.2023. Hence the proposal recommended for approval subject to referring the following special notes:-

1. The water supply pipeline should be laid at the extreme edge of R.O.W specified under the list with a minimum depth of 1.2m below road level, however at restricted area where their shortage of ROW the water supply pipeline can be laid beyond the carriageway with minimum depth as mentioned above.
2. The pits should be properly filling the compaction with sand and water & debris should be removed.
3. No structure of road or C.D. work should be damaged during laying of water supply pipeline.
4. No road crossing is allowed. However, whenever water supply pipeline is required to be laid, it can only be transferred from one side of the road to other through HDD Method.
5. Damages to the OFC, trees, electric poles and other existing utilities should be avoided. In case of such an event, the damages must be repaired to the original condition and any public losses or inconvenience caused shall be the sole responsibility of the Licensee.

Ref 15/01/26
Superintending Engineer
RWSS Division, Sambalpur
15.01.26

09/12/2025
Junior Engineer
N.H. Section Naktideul

9/12/2025
Asst. Executive Engineer
NH Sub-Division, Sambalpur

15/01/26
J. Saha
Superintending Engineer
N.H. Division, Sambalpur