



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / **Regional Office, Madurai**

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



NHAI/15018/4.2/16/2022/RO Madurai/E:164448/2745

02nd December, 2022

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, RO Madurai - PIU- Trichy - Padalur - Trichy section of NH 38 -TWAD Board providing water supply scheme to Koodapalli & 97 Habitations in Manachanallur and Musiri Union of Trichy District - laying of underground water Pipeline along the extreme edge of the NH 38 boundary from Km 300+900 (LHS) to Km 303+300 (LHS) and Km 300+670(RHS) to Km 301.100(RHS) and across Km 301+100 Invitation of Public Comments - Reg.

The Proposal is regarding permission for laying of water supply pipeline from

- a. Along the road by open trench method in the following chainages:
 - i. from Km 300+920(LHS) to Km 301+100(LHS) @ 90 mm Diameter HDPE pipe.
 - ii. from Km 301+100(LHS) to Km 303+300(LHS) @ 75 mm Diameter HDPE pipe.
 - iii. from Km300+670(RHS) to Km 301+100(RHS) @ 110 mm Diameter HDPE pipe.
- b. Across the road by HDD method in the following chainages:
 - i. Km 301+100(RHS) @ 110 mm Diameter Encasing pipe.

The laying of underground water pipeline has been proposed in section of NH-38 by Executive Engineer, TWAD Board, Urban Division, Trichy.

2) Executive Engineer, TWAD Board, Urban Division, Trichy has proposed to lay the Water supply pipeline for a length of 2810 m along the edge of the ROW, at a distance of 1.5m from ROW edge and across the project at a depth of 1.2m belong ground level.

(Signature)

National Highways Authority of India


NHAI/15018/4.2/16/2022/RO Madurai/E:164448/2745

02nd December, 2022

- 3) Executive Engineer, TWAD Board, Urban Division, Trichy has mentioned that the Water supply pipeline along the NH by Open Trench Method at a depth of 1.20m for along portion and by HDD at a depth of 1.20m for across portion.
- 4) Executive Engineer, TWAD Board, Urban Division, Trichy has furnished an undertaking to the effect that the applicant will remove the laid Water supply pipeline in future if required by NHAI/MoRTH, Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation. Further, mentioned that Executive Engineer, TWAD Board, Urban Division, Trichy will also restore the surfaces to its original condition soon after removal of the Water supply pipelines
- 5) As per the guidelines issued by the Ministry vide letter No.RW/NH33044/29/2015/ S&R(R) dated 22.11.2016 the proposal submitted by the applicant will be made available for public comments and the comments is invited within 30 days from the day of uploading. In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No.2nd & 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

Yours Faithfully,



(Mahendra Meena),
Dy. Manager (Tech.,)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Trichy - for information.