

No. RO/Chennai/MoRTH/12017/NH-532/PER/21/2024-25

GOVERNMENT OF INDIA
MINISTRY OF ROAD TRANSPORT & HIGHWAYS
Regional Office, Chennai.

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.
Email: cerochennaiomorth@gmail.com, Tele Off: 24919341.

Dated: 07th February 2025

Invitation of public comments

Subject:- Permission proposal for laying water pipe along the road from Km 55/840 to Km 57/800 (RHS), Km 57/800 to Km 59/550(LHS), Km 59/850 to Km 66/260(LHS) and across the road at Km 57/800 of NH-532 (Cuddalore-Vridhachalam-Salem Road) A.Chittoor - Vridhachalam Taluk, Cuddalore District in the state of Tamil Nadu by M/s Tirumavadi Bio-Energy Private Limited, Chennai -Reg.

The proposal is regarding requesting permission for laying water pipe along the road from Km 55/840 to Km 57/800 (RHS), Km 57/800 to Km 59/550(LHS), Km 59/850 to Km 66/260(LHS) and across the road at Km 57/800 of NH-532 (Cuddalore-Vridhachalam-Salem Road) A.Chittoor - Vridhachalam Taluk, Cuddalore District in the state of Tamil Nadu by M/s Tirumavadi Bio-Energy Private Limited, Chennai submitted to this office by the SE (NH), Chennai vide letter No.3050/2024/AE/NH dated 29.01.2025. The proposal has been examined and the details are as under:

Stretch in Km	Length (m)	ROW (m)	Dist. of Prop. Water pipe line from Centre of NH (m)
RHS Size of the pipe - 300mm DI pipe (by open trench)			
Km 55/840 to Km 57/800 (RHS)	1960	Varies 23.00 to 29.00m	Varies 9.00 to 15.00m at the extreme edge of the Right of Way
LHS Size of the pipe - 300mm DI pipe (by open trench)			
Km 57/800 to Km 59/550(LHS)	1750	Varies 23.00 to 27.00m	Varies 10.50 to 12.00m at the extreme edge of the Right of Way
Km 59/850 to Km 66/260(LHS)	6410	Varies 25.00 to 29.00m	Varies 10.00 to 14.00m at the extreme edge of the Right of Way
Size of pipe 300mm MS pipe & 600mm Dia MS casting pipe (by HDD method)			
Road Crossing at Km 57/800	23.00	23.00m	

2. The Right of Way in the stretch of NH proposed for laying Water pipe line is from 23.00m to 29.00m. The carriageway width of stretch from Km 55/840 to Km 57/800, Km 57/800 to Km 59/550, Km 59/850 to Km 66/260 and across the road at Km 57/800 of NH-532 is 10.00m to 20.00m. The applicant M/s Tirumavadi Bio-Energy Private Limited, Chennai has proposed to lay the underground Industrial Utility at edge of the ROW for a length of 10120m by adopting open trench method along the National Highway and HDD method crosses the National Highway at Km 57/800.

sath

3. M/s Tirumavadi Bio-Energy Private Limited, Chennai has furnished an undertaking to the effect that they will remove the laid Public Utility water pipe line in future if required by NH Authority/MoRTH, Government of India at any time for expansion of the NH at their own cost without claiming any compensation from NH Authority/MoRTH, Government of India and any right on the NH land. Further, mentioned that, the M/s Tirumavadi Bio-Energy Private Limited, Chennai will also restore the ROW surfaces to its original condition soon after removal of the Industrial utility water pipe lines. Also, certified that the proposed Industrial Utility work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

5. In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090
E Mail. Id-rochennai.rth@gov.in

Yours Sincerely,



(Satish)

Assistant Executive Engineer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The SE, NH, Chennai-for information please.

(Satish)
Assistant Executive Engineer
For Regional Officer