



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय)

National Highways Authority of India

(Ministry of Road Transport & Highways, Government of India)

क्षेत्रीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलसानी नगर,
रानीगरीतोटा, कृष्णालंका, विजयवाड़ा - 520 013, आंध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS No. : 373/2A, Kodandaramalayam, Chalasani Nagar,
Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh

फोन / Tele : 0866 -2483910, ई-मेल / E-mail : rovijayawada@nhai.org, nhairovja@gmail.com
वेब / Web : www.nhai.gov.in



Ref: NHAI/RO-VJA/HDPE Water Supply/2024-25/ 2323

Aug 08, 2024.

To

The Sr. Technical Director,
NIC, Transport Bhawan,
New Delhi- 110001.

Sub: NHAI, RO - Vijayawada - Providing of HDPE water supply distribution pipelines of Tanuku Municipality - Permission to lay pipeline through HDD across the NH-216A at Km.968+130 for a length of 40m in the State of Andhra Pradesh - Public comments - Reg.

Sir,

Please find enclosed herewith a proposal submitted by Dy. Collector & Commissioner, Tanuku Municipality seeking permission for providing HDPE water supply distribution pipelines across the NH-216A in the State of Andhra Pradesh for a length of 40m at Km.968+130 through HDD method.

2. As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R® dated 22nd November 2016, the application along with the recommendations of PD, PIU- Rajamahendravaram are enclosed herewith with a request to host the same in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest), for taking further necessary action.

Yours faithfully,

Encl: As above

(R.K. Singh, IES)

CGM (Tech.) & Regional Officer

Copy to:

- (i) PD, PIU - Rajamahendravaram
- (ii) Dy. Collector & Commissioner, Tanuku Municipality - for information.



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय)

National Highways Authority of India

(Ministry of Road Transport & Highways, Government of India)

क्षेत्रीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलासानी नगर,
रानीगरीतोटा, कृष्णालंका, विजयवाड़ा - 520 013, आंध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS No. : 373/2A, Kodandaramalayam, Chalasani Nagar,
Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh

फोन / Tele : 0866 -2483910, ई-मेल / E-mail : rovijayawada@nhai.org, nhairovja@gmail.com
वेब / Web : www.nhai.gov.in



Ref: NHAI/RO-VJA/HDPE Water Supply/2024-25/2322

Aug 08, 2024.

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, RO - Vijayawada - Providing of HDPE water supply distribution pipelines of Tanuku Municipality - Permission to lay pipeline through HDD across the NH-216A at Km.968+130 for a length of 40m in the State of Andhra Pradesh - Public comments - Reg.

The Project Director, PIU - Rajamahendravaram submitted a proposal of Dy. Collector & Commissioner, Tanuku Municipality seeking permission for providing HDPE water supply distribution pipelines across the NH-216A in the State of Andhra Pradesh for a length of 40m at Km.968+130 through HDD method.

As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R® dated 22nd November 2016, the Highway Administration will put out the application in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, the comments of public, if any, on the above mentioned proposal is invited on below mentioned address.

Regional Officer - Vijayawada,
National Highways Authority of India,
Regional Office, Dr. No.41-29-45A, R. S. No.373/2A
Near Kodandaramalayam, Chalasani Nagar,
Ranigarithota, Krishnalanka, Vijayawada - 520 013.
Email: rovijayawada@nhai.org

(R.K. Singh, IES)
CGM (Tech.) & Regional Officer



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Govt. of India)

परियोजना कार्यान्वयन इकाई - टोयोटा शोरूम के बाजू, राजमार्ग २१६ ए,
दिवांचेरुवु, राजमहेंद्रवरम - ५३३ १०२. आ.प्र.

PROJECT IMPLEMENTATION UNIT - Adjacent to Toyota Showroom,
NH-216A, Diwancheruvu, Rajamahendravaram - 533102, A.P.
द र ट / Phone : 0883 - 2431170 ई ईल / e-mail: raj@nhai.org / piurajahmundry@gmail.com



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
प्रदेशीय कार्यालय, विजयवाड़ा
राजमहेंद्रवरम

No: 11015/5/NHAI/PIU-RJY/WS/2024/31310

Date: 02.08.2024

To
The Regional Officer,
National Highways Authority of India,
Vijayawada-520 013



Sub: NHAI, PIU, Rajamahendravaram - Siddhantham to Gudugolanu section
from Km.950.542 to Km.1022.494 (length 71.952 Km) of NH-216A -
**Providing of HDPE water supply distribution pipelines of Tanuku
Municipality - Permission to lay pipeline through HDD across the
NH-216A at Km. 968+130 for a length of 40 mts - Proposal
submitted - Approval - Requested - Reg.**

- Ref: 1. Dy. Collector & Commissioner, Tanuku Municipality, Tanuku letter no.
NWPL/5/ 2021-SA-E1, dated 13.06.2024.
2. This office letter no. 11515/5/NHAI/PIU-RJY/TOT/IE/PP/2024-31145,
dated 26.06.2024
3. IE, M/s. MSV International INC in Association with M/s. Sri Infotech
letter no. MSV-SIT/116/RJY-TOT/2024/NHAI/340, dated 08.07.2024
4. Concessionaire, Siddhantham Tollways Pvt Ltd letter no.
SGTPL/NHAI/2024 25/1784, dated 16.07.2024

Sir,

1. It is to submit that Dy. Collector & Commissioner, Tanuku Municipality,
Tanuku vide reference 1st cited submitted a proposal seeking
permission for Providing HDPE water supply distribution pipelines
across the NH-216A for a length of 40 mts at Km. 968+130 by HDD
method for approval of Competent Authority.
2. As per the Revised Circular Guidelines, the Agency has submitted an
undertaking duly stating that they will submit Performance Bank
Guarantee as demanded by NHAI.
3. The above proposals has been forwarded to the Independent Engineer,
M/s. MSV International INC in Association with M/s. Sri Infotech and
ToT Concessionaire, M/s. Siddhantham Tollways Pvt Ltd vide reference
2nd cited requesting for verification as per MORT&H guidelines dated
26.11.2016 and to furnish their recommendations and consent.
4. The IE, M/s. MSV International INC in Association with M/s. Sri Infotech
vide reference 3rd cited submitted the report and recommendations for
grant of NOC duly submitting the Inspection Report in the requisite
format, as regards to the satisfaction of MORTH requirements.
5. The Concessionaire, M/s. Siddhantham Tollways Pvt Ltd., has given
consent for this proposals vide reference 4th cited for the subject
proposal.


Handwritten signature

Building a Nation, Not Just Roads

6. The Dy. Collector & Commissioner, Tanuku Municipality, Tanuku has submitted the Methodology for laying water supply pipeline crossing the project Highway at Km. 968+130 by HDD method. It is proposed to lay the cable along the road below the ground level and also across the water bodies / bridge portions wherever applicable by HDD method.
7. The proposal has been verified by the Manager (Tech) as per the MORT&H revised Circular / Guidelines amended dated 24.04.2023 and found in order. The Certificate / check list in the prescribed format as per the MORTH Guidelines Dt. 22.11.2016 is enclosed herewith.
6. The License Fee for a period of 5 years (60 month) is worked out as Rs. 56,731/- as per MORT&H circular dated 24.04.2023. The applicant has furnished undertaking to submit the Performance Bank Guarantee @ Rs. 250 per rm, as required vide Para-6 of MORT&H circular dated 22.11.2016. The Specification Report along with Calculation Sheet is enclosed herewith.
7. The proposal submitted by the Agency is herewith submitted along with the following:

(1) Proposal along with enclosures	(2) Check List
(3) License Deed.	(4) Undertakings
(5) Methodology	(6) Diagrams
8. With the above, the proposal submitted by Dy. Collector & Commissioner, Tanuku Municipality, Tanuku vide reference 1st cited seeking permission for Providing HDPE water supply distribution pipelines across the NH-216A for a length of 40 mts at Km. 968+130 by HDD method is herewith recommended for according necessary approval. The license fee to be paid for 60 months is Rs. 56,731/- and PBG to be submitted is for Rs. 10,000/-.


Thanking you,

Yours faithfully,

(D. Surendra Nath)
Project Director

Encl: 2 files (1 Original +1 Duplicate)

CERTIFICATE

1. Undersigned has examined the proposal of the applicant for Providing HDPE water supply distribution pipelines across the NH-216A for a length of 40 mts at Km. 968+130 by HDD method and confirm that all the standard conditions issued vide Ministry Circular No. RW/NH-33044/29/2015/ S&(R) Dt. 22.11.2016 has been followed.
2. It is certified that laying of HDPE water pipeline across ROW will not adversely affect the design, stability & traffic safety of the highway nor the likely future improvement such as widening of the carriageway easing of curve etc., as the pipeline is being laid by HDD method.
3. The Independent Engineer, M/s. MSV International INC in Association with M/s. Sri Infotech of the project verified at site and has recommended the proposal.
4. It will be ensured through the Independent Engineer for the project for supervision of the work of laying of utility and ensure that the defects in road portion after lying of utility are corrected.
5. The proposed permission will be entered in the Register of Records.
6. The record of previous approval, if any has been considered and copy of the same is enclosed with the proposal – Nil in present case


(Salman Ansari)
Manager (Tech)

NHAI, PIU, Rajamahendravaram

Annexure-1

Calculation of Licence Fees & Bank Guarantee Amount

Proposal for Permission to Tanuku Municipality, Tanuku for Providing of HDPE water supply distribution pipelines of Tanuku Municipality – Permission to lay pipeline through HDD across the NH-216A at Km. 968+130 for a length of 40 mts

Estimate

LICENCE FEE CHARGES

S.No	Name Of the Village	Chainage	Length Route (Metres)	Width (Metres)	Utilised NH Land Area Sq.Mts.(dx)	Prevailing Circle rate of Land in Rs/Acre(As per registration& stamps dept)	Prevailing Circle rate of Land in Rs/Sq.mts(Rate per acre (g)/4046.86)	Amount Rs (fxh)
a	b	c	d	e	f	g	h	i
1	Tanuku	968+130	40	0.3	12	169400000	41859.61461	502315
Licence Fee Total Amount								
						502315.38	1.50%	7535
								10000
								10600
								11236
								11910
								12625
								56371
	Total Licence Fee							
	Total Licence Fees payable by Dy. Collector & Commissioner, Tanuku Municipality, Tanuku for laying HDPE water supply pipeline							

Performance Bank Guarantee Amount Calculation

Amount of the performance Bank Guarantee to be submitted : Total no. of Route meter x Rs 250/- per Route meter (300mm dia/width but <=1000mm) as per MORTH circular point no. 6 of F.No RW/NH-33044/29//2015/S&R ® dt: 22-11-2016 i.e 40 m x Rs. 250 = Rs. 10,000/-

<

Performance bank guarantee required to be submitted by the Applicant is for Rs. 10,000/-


Manager (Techy)
NHAI, PIU.

Rajamahendravaram.

SGTPL/NHAI/2024-25/1784

Dated: 16-July-2024

To
The Project Director,
Project Implementation Unit,
National Highways Authority of India,
SY No.560/3, Adjacent to Toyota Showroom, NH-216A,
Diwancheruvu, **RAJAHMUNDRY-533102**, Andhra Pradesh

Sub : Projects comprising of 9 National Highway stretches (Bundle-1) on Toll Operate Transfer Mode -
Siddhantham to Gundugolanu section (from Km.950+542 to Km.1022+494) of NH-5
(New NH-16) in the state of Andhra Pradesh.

Providing of HDPE water supply distribution pipelines from Sharmista Junction to Kanaka Varsha nagar, 1st ward in Tanuku Municipality - Permission to lay pipeline through HDD across the NH-216A at Km.968+130 - Submission of Consent - Regarding.

Ref : 1) Your letter No. 111515/5/NHAI/PIU-RJY/TOT/IE/PP/2024/31145 dated 26-06-2024
2) Commissioner, Tanuku Municipality letter No. NWPL/5/2021-SA-E1 dated 13-06-2024
3) IE letter No. MSV_SIT/116/RJY-TOT/2024/NHAI/340 dated 08-07-2024

Dear Sir,


This refers to your above cited letter dated 26-06-2024, wherein recommendation of the Concessionaire was sought for laying of HDPE water supply pipeline by Tanuku Municipality across NH-216A at Km.968+130.


In response to the above communication, we hereby convey our consent for laying of HDPE pipeline by Tanuku Municipality through HDD at above proposed location subject to the provisions of Clause 11.3.1 of the Concession Agreement i.e., "Where such access or use causes any financial loss to the Concessionaire, it may require the user of the Site to pay compensation or damages as per Applicable Laws".

Further, Tanuku Municipality must execute the works as per the drawings submitted vide their letter cited under ref (2).

Thanking you and assuring of our best services at all times.

Yours faithfully,
For and on behalf of Siddhantham Tollway Private Limited


K. Balasubramanyam
Authorized Signatory


K. Hari Krishna
Authorized Signatory

INWARD			
No:	88281		
Date:	16/07/24		
Time:	5:20		
IN(T)	PS	✓	
SE-I	ACCT		
SE-II	LAO		
NHAI PIU,			
RAJAHMUNDRY			

Copy to : The Independent Engineer, M/s. MSV International, Inc., AV Apparao Road, Rajahmundry - for information please.



MSV INTERNATIONAL INC.

In Association with

SRI INFOTECH



MSV International, Inc.
(ISO 9001:2015 Certified Company)
No. 73-13-10,
Chakravarti's Aashram Avenue, 3rd Floor
AV Appareo Road
OPP: Nathanya School & Church
RAJAMAHENDRA VARAM-533103,
Andhra Pradesh.
E-Mail : msv.rajaramundry@gmail.com

Independent Engineer Services for National Highway Stretches of TOT Projects in the State of Andhra Pradesh for the sections of (i) Anakapalli to Annayaram Section of NH-16 from Km.741.255 to Km.830.525 (TOT) - Bundle-1 (Package-4) for a length of 89.270 Km (ii) Annayaram to Diwancheruvu Section of NH-16 from Km. 830.525 To Km.801.800 (TOT) - Bundle-1 (Package-3) for a length of 70.975 Km (iii) Diwancheruvu to Siddhantham Section of NH-216A from Km.950.542 to Km.950.542 (TOT) - Bundle-1 (Package-2) for a length of 49.942 Km, (iv) Siddhantham to Gundugolanu Section of NH-216A from Km.950.542 to Km. 1022.494 (TOT) - Bundle-1 (Package-1) for a length of 71.952 Km.

Ref: MSV_SIT/116/RJY-TOT/2024/NHAI/340

Dt:08.07.2024

To
The Project Director,
National Highways Authority of India,
Project Implementation Unit, Sy No. 560/3
Diwancheruvu, RAJAMAHENDRAVARAM-533 103.

INWARD	
No:	68061
Date:	15/07/24
Time:	5:10 PM
By:	PS
For:	ACCT.
	LAO
NHAI, PIU, RAJAMAHENDRAVARAM.	

Sub: IE Services for National Highways stretches under Bundle-1 of Tolling, Operation, and Maintenance & Transfer (TOT) Projects (IE Package-1) Siddhantham-Gundugolanu Section (from Km. 950+542-Km.1022.494) of NH-216A in the State of Andhra Pradesh
Comments / Recommendations for laying of HDPE Water Pipeline crossing at Km.968+130 on NH 216A - Reg.

Ref: 11515/5/NHAI/PIU-RJY/TOT/IE/PP/2024/31145. Dt. 26.06.2024.

Dear Sir,

With reference to the above cited subject and reference letter this office has received the Proposal for laying of 150MM dia HDPE water supply distribution pipeline crossing at sharmista junction in Tanuku Municipality at Km 968+130 across the Road NH 216A.

In this regard the IE has inspected the site and the proposal has been reviewed as per the MoRTH guidelines Dt. 22-11-2016 and found in order. As per Concession Agreement the existing ROW is 60M and existing service road from 967+800 to 968+200 BHS.

In view of the above we are here by recommended to grant the permission subject to the following conditions.

1. The top of the 150MM dia pipe shall be minimum 1.2M below the top of the subgrade as shown in the MoRTH circular drawing.
2. The top of the 150MM dia pipe shall be 0.3M below the drain invert level.
3. The HDD crossing pits shall be done extreme edge of the existing ROW of project highway.
4. The pits shall be filled up with the suitable soil properly and compacted to density of minimum 97%.
5. Debris / loose earth produced due to execution of pits shall be cleared at least 50M away from the ROW of the project highway.

6. The applicant shall be intimate the Authority, IE and Concessionaire prior to the works commenced.
7. The damages to the project highway and its assets by the applicant if any, the same shall be restored / reimbursed to Concessionaire or Authority.

This is for your information and necessary action please.

Thanking you and assuring you of our best services at all times.

Yours Sincerely,


For MSV International INC in association with Sri Infotech



A. SRINIVASA RAO
TEAM LEADER

Copy to 1) M/s. Safeway Concessions, Rajamahendravaram - for information (e-mail).
2) H.O, MSV-Sri Infotech, Hyderabad - for information.

SITE PHOTOGRAPHS





भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Govt. of India)

परियोजना कार्यालय - टोयोटा शोरूम के पास, राजमार्ग २१६ ए,
दियानचेरु, राजमहेंद्रवaram - ५३३ १०२, आंध्र प्रदेश.

PROJECT IMPLEMENTATION UNIT - Adjacent to Toyota Showroom,
NH-216A, Diwancheruvu, Rajamahendravaram - 533102, A.P.

दूरभाष / Phone : 0883 - 2431170 ई-मेल / e-mail: raj@nhai.org / piurajahmundry@gmail.com



No: 11515/5/NHAI/PIU-RJY/TOT/IE/PP/2024/31145

Date: 26.06.2024

To

The Team Leader
M/s. MSV International INC
in Association with M/s. Sri Infotech
RAJAMAHENDRAVARAM

Sub: **NHAI, PIU, Rajamahendravaram** – Providing of HDPE water supply distribution pipelines from Sharmista junction to Kanaka Varsha nagar, 1st ward in Tanuku Municipality – Permission to lay pipeline through HDD across the NH-216A at Km. 968+130 - **Comments / Recommendations** – Reg.


Ref: Dy. Collector & Commissioner, Tanuku Municipality, Tanuku letter no. NWPL/5/2021-SA-E1, dated 13.06.2024

Sir,

Please find enclosed herewith a copy of the proposal received from Dy. Collector & Commissioner, Tanuku Municipality, Tanuku, seeking to lay pipeline through HDD across the NH-216A at Km. 968+130 for Providing of HDPE water supply distribution pipelines from Sharmista junction to Kanaka Varsha nagar, 1st ward in Tanuku Municipality.

In this regard, it is requested to inspect the site and examine the proposal as per the revised guidelines of MORT&H Dt. 22.11.2016 and furnish the Inspection Report on the feasibility of the proposal at site including the availability of ROW as per the records available along with specific recommendations on the proposal, for taking further action

Encl: Copy of Proposal.

Yours faithfully,

(D. Surendra Nath)
Project Director

Copy to M/s. Siddhantham Tollways Pvt Ltd – with a request to convey your consent for issue of NOC.

MUNICIPAL ADMINISTRATION DEPARTMENT

From
Sri.B.V.Ramana.,M.A., B.L.,
Dy.Collector & Commissioner,
Tanuku Municipality,
Tanuku.

To
The DGM (T) & Project director,
National Highway Authority of India,
Project implementation Unit,
Rajamahendravaram.

Roc.No.NWPL/5/2021-SA-E1,Dt.13.06.2024.

Sir,

Sub: Tanuku Municipality – NHAI – Providing HDPE Water Supply distribution Pipe lines from sharmista junction to kanaka varsha nagar, 1st ward in Tanuku Municipality – Requesting Permission to lay the pipe line through the horizontal drilling method (HDD) –Observations Attended – Resubmitted- Reg.

- Ref: 1) Letter Roc.No.NWPL/5/2021-SA-E1,Dt.17.08.2023,O/o Commissioner Tanuku Municipality
2) Physical inspection of NHAI authorities on Dt: 20/12/2023
3) Letter Roc. No NWPL/5/2021-SA-E1 Dt 27.03.2024 of this office
4) Letter Roc No 11015/5/P-4/NHAI/PIU-RJY/2023/30834 of the Project Director, NHAI, RJY

I invite kind attention to the rectified, wherein vide reference 4th cited it has been requested to submit the modified proposals. Therefore submitting herewith the modified proposals as detailed below:

1. Undertakings furnished as per MORTH&H Circular dated 22.11.2016
2. Drawings showing the details of NH crossing along with methodology- furnished
3. Check list is as per MORTH&H Circular- furnished
4. NH16 is corrected as NH216A in all the documents of proposal

In view of the above , it is requested to accord necessary permission for the formation of pipe line while crossing at NH-216A at sharmista junction, for using the drinking water supply in Tanuku Municipality in the interest of Public.

INWARD	
No:	87442
Date:	14/06/24
By:	[Signature]
PS	✓
ACCT.	
LAO	
NHAI, PIU,	
Copy to BHIMAVARAM	

Thanking you sir,

20.

Yours Faithfully,

[Signature]
Commissioner,
Tanuku Municipality

Copy to BHIMAVARAM
The District Collector, West Godavri
at Bhimavaram for favour of information.

GOVERNMENT OF ANDHRA PRADESH
Municipal Administration Department
Tanuku Municipality

From:

Sri B V Ramana, M.A., B.L.,
Dy. Collector &
Commissioner,
Tanuku Municipality,
Tanuku.

Dated: 19.04.2024

To Whom So Ever It may Concern

Subject: Authorization for signing and execution of documents related to Permissions/Clearances from authorities for Water supply pipeline of 150mm HDPE Distribution Pipe line main Crossing at Chainage 968+130 KM (RHS to LHS) (ROAD CROSS ONLY) , in the limits of ROW boundary of NH-216A in Tanuku Municipality, Tanuku, West Godavari District, Andhra Pradesh.

I do hereby authorize Sri. B V Ramana , Dy.Collector & Commissioner,Tanuku Municipality,Tanuku to sign and execute all the documents related to Permissions/Clearances from authorities for Water supply pipeline of 150mm HDPE Distribution Pipe line main Crossing at Chainage 968+130 KM (RHS to LHS) (ROAD CROSS ONLY) , in the limits of ROW boundary of NH-216A at Tanuku Municipality, Tanuku, West Godavari District, Andhra Pradesh.

Yours Faithfully,


Commissioner

Tanuku Municipality

D-8
19/4/24
AC

19/4/24
Dy. Collector

Check List

Guidelines for Project Directors for processing the proposal for laying water pipe line in the land across National Highway Vested with NHAI

Relevant Circulars:



- 1 Ministry Circular No.NH-41(58)/68 Dated 31.01.1969
2. Ministry Circular No.HN-III/P/66/76 Dated 18/19-11-1976
3. Ministry Circular No.RW/NJ-III/P/66/76 Dated 01.05.1982
4. Ministry Circular No. RW\NH-11037/1/86-DOI(ii) Dated 28-07-1993
5. Ministry Circular No.RW/NH/11067/1/86DOI Dated 19.04.1995
6. Ministry Circular No.RW/NH/34066/2/95/S&S Dated 25.10.1999
7. Ministry Circular No.RW/NH-34066/7/2003S&R Dated 17.09.2003
8. Ministry Circular No.RW/NH-33044/29/2015S&R DT 22 November 2016

Sl No	Items	Information/Status	Remarks
1	General Information	Providing Water supply pipe line 150mm HDPE Distribution Pipe line main crossing at chainage 968+130Km (RHS to LHS) (Road Cross Only) at NH-216A NH Junction at Tanuku Town, West Godavari District in the state of Andhra Pradesh.	
1.1	Name And Address of the Application	Commssioner, Tanuku Municipality, Tanuku	
2	National Highway Number	NH-216A	
1.3	State	Andhra Pradesh	
1.4	Location	NH-216A at Sharmistha Junction, Tanuku Municipality, Tanuku	
1.5	Chainage in KM	chainage 968+130Km (RHS to LHS) (Road Cross Only)	40m
1.6	Length in Metre	40m.	
1.7	Width of Available Road of NHAI Land		
	(a) Left side from centre line (Towards increasing/Chainage/KM/ Direction)		
	(b) Right side from centre line (Towards increasing/Chainage/KM/ Direction)		
1.8	Proposal to Lay Underground water pipe line		
	(a) Left side from centre line (Towards increasing /Chainage/KM/ Direction)	chainage 968+130Km (RHS to LHS) (Road Cross Only)	
	(b) Right side from centre line (Towards increasing /Chainage/KM/ Direction)	chainage 968+130Km (RHS to LHS) (Road Cross Only)	
1.9	Prooosal to Acauire land		
	(a) Left side from centre line	NA	
	(b) Right side from centre line	NA	



Project Director
NHA-PIU
 RAJAMAHENDRAVARA
 19/11/24


COMMISSIONER
TANUKU MUNICIPALITY

1.10	Whether proposal is in the same side where land is not to be acquired	NA	
	If not then where to lay the water pipe line	NA	
1.11	Details of Already Laid services.If any along the proposal Route	NA	
1.12	Numbers of Lanes (2/4or6/8)/ Existing	4 Lanes	
1.13	Proposed Number of lanes (2 lanes with paved shoulders)	NA	
1.14	Service Road (Existing or Not) Y/N if then which side	Yes	
	(a) Left side from centre line (Width)		
	(b) Right side from centre line (Width)		
1.15	Proposed service road	No	
	(a) Left side from centre line (Width)	-	
	(b) Right side from centre line (Width)	-	
1.16	Whether proposal to lay water supply pipe line is after the service road or between the service and main carrageway	Water Pipe line will belaid ^{along} along RoW boundary under the supervision of NH authorities	
1.17	The permission for laying of water supply pipe line shall be considered for approval/ rejection based on the Ministry circulars mentioned as above		
	(a) Carrying of sewage/gaspipe lines on highway bridges shall not be permitted as furnaes/ gases pipe can accelerate the proces of corrosion or may cause explosions. Thus being muchmore injurious than leakae of water	NA	
	(b) Carrying of water pipe lines on bridges shall also be discourage (d) However.If the water supply authorities seem to have no other aviable alternative and apporach the highway authority well in the before the design of the bridge is finalize permitted to carry the pipe line on independent superstructure, supported on extended portions ofpiers and abutments In such amanner that In the final arrangements enough free spade around the superstructure of the bridge remains available for inspection and repairs. etc.,	NA	
	C) Cost of required extension of the substructure as well as that of the supporting superstructure shall be borne by the agency in charge of the utilities.	NA	




Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM


Project Director
NHAI-PIU
RAJAMAHENDRAVARAM



COMMISSIONER
TANUKU MUNICIPALITY

Date 19/4/2019
 By EEDM

	Services are not being allowed Indiscriminately of the parapet/ anypart of the bridges ,safety of bridges has to be kept in veiw while permitting various services along bridgr(e) Approvals are to be accorded in this regard with the concurrence of the Ministry's project \chief \engineers only. .	NA	
1.18	If crossing of the road involved If yes, it shall be either encased in pipes or through structure or conduits specially built for that purpose at the expenses of the agency owning the line	Yes Agreed	
	(a)Existing drainage structures shall not be allowed to carrv the lines.	Yes Agreed	
	(b) Is It on a line normal to NH	Yes	
	(c) Crossings shall not be too near the existing strucluress on the national Highway.The minium distance being 15 meter, whatis the distance from theexisting structures,	Yes Agreed	
	(d) The case pipe (or conduit pipe in the case of electric cable) carrying the utility line shall be of steel,cast iron, or reinforced cement concrete and have adequate strength and be large enough to permitready withdrawal of the carrier pipe/cable.	150mm HDPE Distribution Pipe	
	(e)Ends of the casing /conduit pipe in shall be sealed from the outside.so that it does not act asa drainage Par(H)	Yes Agreed	
	(F)Thecasing/ conduit pipe shall be sealed from drain to In cuts and toe ofslope in the fills.	Yes Agreed	
	(g) The top of the casing /conduit pipe shouldbe at least 1.2meter below the surface of the road subject to being at least 0.3m below the drain invert.	Yes Agreed	
	(h)Crossing shall be by boring method (HDD) Specially where the existing road pavements is of cement concrete or dense bituminous concrete type.	Yes Agreed	
	(i)The casing/conduit pipe sahll be installed with an even bearing though out its length and in such a manner as to prevent the formation of a water way along it.	Yes Agreed	
	Document\\Drawing\enclosed with the proposal.	Yes document enclosed	


Manager (Tech)
NHA-PIU
RAJAMAHENDRAVARAM


Project Director
NHA-PIU
RAJAMAHENDRAVARAM


COMMISSIONER
TANUKU MUNICIPALITY

Date: 19/12/24
 AE 19/12/24

2.1	Crossing section showing the size of the trench for open trenching method(it is normal size of 1.2deep x 0.3m wide).	Yes Cross section marked on the proposed laying plan	
	(i) should not be greater than 60 cm wider than the outer diameter of the pipe.	Yes Agreed	
	(ii) Located as close to the extreme edge of the right of way as possible but not less than 15 meter from the centre lines of the nearest carriage way.	Yes Agreed	
	(iv) These should be also laid that their top is at least 0.6 meter below the ground level so as not to obstruct drainage of the road land.	Yes Agreed	
2.2	Cross section showing the size of pit and location of pipe line for HDD method.	Yes	
2.3	Strip plan/Route plan showing water pipe fine. Chainage, which of ROW, distance of proposed cable from the edge of ROW important mile stone Intersection., cross drainage works etc..	Yes , Proposed laying plan enclosed	
2.4	Methodology for laying of water pipeline.		
2.4.1	Open trenching method (may be allowed in the utility corridor only where pavements is neither cement concrete nor dense bituminous concrete type if yes, methodology or refilling of trench.	Yes Agreed	
	(a) The trench width should be at least 30 cm but not more than 60cm wider than the outer diameter of the pipe	Yes Agreed	
	(b) For filling of the trench, bedding shall be to a depth of not less than 30cm. It shall consist of granular material, free of lumps clods and cobbles and graded to yield a firm surface without sudden change in the bearing value (e) Unsuitable soil and rock edges should be excavated and replaced by selected material.	Yes Agreed.	
	(c) The back fill shall be completed in two stages.		
	(i) Side fill the level of the top of the pipe and	Yes Agreed	
	(ii) Over fill to the bottom of the road crust.	Yes Agreed	

Schmay
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM

Weth
Project Director
NHAI-PIU
RAJAMAHENDRAVARAM

Duf
AE 19/4/24
12/4/24

COMMISSIONER
TANUKU MUNICIPALITY

	(d) The side fill shall consist of granular material laid in 15 cm layers each consolidated by mechanical tampering and controlled addition of moisture of 90% of the proctor's density as the materials that had been removed, consolidation by saturation or pending will not be permitted.	Yes Agreed	
	(e) The road crust shall be built to the same strength as the existing crust on either side of the road (h) care shall be taken to avoid the formation of dip at the trench.	Yes Agreed	
	(f) The excavation shall be protected by flagman, signs and barricaded and red lights during the night hours.	Yes Agreed	
	(g) If required, a diversion shall be constructed at the expense of the agency owning the utility line.	Yes Agreed	
2.4.2	Horizontal Directional drilling (HDD) Method	Yes Agreed	
2.4.3	Laying of water supply pipe line through CD work and method laying.	NA	
	(a) Open approaches the water mains/cable shall be carried along a line as close to the edge of the right of the way as possible up to distance of 30 m from the bridge and subject to all other stipulation contained in the ministry's guidelines issued with letter NH - HI/66 dated 19.11.1976.	NA	
3	Draft License agreement signed by two witnesses.	Yes	
	Performance bank guarantee in favour of NHAI has to be obtained @ Rs. 50/- per running meter (parallel to NH) and RS. 1,00,000 per crossing of NH for a period of one year initially (extendable if required till satisfactory completion of work) as a security for ensuring / making good the excavated trench for laying the cables/ducts by proper filling and compaction cleaning debris/ loose earth produced due to executing of trenching at least 50m away from the edge of the right of way no payment shall be payable by the NHAI to the licensee for clearing debris/loose earth.	Yes	
4.1	Performance BG as per above is to be obtained	Yes Agreed	

[Signature]
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM

[Signature]
Project Director
NHAI-PIU
RAJAMAHENDRAVARAM

[Signature]
DATE
19/11/2017

[Signature]
DATE
19/11/2017

[Signature]
COMMISSIONER
TANUKU MUNICIPALITY

4.2	Confirmation of BG has been obtained as per NHAI guidelines	Yes Agreed	
5	Affidative/ undertaking from the application for.	Yes Agreed	
5.1	Not to damage to other utility.if damaged then to pay the losses eighte NHAI or to the concertned agency.	Yes Agreed	
5.2	Renewal of bank guarantee.	Yes Agreed	
5.3	Confiming all standard condition of NHAI guidelines	Yes Agreed	
5.4	Shifting to water pipe lines as and when required by NHAI at their owncost.	Yes Agreed	
5.5	Shifting due to lanning/ widening of NH	Yes Agreed	
5.6	Indemnity against all damages and claims clause(xxiv)	Yes Agreed	
5.7	Traffic movement during laying of water pipe lineto be managed bt the applicant.	Yes Agreed	
5.8	If any claim is raised by the concessinaire then the same has to be paid by the applicant.	Yes Agreed	
5.9	Prior approved of the NHAI shall be obtained before undertaking any work of the installation, shifting or repairs of alteranation to the showing water pipe line located in theNational Highway right of ways.	Yes Agreed	
5.10	Expenditure.if any incurred by NHAI for repairing any damage cause to the Nataional Highway by the laying, maintenance or shifting of the water pipe line will be borne by the agency owning the line.	Yes Agreed	
5.11	If the NHAI consider it necessary in futurre to move the utility line for any work of improvement or reparisof the road .It willbe carried out as desired by the NHAI or the cost of the agency owning the utility line with in a reasonable time (not exceeding 60days) of the intimation given.	Yes Agreed	
5.12	Certificate from the application In thefollowing format:		
	(i)laying of water Pipe line will not have any deleterious effects on anyof the bridge components and road way safety for traffic	Yes	

Satish
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM

Heeth
Project Director
NHAI-PIU
RAJAMAHENDRAVARAM

Dag
AE 19/4/24

By
DMEE

[Signature]
COMMISSIONER
TANUKU MUNICIPALITY

	{ii)for lanning"we do undertake that l will relocates service road/ approachroad/ utilities at my own cost not with standing the permission granted within suchtime aswell be stipulated by NHAI forfuture six-lanning or any other development.	Yes	
6	Who will sign the agreement on behalf or water pipeline agency.	Commissioner, Tanuku Municipality	
7	Certification of the project director		
7.1	Certificate for confirming of all standard condition Issued vide ministry circular NO. NH41(58)/68 Dated.31.01.1969 Ministry circular no .NHIII /P66/76 Dated18/19/1976 Dated.11.05.1982 Ministry circular No.RW/NH-11037/1/86-DOI(II) DATED 2/1/1993 Ministry circularno.RW/NH-11037/1/86-DOI Dated.19-1-1995. Ministry circular No. RW/ NH31066/ 2/ 95/ S &R Dated25/10/1999 ANDMinistry circularno. RW/ NH/ 34066/ 7/2003S&R (B)Dated.17-09-2003.	Yes	
7.2	Certificate from PD in the following format(i) it is certified that anyother location of the water pipe line would be extremely difficult and unreasonable costly and the installation of water pipe line with in ROW will not adversely affect the desgin. stability and traffic safety of the highway nor the likely future imporvement such as widening of the carrigeway casing of curves etc.,	Yes	
	(ii) for 6 Lanning		
	(a) Where is feasibility avallabe "I do certify that there wlll be no hindrance ot h proposed six Lanning based on the feasibility report considering proposed structured at the side location"	Yes	
	(B) In case feasibility Report is not available "I do certify that suffcient ROW is available at site for accommodating proposed six lanning"	Yes	


Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM


Project Director
NHAI-PIU
RAJAMAHENDRAVARAM


COMMISSIONER
TANUKU MUNICIPALITY


AE


Dy. EE


19/4/24

8	If NH section proposed to be taken up by NHAI on BOT basis-a clause is to be inserted in the agreement 'the permitted highway on which Licensee has been granted the right to lay water pipe line cable duct has also been granted as right to way to the concessionaire under the concession agreement for up gradation of section km to km	Yes	
9	Who will supervise the work of laying of water pipe line	Applicant IE/PD	
10	Who will ensure, that the defects in road portion after laying of water pipe line are corrected and if not corrected then what action will be taken.	Applicant IE/PD	
11	Who will pay the claims for damaged one/diminished in working of concessionaire if asked by the concessionaire.	Applicant	
12	A certificate from PD that he will enter the proposed permission in the register records of the permission in the prescribed proforma (copy enclosed)	Yes	
13	If any previous approval is accorded for of underground water pipe line then photocopy of register of records of permission accorded as maintained by PD then copy enclosed.	NA	

Commissioner
Tanuku Municipality

Name/Designation/
Signature of the concerned

Day
15/4
AE

Day
12/EE

Salman
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM

Wadhwa
Project Director
NHAI-PIU
RAJAMAHENDRAVARAM



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP74014279506759W

e-Stamp

Certificate No. : IN-AP74014279506759W
Certificate Issued Date : 22-Mar-2024 05:59 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/appanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180437240560240124W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 100
(One Hundred only)



Please write or type below this line

AGREEMENT REGARDING GRANTING OF RIGHT OF WAY PERMISSIONS
FOR LAYING UTILITY SERVICES ON NATIONAL HIGHWAYS

Agreement for Water supply pipeline of 150mm HDPE Distribution Pipr linr main Crossing at Chainage 968+130 KM (RHS to LHS) (ROAD CROSS ONLY) and laying at Chainage at NH-216A Junction at Tanuku Town, West Godavari District in the state of Andhra Pradesh

This agreement made this _____ day of _____ 2024 between The Regional officer, Reginal office, Vijayawada acting in his Executive capacity through the President of India/National Highways Authority of India (Herein after referred to as the "Authority" which expression shall unless exclude by or repugnant to the context, include his successors in office and assigns) on the one part, and Commissioner, Tanuku Municipality, Tanuku, West Godavari District (hereinafter called the "Licensee") which expression shall unless excluded by repugnant to the context, include his successors/administrator assignees.
On the second part.

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.

Do
AE 19-4
12 FEB 24

12 FEB 24

0002272002
COMMISSIONER
TANUKU MUNICIPALITY

Whereas the PD, NHALPIU- Rajamahendravaram is responsible, inter-alia, for development and maintenance of landat Crossing at chainage 968+130 Km (ROAD CROSS ONLY) (RHS to LHS) at NH-216A RoW.

Whereas the Licensee proposes 150mm HDPE Distribution Pipe line maincrossing at chainage 968+130 Km (ROAD CROSS ONLY) water supply pipeline referred to as utility services in subsequent paras.

Whereas the Licensee has applied to the Authority for permission for utility services water supply pipeline of 150mm HDPE Distribution Pipe line mainat chainage 968+130 Km (ROAD CROSS ONLY) (RHS to LHS)atNH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh.

And Whereas the Authority has agreed to grant such permissions for way leave on the NH RoW as per terms and conditions herein after mentioned.

Now this agreement witness that in consideration of the conditions hereinafter contained and on the part of the Licensee to be observed and performed, the Authority hereby grants to the Licensee permission to lay utility services as per the approved drawing attached hereto subject to the following conditions namely.

1. RoW permissions are only enabling in nature. The purpose of extending the way leave facility, on the National Highway RoW is not for enhancing the scope of activity of a utility service provider, either by content or by intent. Further, enforceability permission so granted shall be restricted. Only to the extent of provisions/scope of activities defined in the license agreement & for the purpose, for which it is granted.
2. No Licensee shall claim exclusive right on the RoW and any subsequent user will be permitted to use the RoW, either above or below, or by the side of the utilities laid by the first user, subject to technical requirements being fulfilled. Decision of the Authority in relation to fulfillment of technical requirements shall be final and binding on all concerned parties. In case any disruption/damage is caused to any existing user by the subsequent user, the Authority shall not be held accountable or liable in any manner.
3. The Licensee shall be responsible for undertaking all activities including, but not limited to site Identification, survey, design, engineering, arranging finance, project management, obtaining, regulatory approvals & necessary clearances, supply of equipment, material, construction, erection, testing and commissioning, maintenance, and operation all other activities essential or required for efficient functioning of their own utility/ industrial infrastructure facilities.
4. The Licensee shall pay license fees @ _____/Sq.m/month to the Authority. The License fee shall become payable from the date of handing over of RoW land to the Licensee, for laying of

utilities/cables/conduits/pipelines for infrastructures/ service provider. As regards Tariff and terms and conditions for providing common utility ducts along National Highways, there shall be a separate agreement regime.

5. Fee shall have to be paid in advance for the period for which permission is granted for entering into a license agreement. In case of renewal, rate prevailing at the time of renewal shall be charged. Delay in deposition of fee shall attract interest @, 15% per annum compounded annually.
6. Present policy of the MoRT&H is to provide a 2.00 m wide utility corridor on either side of the extreme edge of RoW. In cases where utility ducts with sufficient space are already available along NH, the utility services shall be laid in such ducts subject to technical requirements being fulfilled.
7. The utility services shall be laid at the edge of the RoW, in case of restricted width of RoW, which may be adequate only to accommodate the carriageway, central verge, shoulders, slopes of embankment, drains, other roadside furniture etc., the utility services shall be laid beyond the toe line of the embankments and clear of the drain.
8. The Licensee shall make his own arrangement for crossing of cross drainage structure, rivers, etc., below the bed. In case, this is not feasible, the utility services may be carried outside the railings/parapets and the bridge superstructure. The fixing and supporting arrangement with all details shall be required to be approved in advance from the concerned Highway administration. Additional cost on account of fixing and supporting arrangement as assessed by the Authority shall be payable by the Licensee.
9. In exceptional cases, where RoW is restricted the utility services can be allowed beneath the carriageway of service road. If available, subject to the condition that the utility services be laid in concrete ducts, which will be designed to carry traffic on top. The width of the duct shall not be less than one lane. In such cases, it also needs to ensure that maintenance of the utility services shall not interfere with the safe and smooth flow of traffic. The cost of operation and maintenance will have to be borne by the Licensee.
10. It is to be ensured that at no time there is interference with the drainage of the road land and maintenance of the National Highways. Towards this, the top of the utility services shall be at least 0.6 meter below the ground level. However, any structure above ground shall be aesthetically provided for/landscaped with required safety measures as directed by the concerned authority.
11. The utility services shall be permitted to cross the National Highway either through structure or conduits specially built for that purpose. The casing /conduit pipe should, as minimum, extend from drain to drain in cuts and toe of slope in the fills and shall be designed in accordance with provision of IRC and executed following the specifications of the Ministry.
12. Existing drainage structures shall not be allowed to carry the lines across.

- 13.** The top of the casing/conduit pipe containing the utility services to cross the road shall be at least 1.2m below the top of the sub grade or the existing ground level whichever is lower, subject to being at least 0.3m below the drain inverts. A typical sketch showing the clearances is given in Attachment - I.
- 14.** The utility services shall cross the National Highway preferable on a line normal to its or as nearly so as practicable.
- 15.** The casing/conduit pipe for crossing the road may be installed under the road embankment either by boring or digging a trench. Installation by boring method shall be preferred.
- 16.** In case of trenching, the sides of the trench should be done as nearly vertical as possible. The trench width should be at least 30cm but not more than 60cm wider than the outer diameter of the pipe. Filling of the trench shall conform to the specifications contained here-in-below or as supplied by the Highway Authority.
- a) Bedding shall be to a depth not less than 30cm. It shall consist of granular material, free of lumps, clods, and cobbles, and graded to yield a firm surface without sudden change in the bearing value. Unsuitable soil and rock edges should be excavated and replaced by selected material.
- b) The backfill shall be completed in two stages
- (i) side-fill to the level of the top of the pipe (ii) Overfill to the bottom of the road crust.
- c) The side fill shall consist of granular material laid in 15cm. Layers each consolidated by mechanical tamping and controlled addition of moisture to 95% of the proctor's density. Overall, shall be compared to the same density as the material that had been removed. Consolidation by saturation or ponding will not be permitted.
- d) The road crust shall be built to the same strength as the existing crust on either side of the trench or to thickness and specifications stipulated by the Highway Authority.
- 17.** The Licensee shall ensure making good the excavated trench for laying utility services by proper filling and compaction, so as to restore the land into the same condition as it was before digging the trench, clearing debris/loose earth produced due to execution of trenching at least 50m away from the edge of the right of way.
- 18.** All required restoration work subsequent to laying of the cable shall be required to be undertaken by the Licensee at its cost either by itself or through its authorized representative in consultation with the Authority as per predetermined time schedule and quality standards.
- 19.** Prior to commencement of any work on the ground, a performance Bank Guarantee @Rs.250 Per route meter/Rs250/- per sq m with a validity of one year initially (extendable if required till satisfactory completion of work) shall have to be furnished by the Licensee to the Authority/its designated agency as a security against improper restoration of ground in terms of filling/unsatisfactory compaction damages caused to other underground installations/utility services & interference, interruption, disruption, or failure caused thereof to any services etc. In case of the Licensee failing to discharge the obligation of

making good of the excavated trench/other restoration work, the Authority shall have a right to make good the damages caused by excavation, at the cost of the Licensee and recover the amount by forfeiture of the bank guarantee.

20. In case, the performance Bank Guarantee is invoked as mentioned above, the licensee shall be required to replenish and reinstate the required performance Bank Guarantee within one month of such invoking. In case the work contemplated herein is not completed to the satisfaction of the Authority, which has granted the permission, within a period of 11 months from the date of issue of Bank Guarantee, the Licensee shall either furnish a fresh guarantee or extend the guarantee for a further period of one year. Notwithstanding this, the Licensee shall be liable to pay full compensation to the aggrieved authority/ its designated agency for any damage sustained by them by reason of the exercise of the RoW facility.

21. The Licensee shall shift the utility services within 90 days (or as specified by the respective authority) from the date of issue of the notice by the concerned authority to shift/relocate the utility services, in case it is so required for the purpose of improvement /widening of the road/route/highway or construction of flyover/bridge and restore the road/land to its original condition at his own cost and risk.

22. The Licensee shall be responsible to ascertain from the respective agency in coordination with Authority. Regarding the location of other utilities/underground installations/facilities etc. The Licensee shall ensure the safety and security of already existing underground installations/utilities/facilities etc. before commencement of the excavation/using the existing cable ducts. The Licensee shall procure insurance from a reputed insurance company against damages to already existing underground installations/utilities/facilities etc.

23. The Licensee shall be solely responsible/liable for full compensation/indemnification of concerned agency/aggrieved authority for any direct, indirect, or consequential damage caused to them/claims or replacements sought for, at the cost and risk of the Licensee. The concerned agency in coordination with Authority shall also have a right make good such damages/recover the claims by forfeiture of Bank Guarantee.

24. If the Licensee fails to comply with any condition to the satisfaction of the Authority, the same shall be executed by the authority at the cost and risk of the Licensee.

25. Grant of License is subject to its Licensee satisfying (a) minimum disruption of traffic and (b) no damage to the highways. As far as possible, the licensee should avoid cutting of the road for crossing highway, and other roads and try to carry out the work by trenchless technology. In case any damage is caused to the road pavement in this process, the licensee will be required to restore the road to the original road condition at its cost. If due to unavoidable reasons the road needs to be cut for crossing or laying utility services, the licensee has to execute the restoration work in a time bound manner at its cost either by itself or through its authorized representative in consultation with the Authority as per

predetermined time schedule and quality standards. In case of the Licensee failing to discharge the obligation of making good of the excavated trench / other restoration work, the Authorized signatory have a right to make good the damages caused by excavation, at the cost of the Licensee and recover the amount by forfeiture of the Bank Guarantee.

26. The licensee shall inform/give a notice to the concerned agency designated by the Authority at least 15 days in advance with route details prior to digging trenches, for fresh or maintenance/repair works. A separate performance bank guarantee for maintenance/repair works shall have to be furnished by the licensee.

27. Each day, the extent of digging the trenches should be strictly regulated so that utility services is laid and trenches filled up before the close of the work that day. Filling should be completed to the satisfaction of the concerned agency designated by the Authority.

28. The licensee shall indemnify the concerned agency in coordination with Authority, against all damages and claims, If any due to the digging of trenches for laying cables/ducts.

29. The permission for laying utility services is granted maximum for 5 years at a time, which can thereafter be considered for renewal. On payment of additional fee at the time of renewal, the permission shall automatically be renewed, unless defaults exist. In case of renewal, rate prevailing at the time of renewal shall be charged. Delay in deposition of fee shall attract interest @ 15% per annum compounded annually.

30. The permission shall be valid only for the period it is issued, and fee deposited. However, the Authority also has a right to terminate the permission or to extend the period of agreement.

31. The Licensee shall not undertake any work of shifting, repairs or alterations to the utility services without prior written permission of the concerned agency in coordination with the Authority.

32. The permission granted shall not in any way be deemed to convey to the Licensee any ownership right or any interest in route/road/highway land/property, other than what is herein expressly granted. No use of NH RoW will be permitted for any purpose other than that specified in the agreement.

33. During the subsistence of this agreement, the utility services located in highway land/ property shall be deemed to have been constructed and continued only by the consent and permission of the Authority so that the right of the licensee to the use thereof shall not become absolute and indefeasible by lapse of time.

34. The Licensee shall bear the stamp duty charged on this agreement.

35. Three copies of as laid drawings' of utilities (hard & soft copies) with geo-tagged photographs and geo-tagged video recordings of laying of cables in the trench (with respect to the NH) and after complete restoration shall be submitted to the Authority for verification and record within a month of completion of works.

36. The Licensee shall allow free access to the site at all times to the authorized representatives of Authority to inspect the project facilities and to investigate any matter within their authority, and upon reasonable notice. Shall provide reasonable assistance necessary to carry out their respective duties and functions.

37. The utility services shall not be made operational by the licensee unless a completion certificate to the effect that the utility services has been laid in accordance with the approved specifications and drawings and the trenches have been filled up to the satisfaction of the concerned agency in coordination with the authority has been obtained. Notwithstanding anything contained herein, this agreement may be cancelled at any time by authority for breach of any condition of the same and the licensee shall neither be entitled to any compensation for any loss caused to it by such cancellation nor shall it be absolved from any liability already incurred.

38. The licensee shall ensure adherence to relevant Indian standards and follow best industry practices, methods, and standards for the purpose of ensuring the safe, efficient, and economic design, construction, commissioning, operation, repair, and maintenance of any part of the utility lines/industrial infrastructure facilities and which practices, methods and standards shall be adjusted as necessary, to take account of

- a. Operation, repair, and maintenance guidelines given by the manufacturers,
- b. The requirements of Law,
- c. The physical conditions at the site, and
- d. The safety of operating personnel and human beings.

39. The licensee shall have to provide safety measures like barricading, danger lighting and other necessary caution boards while executing the work.

40. While laying utility services, at least one lane of road shall be kept open to traffic at all times, in case of single lane roads, a diversion shall be constructed. If any traffic diversion works are found necessary during the working period such diversion shall be provided at the cost of licensee.

41. After the termination/expiry of the agreement, the licensee shall remove the utility services within 90 days and the site shall be brought back to the original condition failing which the licensee will lose the right to remove the utility services. However before taking up the work of removal of utility services the licensee shall furnish a Bank Guarantee to the Authority for a period of one year for an amount assessed by the Authority as a security for making good the excavated trench by proper filling and compaction. Clearing debris, loose earth produced due to excavation of trenching at least 50m away from the edge of the RoW.

42. Any disputes in interpretation of the terms and conditions of this agreement or their implementation shall be referred to the redress mechanism prevailing in the Ministry and the decision of the redress mechanism shall be final and binding on all..

43. For PPP Projects , in case of any financial loss incurred by the respective project concessionaires due to such laying/shifting of utility services by the licensee. Compensation for the same shall be required to be borne by the licensee in mutual agreement with the respective project concessionaires. MoRT&H/HAI/implementing authorities for the project shall not be liable to the concessionaire in any way in this regard.

This agreement has been made in duplicate, each on a stamp paper, each party to this agreement has retained one stamped copy each.


IN WITNESS WHEREOF THE PARTIES HERETO HAVE CAUSED THIS AGREEMENT TO BE EXECUTED THROUGH THEIR RESPECTIVE AUTHORISED REPRESENTATIVES THE DAY AND THE YEAR FIRST ABOVE WRITTEN.

SIGNED SEALED AND DELIVERED FOR AND ON BEHALF OF AUTHORITY.

BY SHRI.....


COMMISSIONER
(Signature, Name & Address with Stamp)
TANUKU MUNICIPALITY

SIGNED ON COMMISSIONER, TANUKU MUNICIPALITY


AE 19/04


11-04
DMELE

(Signature, name & address with stamp)

HOLDER OF GENERAL POWER OF ATTORNEY DATED.....

EXECUTED IN ACCORDANCE WITH THE RESOLUTION NO
DATED..... PASSED BY THE BOARD OF DIRECTORS IN THE MEETING HELD
ON.....

IN THE PRESENCE OF (WITNESSES)



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78954944209144W

e-Stamp

Certificate No. : IN-AP78954944209144W
Certificate Issued Date : 13-Apr-2024 01:01 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446974513819336W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 100
(One Hundred only)



Please write or type below this line

INDEMNITY BOND

Name of Work: Providing Water supply pipe line 150mm HDPE Distribution Pipe line main crossing at chainage 968+130Km (RHS to LHS) (Road Cross Only) at NH-216A NH Junction at Tanuku Town, West Godavari District in the state of Andhra Pradesh.

I, **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216ATanuku Town, West Godavari District in the state of Andhra Pradesh

Maintenance thereof and against all claims proceedings, damage costs, charges and expenses whatsoever in respect thereof in relation there to. Failing such payments of claims in the above work abide in accepting for recovery of such claims after from any of our assets.

Dr. S. S. S. S. S.
AG 19/4/24

Ray
DICE

COMMISSIONER
TANUKU MUNICIPALITY

IHF

0002273695

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78957214316205W

e-Stamp

Certificate No. : IN-AP78957214316205W
Certificate Issued Date : 13-Apr-2024 01:06 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446976793830031W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will not damage any other utility, if damaged then to pay the losses either to NHAI or to the concerned agency

Commissioner

Tanuku Municipality

Tanuku

Done
19/4
AE
19/4
AE

HIF 0002273709

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78957600478414W

e-Stamp

Certificate No. : IN-AP78957600478414W
Certificate Issued Date : 13-Apr-2024 01:07 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R.
Unique Doc. Reference : SUBIN-APAP1801180446976132535796W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We hereby undertake to furnish a Performance Bank Guarantee @ Rs.250/- per route meter for a period of one year initially (extendable if required until satisfactory completion of work) as security against improper ground restoration, such as filling/unsatisfactory compaction/damages caused during underground installation/utility services, and any interference, interruption, disruption or failure caused thereof to any services, etc.

Commissioner

Tanuku Municipality

HIF 0002273711

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78957692612242W

e-Stamp

Certificate No. : IN-AP78957692612242W
Certificate Issued Date : 13-Apr-2024 01:07 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446975520241535W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I. COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will confirm that we are complying with all standard condition of Ministry /NHAI guide lines

13/4
AE

11/04
12/04

Commissioner
Tanuku Municipality

0002273713

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at www.shoilestamp.com or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.




INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78957947524694W

e-Stamp

Certificate No. : IN-AP78957947524694W
Certificate Issued Date : 13-Apr-2024 01:07 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446975323954214W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I. COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will indemnify against all damages and claims.

Do
AE 194

U-By
DMEE

Commissioner

Tanuku Municipality

HIF 0002273714

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78958011651569W

e-Stamp

Certificate No. : IN-AP78958011651569W
Certificate Issued Date : 13-Apr-2024 01:08 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446975244893888W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will manage traffic moment during laying of Water supply pipe line without hampering the traffic.

AE 19/4/24

R-DY
IDYEE

Commissioner
Tanuku Municipality

HIF 0002273715

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL



Government of Andhra Pradesh

IN-AP78960133561394W

e-Stamp

Certificate No. : IN-AP78960133561394W
Certificate Issued Date : 13-Apr-2024 01:13 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446988916909052W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I. COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will address any claim is raised by the concessionaire /contractor then the same has to be paid by applicant.

Commissioner

Tanuku Municipality

DRS
19/4
AE
12/4

HIF 0002273717

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcstamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78960226176726W

e-Stamp

Certificate No. : IN-AP78960226176726W
Certificate Issued Date : 13-Apr-2024 01:14 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446987598199811W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will obtain prior approval from the NHAI before undertaking any work/installation/shifting/repairs/alterations to the water supply pipeline located in the national highways Row.

Commissioner

Tanuku Municipality

DOF
AE 19/4
AE 19/4
AE 19/4

HIF 0002273719

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shoilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78960537123877W

e-Stamp

Certificate No. : IN-AP78960537123877W
Certificate Issued Date : 13-Apr-2024 01:14 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446987117248737W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I. **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will bear the expenditure, if any, incurred by NHAI for repairing any damage caused to the national highway by laying, maintenance, or shifting of the water supply pipeline. The applicant agency owning the pipeline will be responsible for covering these costs.

Commissioner

Tanuku Municipality

Dul
AE 19/4
11/4
10/4

HIF 0002273721

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shoilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78960667579414W

e-Stamp

Certificate No. : IN-AP78960667579414W
Certificate Issued Date : 13-Apr-2024 01:15 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446986631635982W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

The text of the License deed is as per the verbatim of MORTH format issued vide Ministry's Circular No: RW/NH-33044/29/2015/S&R(R) dated 22-11-2016.

Commissioner

Tanuku Municipality

On 13/4/24
AE 194
12-04
DMICE

HIF 0002273723

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78956082266338W

e-Stamp

Certificate No. : IN-AP78956082266338W
Certificate Issued Date : 13-Apr-2024 01:03 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446977819316349W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I. COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India. PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We will obtain various safety clearances from representative authorities, such as the Directorate of Electricity, Chief Controller of Explosives, Petroleum and Explosive Safety Organization, Oil Industry Safety Directorate, State/Central Pollution Control Board, and any other statutory clearances applicable, before applying to the Highway Administration.

Commissioner

Tanuku Municipality

HIF 0002273704

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid
2. The onus of checking the legitimacy is on the users of the certificate
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL



IN-AP78956327827758W

Government of Andhra Pradesh

e-Stamp

Certificate No. : IN-AP78956327827758W
Certificate Issued Date : 13-Apr-2024 01:04 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446977269930736W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

I, **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVARI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

If the MORTH/NHAI considers it necessary in the future to move the utility line for any road improvement or repairs, it will be carried out as desired by the MORTH/NHAI at the cost of the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.

D-1
AE 19/4
R.B.
DME

Commissioner
Tanuku Municipality

HIF 0002273706

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shoilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.




INDIA NON JUDICIAL

Government of Andhra Pradesh

IN-AP78955771638628W

e-Stamp

Certificate No. : IN-AP78955771638628W
Certificate Issued Date : 13-Apr-2024 01:03 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDQ Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446978040014438W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

CERTIFICATE

I, **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

Laying of Water pipe line will not have any deleterious effect on any of the bridge components and roadway safety for traffic.

Commissioner

Tanuku Municipality

DRS
AE 19/4
R.DY
DNYKE

HIF 0002273702

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.



INDIA NON JUDICIAL



IN-AP78955520591293W

Government of Andhra Pradesh

e-Stamp

Certificate No. : IN-AP78955520591293W
Certificate Issued Date : 13-Apr-2024 01:02 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446978544964716W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

UNDERTAKING

II, COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT do hereby Indemnity Project Director, National Highway Authority of India, PIU, Rajamahendravaram binding ourselves to pay all the losses and claims in respect of Right of way permission for providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

We do undertake that I/we relocate service road/approach road/utilities at my/our own cost, notwithstanding the permission granted, within such time as will be stipulated by NHAI for future six-laning or any other development.

Commissioner

Tanuku Municipality

Dr. S. S. S. S. S.
19/4/24
AE
K. S. S. S. S.
DYEE

HIF 0002273699

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority



INDIA NON JUDICIAL



Government of Andhra Pradesh

IN-AP78955006103294W

e-Stamp

Certificate No. : IN-AP78955006103294W
Certificate Issued Date : 13-Apr-2024 01:01 PM
Account Reference : NEWIMPACC (SV)/ ap18011804/ AP-WGV/ AP-TNK/apbanmanu
DDO Code : 27002308001 O/o IG R
Unique Doc. Reference : SUBIN-APAP1801180446979246302348W
Purchased by : B VENKATA RAMANA SONOF APPALA NAIDU TANUKU
Description of Document : Article 7 Agreement
Property Description : Not Applicable
Consideration Price (Rs.) : 0
(Zero)
First Party : COMMISSIONER TANUKU MUNICIPALITY
Second Party : Not Applicable
Paid By : COMMISSIONER TANUKU MUNICIPALITY
Stamp Duty Amount(Rs.) : 20
(Twenty only)



Please write or type below this line

AFFIDAVIT

I, the **COMMISSIONER, TANUKU MUNICIPALITY, TANUKU, WEST GODAVRI DISTRICT** do hereby undertake in Reference to our RoW application, Providing water supply pipeline 150mm HDPE Distribution Pipe line main crossing at Chainage 968+130km(RHS to LHS) (ROAD CROSS ONLY) at NH-216A Tanuku Town, West Godavari District in the state of Andhra Pradesh

1. Undertaking not to damage any other utility: if any damage occurs, then the responsible party will pay for the losses either to NHAI or to the concerned agency
2. Undertaking for renewal of bank guarantee as and when asked by MORTH/NHAI.
3. Undertaking to conform to all the standard conditions of Ministry circulars and NHAI's guidelines.
4. Undertaking for indemnity against all damages and claims.
5. Undertaking for management of traffic movement during laying of water supply pipeline without hampering the traffic.
6. Undertaking that if any claim is raised by concessionaire/contractor the same to be paid by us

HIF 0002273696

COMMISSIONER
TANUKU MUNICIPALITY

Statutory Alert:

1. The authenticity of this Stamp certificate should be verified at 'www.shcilestamp.com' or using e-Stamp Mobile App of Stock Holding. Any discrepancy in the details on this Certificate and as available on the website / Mobile App renders it invalid.
2. The onus of checking the legitimacy is on the users of the certificate.
3. In case of any discrepancy please inform the Competent Authority.

7. Undertaking that prior approval of NHAI shall be obtained before undertaking any work for installation, shifting, repairs, or alteration to the water supply line located in the National Highway Right of Way.

8. Undertaking that expenditure, if any, incurred by NHAI for repairing any damages caused to the National Highway by the laying, maintenance, or shifting of the water supply pipeline will be borne by us.

9. Undertaking that the text of the license deed is verbatim as per the MoRTH format (issued vide Ministry's circular no. RW/NH - 33044/29/2015/S&R(R) dated 22.11.2016).

10. Undertaking that the applicant has obtained various safety clearances from the relevant authorities, such as the Directorate of Electricity, Chief Controller of Explosives, Petroleum and Explosive Safety Organization, Oil Industry Safety Directorate, State/Central Pollution Control Board, and any other statutory clearances as applicable before applying to the Highway Administration.

11. If MoRTH/NHAI considers it necessary in the future to move the water supply line for any road improvement or repair work, the agency responsible for moving the water supply line shall carry out the relocation as per MoRTH/NHAI's requirements and at their own cost within a reasonable time frame, not exceeding 60 days from the date of intimation.

12. (i) certify that laying the water supply pipeline will not have any deleterious effects on any of the bridge components and roadway safety for traffic.

(ii) "We undertake that we will relocate the service road/approach road/utilities at our own cost, notwithstanding the permission granted, within the timeframe stipulated by NHAI for future six-laning or any other development.

Commissioner
Tanuku Municipality

D.S.
19/4
AE 24

11-04
DMCE

Annexure-1

Calculation of Licence Fees & Bank Guarantee Amount

Proposal for Providing HDPE water supply distribution pipeline of 150mm HDPE Distribution Pipe line at , Crossing at Chainage 968+130Km (RHS to LHS) (ROAD CROSS ONLY) and laying at Chainage at NH-16 Tanuku Municipality, Tanuku, West Godavari District in the state of Andhra Pradesh.

Estimate

LICENSE FEE CHARGES

S.No	Name Of the Village	Chainage	Length Route (Metres)	Width (Metres)	Utilised NH Land Area Sq.Mts.(dx)	Prevailing Circle rate of land in Rs/Acre(As per registration & stamp dept)	Prevailing Circle rate of Land in Rs/Sq.mts(Rate per acre (g)/4046.86)	Amount Rs (fxh)	Remarks
a	b	c	d	e	f	g	h	i	j
1	Tanuku Municipality	968+130Km	40	0.3	12	169400000	41859.61461	502315.38	
Total Amount									
License Fee (Rs./Month)=									
Total Licence Fee for 5 Years									
						502315.38	/(10*12)	502315.38	
						4185.96	*12*5	4185.96	
							Rounding up to next value	251157.69	
								251158.00	
Total Licence Fees payable Public Health Division Rajamahendravaram for laying pipeline									
						251158.00	33.00%	₹ 82,882.14	
For Public Utility 33% of the fee prescribed for industrial utilities as per point no .5 of MORTH guideliness vide letter no RW/NH/33044/29/2015/s/&r® Dt.22.11.2016									

Performance Bank Guarantee Amount Calculation

Amount of the performance Bank Guarantee to be submit = Total no.of Route meter x Rs 250/- per Route meter (> 300mm dia/width but <= 1000mm) as per MORTH circular point no .6 of F.No RW/NH-33044/29/2015/S&R ® dt: 22-11-2016.	
I.e 40 m x Rs.250 = Rs.10000/-	
Performance bank guarantee = Rs. 10000/-	


(Signature)
Deputy Executive Engineer
Tanuku Municipality

(Signature)
Commissioner
Tanuku Municipality

(Signature)
19/4
AE

TANUKU MUNICIPALITY

PLAN SHOWING THE PROPOSAL OF LAYING 160MM DIA HDPE PIPE
NH-216A CROSSING AT SHARMISTA JUNCTION @ CHAINAGE 968+130KM



PLAN

[Signature]
ASSISTANT ENGINEER 19/4/2019
TANUKU MUNICIPALITY


[Signature]
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAHM

[Signature]
Project Director
NHAI-PIU
RAJAMAHENDRAVARAHM

[Signature]
DEPUTY EXECUTIVE ENGINEER
TANUKU MUNICIPALITY

TANUKU MUNICIPALITY

21.0M



CROSS SECTION

D. Sundar
ASSISTANT ENGINEER 19/4/2019
TANUKU MUNICIPALITY


Sundar
Manager (Tech)
NHAI-PIU
RAJAMAHENDRAVARAM

Sundar
Project Director
NHAI-PIU
RAJAMAHENDRAVARAM

Sundar
DEPUTY EXECUTIVE ENGINEER
TANUKU MUNICIPALITY

TANUKU MUNICIPALITY

CROSS SECTION OF TRENCHING FOR WATER PIPE LINE



P. Chandrasekhar
 ASSISTANT ENGINEER 19/4/2019
 TANUKU MUNICIPALITY

Rajamohandran
 Manager (Tech)
 NH&PIU
 RAJAMOHANDRAN

Rajamohandran
 Project Director
 NH&PIU
 RAJAMOHANDRAN

V. Suresh Kumar
 DEPUTY EXECUTIVE ENGINEER
 TANUKU MUNICIPALITY