



सत्यमेव जयते

Government of India

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4<sup>th</sup> floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010

Phone No. 079-26950705, Phone/Fax No. 079-26950705 Email: rogandhinagar@yahoo.in

RW/GNR/NH/US/GL/NOC/349/2023/793

Date: 31 October 2023

**Invitation of Public Comments**

**Subject:** Permission for accommodation and crossing of 66 KV underground electric line (from Trimandir sub-station Adalaj -Sargasan line) along NH-147 between km 18/800 to km 19/400 and across @ 18/800 in the state of Gujarat.

**Reference:** Letter No. NHP-11-2023-598-M dated 15.09.2023

The Under Secretary , Roads and Building Department, Government of Gujarat vide letter cited under reference has recommended the subject cited proposal for accommodation and crossing of 66 KV underground electric line (from Trimandir sub-station Adalaj -Sargasan line) along NH-147 between km 18/800 to km 19/400 and across @ 18/800 in the state of Gujarat for approval of Regional Officer , MoRT&H Gujarat.

2. As per Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of the above the comments of public are invited on captioned proposal and the same should reach to below mentioned address by 30 days beyond which no comments will be considered.

The Regional officer, Gandhinagar

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010

Email: rogandhinagar@yahoo.in

4. This issues with the approval Regional Officer, MoRT&H, Gandhinagar.

(Ganesh Shelar)

Executive Engineer

For Regional Officer Gandhinagar

**Copy to:**

1. The Senior Technical Director, NIC, Transport Bhawan, New Delhi-110001- for uploading on Ministry's website.
2. The Chief Engineer(NH) &AS, Roads and Building Department, Government of Gujarat.- for information.



3. The Executive Engineer, NH-Division Ahmedabad -For Information and necessary Action.
4. Executive Engineer (Construction), M/s GETCO, Mehsana.
  - i. For information and with request to submit the license fees of Rs.799058/- through online portal for NTRP collection i.e through BHARATKOSH (<https://bharatkosh.gov.in/>) within 15 days along with performance BG amounting to Rs. 208600/-.
  - ii. The receipt of online license fee deposition should be submitted to this office with intimation to the Executive Engineer, NH- Division, Ahmedabad. The BG should be in favor of the Executive Engineer, NH- Division, Ahmedabad (as per prevailing procedure in R&B Dept.) and to be submitted to Executive Engineer, NH- Division , Ahmedabad custodian of BG/s.

The details for payment for submission of license fees through NTRP of is as under:


**Name of Ministry: ROAD TRANSPORT & HIGHWAYS**

**Pay & Account Office (PAO): 034650 -PAO(NH), Mumbai**

**Drawing & Disbursing Office(DDO): 234653, SE**

**Purpose: 'license fees for laying utility services'**

**'Processing fee for permission to access to NH'** (only if above purpose is not available)

  
(Ganesh Shelar)  
Executive Engineer  
For Regional Officer Gandhinagar

**Note: This document is not any kind of NOC.**



Subject: Permission for accommodation and crossing of 66 KV underground electric line (from Trimandir sub-station Adalaj -Sargasan line) along NH-147 between km 18/800 to km 19/400 and across @ 18/800 in the state of Gujarat

---

Details of the proposal are as under

1	Name of Applicant and Department	Executive Engineer (Construction), M/s GETCO, Mehsana
2	NH No	NH-147
3	Width of ROW	90 mtr
4	Whether Service road is existing	No.
5	Number of lane/s	6 lane with paved Shoulder
6	Purpose of utility	Underground electric pipeline
7	Dimension of pipelines	Under ground duct with 1400x 600 with top slab of 600x 300x 50 mm
8	Whether provisions of utility duct are available at propose location	Proposed by the applicant
9	Location of Utility w.r.t NH	along NH-147 between km 18/800 to km 19/400 and across @ 18/800
10	Methodology for laying Gas pipeline	HDD method
11	Whether details of rent /license fees is given	Yes. As per para.4 above
12	Whether State R&B has recommended the proposal for access permission	Yes, vide letter No. RW/GNR/NH/US/GL/NOC/349/2023 dated 15.09.2023