



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. of India)

क्षेत्रीय कार्यालय : "नारंग टावर", पहली मंजिल, उपआयुक्त यातायात पुलिस (नागपुर शहर) कार्यालय के सामने, पाम रोड, सिविल लाईन्स नागपुर-440 001 महाराष्ट्र
Regional Office : "Narang Towers", 1st Floor, Opp. to Office of Dy. Commissioner of Police Traffic (Nagpur City), Palm Road, Civil Lines, Nagpur- 440 001 Maharashtra
Tel/Fax : 0712-2520091, 0712-2980554 ई-मेल/ Email : ronagpur@nhai.org



भारतमाला
प्रगति के पथ पर अग्रसर

NHAI/RO-NAG/OL/NH-47/MPPTCL-Km.30.200/2020/ 3059

Date: 10.02.2020

Invitation of Public Comments

Sub: Proposal of permission for crossing of LILO of 220 KV Sarni Pandhurna line at 400 KV PGCIL S/s, Betul at Km.30.200 near Sasundra village on LHS to RHS on Nagpur-Saoner-Betul Section of NH-47 in the State of Maharashtra by EE, Madhya Pradesh Transmission Company Limited – Reg.

Ref.: (i) PD, PIU-2, Nagpur Lr.No.NHAI/PIU-2 NAG/NSB/NH-69/Central/2019/1452, dated 26.12.2019
(ii) EE, MPPTCL Lr.No.EE/EHT//Dn/ITR?2619, dated 25.11.2019

It is to inform all concern that the Executive Engineer, Madhya Pradesh Transmission Company Limited, Itarsi vide letter under reference (ii) has submitted a proposal for the subjected work and PD, NHAI, PIU, Nagpur has recommended the above proposal vide letter under reference (i) for approval of the Competent Authority / Highway Administrator.

2. The alignment proposed by that the Executive Engineer, Madhya Pradesh Transmission Company Limited, Itarsi along on Nagpur-Saoner-Betul Section of NH-47 in the State of Maharashtra is as follows:

- Overhead line crossing of LILO of 220 KV Sarni Pandhurna line at 200 KV PGCIL S/s, Betul near Sasundra village on LHS to RHS
- Both the towers are away from the NH boundary i.e. 66.2m and 64.8m respectively
- The vertical clearance of 14.7m will be maintained at the NH which is more than required.
- Height of the both the crossing towers is 39.22m
- Line is crossing the NH at 83°

3. As per Para-4 of Ministry's Circular No.RW/NH-33044/29/2015/S&R(R), dated 22.11.2016, the Highway Administration shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, the comments / objections of affected public is hereby invited with reference to the Ministry's circular dated 22.11.2016 due to above overhead line crossing on the subjected stretch. The objections / comments may be addressed to the below mentioned address upto 23.02.2020, beyond due date, no comments/ objections will be accepted.

Contd...2

मुख्यालय : जी-5 एवं 6, सेक्टर-10, द्वारका, नई दिल्ली - 110 075
Head Office : G-5 & 6, Sector-10, Dwarka, New Delhi - 110 075

- : 2 : -

The Regional Officer,
Regional Office - Nagpur
National Highways Authority of India,
"Narang Towers", 3rd Floor,
Opp.to Office of Dy. Commissioner of Police Traffic (Nagpur City),
Palm Road, Civil Lines, Nagpur-440 001, Maharashtra
Tel : 0712-2520091
Email : ronagpur@nhai.org

This is issued with the approval of the Regional Officer, RO, Nagpur

(Arun P. Sarodaya)
Dy. General Manager (Tech.)
NHAI, RO, Nagpur

Copy to : (i) Web Admn., NHAI, HQ, New Delhi - for uploading in NHAI's website
[web-admin@nhai.org]

(ii) Director, NIC, New Delhi
[mansoor@nic.in]

- for uploading in Ministry's website