



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt of India)

क्षेत्रीय कार्यालय, ओडिशा / Regional Office, Odisha

301 - ए, तीसरी मंजिल, पाल हाईट्स, प्लॉट नं जे/7, जयदेव विहार, भुवनेश्वर - 751013, ओडिशा

301-A, 3rd Floor, Pal Heights, Plot No : J/7, Jayadev Vihar, Bhubaneswar- 751013, Odisha

दूरभाष / Ph.: 0674 - 2361470/ 570/670 (का/ओ)

ई-मेल/e-mail : roodisha@nhai.org, ronhaiodisha@gmail.com, वेबसाइट/Web : www.nhai.gov.in



NHAI/13011/54/RO/OD/ 1958/2024

30.09.2024

To

The Sr. Technical Director,
NIC Centre at MoRTH,
Transport Bhawan,
New Delhi 110001

Sub: Four lane to Six laning of Chandikhole - Bhadrak (Km 62.000 to Km 136.500)
Section of NH-16 in the State of Odisha : Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16 from Chainage No. 122+400 to 124+100 (RHS) - reg.

Ref: PD, PIU- Chandikhole letter No. 1276 dated 22.08.2024

Sir,

Please find enclosed herewith a proposal for Permission Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16. The details are as under:

Sl. No.	Chainage	Along/ Across	HDPE / DI Pipe Dia in MM	Remarks
1.	122+400 to 124+100 (RHS)	Along	Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16	By HDD Method

2. Accordingly, as per guidelines issued by MoRT&H vide F. No. RW/NH-33044/29/2015/S&R(R) dt. 22.11.2016, the application along with the recommendations of concerned PD/Consultants are enclosed herewith with request to hoist the same in the Ministry's Website for public comments within 30 days of uploading on the website.

This is issued with the approval of Regional Officer, Odisha.

Thanking you,

Yours Sincerely,

Amit Kumar Gupta

(Amit Kumar Gupta)

Dy. General Manager (Tech)



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt of India)

क्षेत्रीय कार्यालय, ओडिशा / Regional Office, Odisha

301 - ए, तीसरी मंजिल, पाल हाईट्स, प्लॉट नं जे/7, जयदेव विहार, भुवनेश्वर - 751013, ओडिशा

301-A, 3rd Floor, Pal Heights, Plot No : J/7, Jayadev Vihar, Bhubaneswar- 751013, Odisha

दूरभाष / Ph.: 0674 - 2361470/ 570/670 (का/ओ)

ई-मेल/e-mail : roodisha@nhai.org, ronhaioodisha@gmail.com, वेबसाइट/Web : www.nhai.gov.in



INVITATION OF PUBLIC COMMENTS

Sub: Four lane to Six laning of Chandikhole - Bhadrak (Km 62.000 to Km 136.500)
Section of NH-16 in the State of Odisha : Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16 from Chainage No. 122+400 to 124+100 (RHS) - reg.

TDNODL has submitted a proposal for permission of Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16 from Chainage No. 122+400 to 124+100 (RHS). The details are as under:

Sl. No.	Chainage	Along/ Across	HDPE / DI Pipe Dia in MM	Remarks
1.	122+400 to 124+100 (RHS)	Along	Laying of 33 KV UG cable (3c x 400 Sq mm) 2 RUN along NH-16	By HDD Method

2. As per guidelines issued by MoRT&H vide F. No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will put out the application in the public domain for 30 days for seeking claims and objections on grounds of public inconvenience, safety and general public interest.

3. In view of the above, the comments of public, if any, on the above-mentioned proposal are invited on below mentioned address:

The Regional Officer,
National Highways Authority of India,
Regional Office, Odisha
301-A, 3rd Floor, Pal Heights,
J/7, Jayadev Vihar, Bhubaneswar 751013, Odisha
e-mail: roodisha@nhai.org

This is issued with the approval of RO, Odisha.

Anak se

Dy. General Manager (Tech)
National Highways Authority of India,
Regional Office, Odisha
301-A, 3rd Floor, Pal Heights,
J/7, Jayadev Vihar, Bhubaneswar 751013

To,
The Project Director,
NHAI, Chandikhol.

Sub: Submission of Check list for getting approval for laying of underground Electrical cable line through HDD on NH 16 from Bhadrak GSS To Tahasil PSS, Bhadrak.

Dear Sir,

With reference to above, we are submitting the check list duly fill up for laying of underground Electrical cable on NH 16 land for & necessary approval at your end.

CHECK LIST

S.no	ITEM	Information/Status	Remarks
1	General information	OPTCL/TPNODL/SDMF	
1.1	Name &Address of the Applicant/Agency	TPNODL BNED, Bhadrak	
1.2	National Authority number	NH-16	
1.3	State	ODISHA	
1.4	Location	Existing Road Bhadrak GSS To Tahasil PSS Bhadrak	
1.5	Chainage in km	KM 122+400 to 124+100	
1.6	Length in meters	1700	
1.7	Width of available ROW		
	a) Left side from center line towards increasing chainage/km direction	34 M	
	b) Right side from center line towards increasing chainage/km direction	42 M	
1.8	Proposal to lay underground electrical cable		
	a) Left side from center line towards increasing chainage/km direction	NA	
	b) Right side from center line towards increasing chainage/km direction	43M	
1.9	Proposal to acquire land		
	a)Left side from center line	NA	
	b) Right side from center line	NA	
1.10	Whether proposal is in the same side where land is nor to be acquired	NA	
	If not then where to lay the cable		
1.11	Details of already laid services ,if any along the proposed route	NA	
1.12	Number of lanes existing	6 Lanes	
1.13	Proposed number of lanes(2 lane with paved shoulders	NA	
1.14	Service road existing or not	yes	
	If yes then which side	LS	
	a)Left side from center line	NA	
	b) Right side from center line	yes	



PROJECT DIRECTOR,
NATIONAL HIGHWAYS AUTHORITY OF INDIA
PIU-CHANDIKHOLE

Executive Engineer(Elect.)
TPNODL
BNED, Bhadrak

S.no	ITEM	Information/Status	Remarks
1.15	Proposed service road	YES	
	a) Left side from center line		
	b) Right side from center line	KM 122+400 to 124+100	
1.16	Whether proposal to lay water supply Pipe line/Electrical Cable is after the service road or between the service road and main carriageway	Cable will go along the service lane. No crossing will be there.	
1.17	The permission for laying of water supply pipe line/Electrical cable Shall be considered for approval/rejection based on the Ministry Circulars mentioned as above		
	a) Carrying of sewage/gas pipelines on highway bridges shall not be permitted as fumes/gases pipes can accelerate the process of corrosion or may cause explosions thus being much more injurious than leakage of water	NO Sewage/Gas pipe lines on highway bridge will be carried.	
	b) Carrying of water pipes on bridges shall also be discouraged. However, if the water supply authorities seem to have no other viable alternative and approach the highway authority well in line before the design of the bridge is finalized they may be permitted to carry the pipeline on independent superstructure supported on extended portions of piers and abutments in such a manner that in the final arrangement enough free space around the superstructure of the bridge remains available for inspection and repairs .etc	YES water pipe lines on the bridge shall be carried.	
	c) Services are not being allowed indiscriminate on the parapet/any part of the bridges. Safety of the bridges has to be kept in view while permitting various services along bridge. Approvals are to be accorded in this regard with the concurrence of the Ministry's Project Chief Engineers only.	Not Applicable	
1.18	If crossing of the road involved If Yes. It shall be either encased in pipes or through structure or conduits specially built for that purpose at the expenses of the agency owning the line.	NA	
	a) Existing drainage structures not be allowed to carry the line.	YES, The existing structure will not be used to carry the line	
	b) Is it on a line normal NH	YES	
	c) Crossing Shall not be too near the existing structures on the National Highway ,the minimum distance being 15 meters. What is the distance from the existing structures	More than 15mtrs	
	d) The casing pipe or conduit pipe in the case of electric cable carrying the utility line shall be of steel, cast iron or reinforced cement concrete and have adequate strength and be large enough to permit ready withdrawal of the carrier pipe/cable.	Casing pipe will be HDPE Pipe of 200 mm dia.	



Executive Engineer(Elect.)
TPNODL
BNEB, Bhadrak

PROJECT DIRECTOR,
NATIONAL HIGHWAY AUTHORITY OF INDIA
PIU-CHANDIKHOLE

S.no	ITEM	Information/Status	Remarks
	e)Ends of the casing/Conduit pipe should be sealed from the outside, so that it does not act as a slope of the fills	Yes, It will be sealed on both side.	
	f)The casing/conduit pipe should be as minimum extend from drain to drain in cuts and toe slope in the fills	Yes, will be followed.	
	g)The top of the casing/conduit pipe should be at least 1.2 meter below the surface of the road subject to being at least 0.3 m below the drain inverts.	From it will be below 1.5mtr	
	h)Crossing shall be by boring method(HDD) specially where the existing road pavement is of cement concrete or dense bituminous concrete type.	NA	
	I)The casing/conduit pipe shall be installed with an even bearing throughout its length and in such a manner as to prevents the formation of waterway along it.	Yes	
2	Document/Drawing enclosed with the proposal	Yes,3sets	
2.1	Cross section showing the size of trench for open trenching method (Is it normal size of 1.2 m depth/0.3m wide)	NA	
	I) Should not be greater than 60 cm wider than the outer diameter of the pipe.	NA	
	II)Location as closer to the extreme edge of the right-of-way as possible but not less than 15 meter from the center lines of the nearest carriageway.	NA	
	III) Shall not be permitted to run along the National Highways when the road formation is situated in double cutting. Nor shall these be laid over the existing culverts and bridges.	NA	
	IV)These should be so laid that their top is at least 0.6 meter below the ground level so as not to obstruct drainage of the road land.	NA	
2.2	Cross section showing the size of pit and location of cable for HDD method	Shown in the Enclosed drawing.	
2.3	Strip plan/Route plan showing Water supply pipe line/Electrical Cable Chain age, width of ROW, distance of proposed cable from the edge of ROW, important mile stone, intersecting, cross drainage works etc.	As per the Dwg enclosed.	
2.4	Methodology for laying of showing water supply pipe etc.	NA	
2.4.1	Open trenching methods(May be allowed in utility corridor only where pave meter is neither cement concrete type. If yes, Methodology of refilling of trench.	NA	
	a)The trench width should be at least 30cm,but not more than 60cm wider than the outer diameter of the pipe.	NA	
	b)For filling of the trench, Beading shall be to depth of not less than 30cm it shall consist granular material unsuitable soil and rock edge should be excavated and replaced by selected material.	Yes	



PROJECT DIRECTOR,
NATIONAL HIGHWAYS AUTHORITY OF INDIA
PIU-CHANDIKHOLE

Executive Engineer (Elect.)
TPNODL
RNEB, Bhadrak

S.no	ITEM	Information/Status	Remarks
	c)The back shall be completed two stages (I) Side-fill to the level of the top of the pipe and (II) overfill to the bottom of the road crust.	Ok	
	d) 95% of the proctors Density. Overfill shall be connected to the same density as the material that had been removed consolidation by saturation or ponding will not be permitted.	Ok	
	e)The road crust shall be built to the same strength as the existing crust on either side of the trench. Care shall be taken to avoid the formation of a clip at the trench.	Ok	
	f)The excavation shall be protected by flagman, signs and barricades and red lights curing night hours.	Ok	
	g)If required , a diversion shall be constructed at the expense of agency owning the utility line.	Ok	
2.4.2	Horizontal Directional Drilling(HDD) Method	Cable laying by HDD Method only.	
2.4.3	Laying of Water Supply Pipe line/Electrical Cable through HD Works and method of laying.	NA	
	a)On Approaches the water mains/cables shall be carried along a line as close to the right way as possible up to a distance of 30m from the bridge and subject to all other stipulations in this Ministry's guidelines issued with letter no NH-HI/P/66/76 dated 19.11.197	Yes , Will be followed.	
3	Draft license agreement signed by two witnesses.	Enclosed	
4	Performance Bank Guarantee in favor of NHAI submitted @Rs.50/- per running meter (Parallel to NH) and Rs.1,00,000/- per crossing of NH, for a period of one year initially (Extendable if required till satisfactory completion laying the cables /ducts by proper filling and compaction, clearing debris/loose earth produced due to execution trenching at least 50m away from the edge of the right of way. No payment shall be payable by the NHAI to the license of clearing debris/loose earth	YES Agreed for submission of performance BG as per the last Month/NHAI Guideline	
4.1	Performance BG as per above obtained	In Conformity with NHAI	
4.2	Confirmation of BG has been obtained as per NHAI guidelines.	Yes	
5	Affidavit/Undertaking from the applicant for carrying out the work.	Yes	
5.1	Not to damage other utility, If damaged then to pay losses either to NHAI or to the concerned agency	Yes	
5.2	Renewal of Bank Guarantee.	Renewal to be done after its validity lapses	
5.3	Confirming all standard condition of NHAI guidelines	Yes	
5.4	Shifting of water supply pipe line/Electrical cable as and when required.	Yes, It will be carried out if required.	
5.5	Shifting due to 6 lining/widening of NH.	NA	
5.6	Indemnity against all damages and claims clause(XXLV)	Yes	



PROJECT DIRECTOR,
NATIONAL HIGHWAYS AUTHORITY OF INDIA
PIU-CHANDIKHOLE

Executive Engineer (Elect)
TPNODL
RNED.Bhadrak

S.no	ITEM	Information/Status	Remarks
5.7	Traffic movement during laying of Water Supply pipe line/Electrical cable to manage by the applicant.	Yes, The same will be managed at the time of work execution.	
5.8	If any claim is raised by the concessionaire then the same has to be paid by the applicant.	Yes	
5.9	Prior approval of the NHAI shall be obtained before undertaking any work of installation, shifting or repairs or alternations to the showing water supply pipe line/Electrical cable located in the National Highway right of ways.	Yes, Necessary permission to be taken before starting the work.	
5.10	Expenditure ,if any incurred by NHAI for repairing and damage caused to the National Highway by the laying maintenance or shifting of the water supply pipe line/Electrical Cable will be borne by the agency owning the line.	Yes	
5.11	If the NHAI considers it necessary in future to move the utility line for any work of improvement or repairs to the road, it will be carried out as desired by the NHAI at the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.	Yes	
5.12	Certificate from the applicant in the following format.		
	I) Laying of Electrical cable line will not have any deleterious effects on any of the bridge components and road way safety for traffic.	Yes	
	II) For 6 lining we do undertake that I will reinstate service road/approach road/utilities at our own cost not standing the permission granted within such time as will be stipulated by NHAI for future six-lining or any other development.	Yes, It will be certified.	
6	Who will sign the agreement	Executive Engineer, TPNODL, Bhadrak North Electrical Division, Bhadrak	
7	Certificate from the Project Director.	NA	
7.1	Certificate for confirming of all standard condition issued vide ministry Circular No NH-41(581/68 dated 31.01.1969, Ministry circular no NH-III/P/66/76 dated 18/19.11.1976, Ministry circular no RW/NH-III/P/66/76 dated 11.05.1982' Ministry circular no RW/NH-11037/1/86/DOI dated 19.01.1995, Ministry circular no RW/NH-34066/2/95/S&R dated 25.10.1999 & Ministry circular no RW/NH-34066/7/2003 S&R (B) dated 17.09.2003.	Enclosed	
7.2	Certificate from PD in the following format.		
	I) It is certified that any other location of the electrical cable would be extremely difficult unreasonable costly and the installation of Water Supply pipe line/Electrical Cable within ROW will not adversely affect the design, stability & traffic safety such as widening of the carriageway, easing of curve etc.	Enclosed PROJECT DIRECTOR, NATIONAL HIGHWAYS AUTHORITY OF INDIA PIU-CHANDIKHOLE	




PROJECT DIRECTOR,
NATIONAL HIGHWAYS AUTHORITY OF INDIA
PIU-CHANDIKHOLE

Executive Engineer/Elect
TPNODL
NHED, Bhadrak


S.no	ITEM	Information/Status	Remarks
	II) For 6-Lanning.	NA	
	a) Where feasibility is available I do certify that there will be no hindrance to proposed six-lining structures at the said location.	NA	
	b) In case feasibility report is not available I do certify that sufficient ROW is available site for accommodating proposed six lining.	NA	
8	If NH section proposed to be taken up by NHAI on BOT basis a clause is to be inserted in the agreement." The permitted Highway on which licensee has been granted the right to pay cable/duct has also been granted as right of way to the concessionaire the concession agreement for up-gradation of... NH no 215 on bid, operate and transfer basis and therefore, the licensee shall honor the same	We will honor NHAI Guidelines	
9	Who will supervise the work of laying of UG Electrical cable use.	Executive Engineer, TPNODL, Bhadrak North Electrical Division, Bhadrak	
10	Who will ensure that the defects in road portion after laying of Electrical cable line are corrected and if not corrected then what action will be taken.	Executive Engineer, TPNODL, Bhadrak North Electrical Division, Bhadrak	
11	Who will pay the claims for damages done/disruption permission in the concessionaire if asked by the concessionaire?	Executive Engineer, TPNODL, Bhadrak North Electrical Division, Bhadrak	
12	A certificate form PD that he will enter the proposed permission in the register of records of the permissions in the register of the permissions in the prescribed preformat (copy enclosed)	Enclosed	
13	If any previous approval is accorded for laying of underground water supply pipe line/Electrical Cable then Photocopy of register of records of permissions accorded as maintained by PD then copy be enclosed.	NA	

Thanking you.

Yours Faithfully,


 Executive Engineer (Electrical)
 TPNODL, Bhadrak




 PROJECT DIRECTOR,
 NATIONAL HIGHWAYS AUTHORITY OF INDIA
 PIU-CHANDIKHOLE