



Government of India
Ministry of Road Transport & Highways

Office of the Regional Officer, (Civil)
No. 32, 2nd Floor, KSCFL Building, Race Course Road, BENGALURU-560 001
Email: robengaluru@gmail.com; Telephone: 080-22267457, 080-22265765

No. RW/BNG/GENL/PER.CASES/SMG DVN./2020

Dated: 07.11.2022

Notice Inviting Public Comments on proposal seeking Permission for laying of HT UG cable of 2X400sqmm XLPE armed from Channagiri Town limit along NH-369 (13) from Km.483.910 to km.484.920 on LHS for a length of 1.01 Kms & Road Crossing with HDPE pipe 90mm & 200mm (with casing 400mm) dia at Km.483.910 of Chitradurga-Shivamogga Section in the State of Karnataka by Executive Engineer, Karnataka Housing Board, Co-ordinating unit, Shivamogga.

Reference: The Chief Engineer, National Highways, Bengaluru letter No. CNH/TA-3/AE-9/NH-13/Km. 484.910 to Km 484.920/OFC/2022-23/1094 dated 30.06.2022.

The Chief Engineer, National Highways, Bengaluru vide letter cited under reference above (Annexure I), has submitted proposal seeking Permission for laying of HT UG cable of 2X400sqmm XLPE armed from Channagiri Town limit along NH-369 (13) from Km.483.910 to km.484.920 on LHS for a length of 1.01 Kms & Road Crossing with HDPE pipe 90mm & 200mm (with casing 400mm) dia at Km.483.910 of Chitradurga-Shivamogga Section in the State of Karnataka by Executive Engineer, Karnataka Housing Board, Co-ordinating unit, Shivamogga.

4. The proposal has been examined as per Ministry's Guidelines vide letter no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 and is generally found in order.

5. In view of above, as per Ministry's said guidelines Para 4, public comments are invited on the above proposal making claims and raising objections (on grounds of public inconvenience, safety and general public interest) if any within 30 days on public portal i.e., website of Ministry of Road Transport and Highways (morth.nic.in) in Form-A (copy enclosed) for "Accommodation of Public and Industrial Utility Services along and across National Highways".

Comment Inviting Authority

The Regional Officer, (Civil)
Ministry of Road Transport & Highways
No. 32, 2nd Floor, KSCFL Building,
Race Course Road, BENGALURU-560 001
Email: robengaluru@gmail.com; Telephone: 080-22267457, 080-22265765

Enclosed: As above.

(Sandesh.K)

Asst. Engineer(C)

for Regional Officer, (Civil)

- Copy to: (i) The Senior Technical Director, NIC, Transport Bhawan, New Delhi- 110001 for uploading on Ministry's website.
- (iii) Executive Engineer, Karnataka Housing Board, Co-ordinating unit, Shivamogga for information.

(Sandesh.K)

Asst. Engineer(C)

for Regional Officer, (Civil)

FORM A

Form for seeking claims and objections (on grounds of public inconvenience, safety and general public interest) on the application for Accommodation of Public and Industrial Utility Services along and across National Highways.

Subject: Proposal seeking Permission for laying of HT UG cable of 2X400sqmm XLPE armed from Channagiri Town limit along NH-369 (13) from Km.483.910 to km.484.920 on LHS for a length of 1.01 Kms & Road Crossing with HDPE pipe 90mm & 200mm (with casing 400mm) dia at Km.483.910 of Chitradurga-Shivamogga Section in the State of Karnataka by Executive Engineer, Karnataka Housing Board, Co-ordinating unit, Shivamogga - Reg.

The claims and objections (on grounds of public inconvenience, safety and general public interest) by the general public needs to be given within 30 days of uploading the online application for comments.

Sl. No	Item	Details
1	Name of the person who is desiring to give claims and objections (on grounds of public inconvenience, safety and general public interest)	
2	Address of the person	
3	Details of the application for Accommodation of Public and Industrial Utility Services along and across National Highways against which claims and objections are being given (name of applicant and other details like site address etc.)	
	d) Application No.	
	e) Name of applicant (who applied to Accommodation of Public and Industrial Utility Services along and across National Highways)	
	f) Details of Application	
4	The claims and objections (on grounds of public inconvenience, safety and general public interest)	





Phone No:2276601

Fax No:080-2276605

E-Mail: cenhpwd@yahoo.co.in

GOVERNMENT OF KARNATAKA
(Public Works Department)

Telegram : CENHW
Telephone : 080-22276601
Fax : 080-22276605
e-mail : cenhpwd@yahoo.co.in

Office of the Chief Engineer,
National Highways, K.R. Circle,
Bangalore-560001

No: CNH/TA-3/AE-9/NH-13/Km 484.910 to Km 484.920/OFC/2022-23/11094 Dated:

30 JUN 2022

To,

The Chief Engineer-Regional Officer,
KSCFL Building, Race Course Road,
Ministry of Road Transport and Highways,
Bangalore.

O/o. THE CE-RO
MORT&H, BENGALURU

Diary No.: 12.76.

Date: 1-07-2022

Sir,

Sub:- Proposal for obtaining permission for laying of HT UG cable of 2X400sqmm XLPE armed from Channagiri town limit along NH-369(13) Km 483.910 to Km 484.920 on LHS for a length of 1.01Kms & Road crossing with HDPE pipe 90mm & 200mm dia at Km 483.910 of Chitradurga-Shivamogga section- Issue of NOC reg.

Ref:- The SE, NH,PPP Cell, B'lore letter No.63-64 Dtd:-27.05.2022.

The Telescopic Networks Ltd, Bangalore has sought permission for laying of HT UG cable of 2X400sqmm XLPE armed from Channagiri town limit along NH-369(13) Km 483.910 to Km 484.920 on LHS for a length of 1.01Kms & Road crossing with HDPE pipe 90mm & 200mm dia at 483.910 Km of Chitradurga-Shivamogga section. Based on the request of the Telescopic Networks Ltd, Bangalore the Assistant Executive Engineer, NHSD, Shimoga has inspected the site and verified the proposal with respect to Ministry's guide line and circular No.RW/NH-33044/29/2015/S&R(R) Dated 22.11.2016. After detailed examination the Superintending Engineer, NH, PPP Cell Bangalore has recommended for issue of NOC as per Ministry's guide lines.

The firm proposed to lay the HT UG cable from Km 483.910 to Km 484.920 on LHS for a length of 1.01Kms by HDD method & Road crossing with HDPE pipe 90mm & 200mm dia at Km 483.910. A strip plan indicating the proposed OFC lines are also here with enclosed

However, the request of the firm to issue NOC for laying HT UG cable of 2X400sqmm XLPE armed from Channagiri town limit along NH-369(13) Km 483.910 to Km 484.920 on LHS for a length of 1.01Kms & Road crossing with HDPE pipe 90mm & 200mm dia at Km 483.910 of Chitradurga-Shivamogga section is forwarded herewith subject to the following conditions.

1. The applicant has to furnish the License deed duly signing the agreement for the use of NH land as per Ministry's Guidelines along with the required Bank Guarantee/Performance guarantee.
2. The Cable shall not be laid at depth not less than approved depth from road surface / ground level.
3. The Cable should be laid as per IRC: 98-1997 Guidelines on Accommodation of utility services on roads in urban areas.
4. Laying of cables should not be carried out during the monsoon season.
5. Carriageway has to be restored for smooth vehicular movements immediately if any damages are observed during the work.
6. All care & adequate safety measures have to be taken for controlling the traffic during the execution.
7. This trench should be properly restored to the original condition in shoulder & formation area.
8. Under any circumstances highway structures should not be damaged.
9. The Cable trench will have to be shifted by the concerned department without damaging National Highway property in case it is required for widening / improvement or reconstruction.
10. This department is not responsible for any damages which are likely to occur to the Cable caused during maintenance or any other nature of works to be carried out in National Cable is to be laid along the drain it should be refilled with M15 concrete and original drain may be restored for the true flow of rain water with minimum depth of 0.60mtrs for surface runoff.
11. No trenching work is allowed on the approaches of bridges.
12. Back filling trench across the road should be done with proper adequate compaction.
13. Earth-slip if observed during the trenching, by the side of the formation or hillock side immediate action to be taken for a restoration.
14. Trenching should be done on day to day basis with the excavation, laying the pipelines and backfilling, so as not to keep the trench open for any hazards.
15. The restoration charges should be deposited well in advance.
16. Work is to be taken up only after giving the intimation well in advance to this office, duly obtaining NOC from this department.
17. As per Ministry's Guidelines for granting Right of Way permission to Telecom service Licensees/Infrastructure providers for laying of Telecom cables/ducts on NH land vide letter No.RW/NH-

33044/29/2015/S&R(R) dated:22.11.2016. The calculation details of


- license fees enclosed separately;
- 18. Trenching should be done by HDD method only for entire length.
- 19. The necessary fee may be paid to the department as per the ministerial norms, as mentioned below by the applicant.
- 20. The approval may be communicated from NH point of view.

With the above conditions the proposal along with check list and necessary documents and drawings are here with enclosed and submitted with a request to communicate approval to issue NOC.

Encl : As above

Draft Approved by CE

Yours faithfully,


For Chief Engineer,
National Highways,
Bengaluru.

