



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

श्रेणीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलासानी नगर,

रानीगारीतोटा, कृष्णालंका, विजयावाडा - 520 013, आन्ध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS.No. : 373/2A, Kodandaramalayam, Chalasani Nagar,

Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh.

फोन / Tel : 0866-2483910, ई-मेल/e-mail: rovijayawada@nhai.org, nhairovja@gmail.com

वेब/ web: www.nhai.gov.in

Lr.No. NHAI/RO-VJA/PIU-AMR/NH-16/C-V/NOC/2025/1694

Dt.10.06.2025

To

The Sr. Technical Director,
NIC, Transport Bhawan,
New Delhi- 110001.

Sub: M/s. Jaipuria Beverages & Food Industries Pvt. Ltd. - Permission for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 (Crossing length 78m) on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District in the State of Andhra Pradesh (MORTH NOC Portal ID: 20250222/2/16/35792/14642) - **Public comments - Reg.**

Sir,

Please find enclosed herewith a proposal submitted by M/s. Jaipuria Beverages & Food Industries Pvt. Ltd. for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District in the State of Andhra Pradesh.

2. As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22nd November 2016, the application along with the recommendations of PD, PIU-Amaravati & notice inviting public comments are enclosed herewith with a request to host the same in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest), for taking further necessary action.

Yours faithfully,

(R.K. Singh, IES),
CGM (Tech.) & Regional Officer

Encl: As above

Copy to:

(i) PD, PIU - Amaravati

(ii) M/s. Jaipuria Beverages & Food Industries Pvt. Ltd.



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

श्रेणीय कार्यालय : 41-29-45A, सर्वे नं: 373/2A, कोदंडरामालयम्, चलासानी नगर,
रानीगारीतोटा, कृष्णलंका, विजयावाडा - 520 013, आन्ध्र प्रदेश

Regional Office : D.No. 41-29-45A, RS.No. : 373/2A, Kodandaramalayam, Chalasani Nagar,

Ranigari Thota, Krishna Lanka, Vijayawada - 520 013, Andhra Pradesh.

फोन / Tel : 0866-2483910, ई-मेल/e-mail: rovijayawada@nhai.org, nhairovja@gmail.com

वेब/ web: www.nhai.gov.in



Lr.No. NHAI/RO-VJA/PIU-AMR/NH-16/C-V/NOC/2025/1693

Dt.10.06.2025

INVITATION OF PUBLIC COMMENTS

Sub: M/s. Jaipuria Beverages & Food Industries Pvt. Ltd. - Permission for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 (Crossing length 78m) on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District in the State of Andhra Pradesh (MORTH NOC Portal ID: 20250222/2/16/35792/14642) - Public comments - Reg.

The Project Director, PIU - Amaravati submitted a proposal of M/s. Jaipuria Beverages & Food Industries Pvt. Ltd. for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 (Crossing length 78m) on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District in the State of Andhra Pradesh.

As per MORTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22nd November 2016, the Highway Administration will put out the application in the Ministry's website for 30 days seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, the comments of public, if any, on the above mentioned proposal is invited on below mentioned address.

Regional Officer - Vijayawada,
National Highways Authority of India,
Regional Office, Dr. No.41-29-45A, R. S. No.373/2A
Near Kodandaramalayam, Chalasani Nagar,
Ranigarithota, Krishnalanka, Vijayawada - 520 013.
Email: rovijayawada@nhai.org

(R.K. Singh, IES),
CGM (Tech.) & Regional Officer



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

प.क.ई. अमरावती (आ.प्र.) 136ए, 106&107, वसन्ता रेसिडेंसी,

श्री लक्ष्मी नरसिम्ह स्वामी कॉलनी, मंगलगिरी, आ.प्र. - 522 503

PIU-Amaravati(AP), 136A, 106&107, Vasantha Residency,

Sri Lakshmi Narasimha Swamy Colony, Mangalagiri, A.P. - 522 503.

टेली / Tele : 08645 - 234599 ई-मेल / E-mail : piuamaravati@nhai.org / nhapiuamaravati@gmail.com

वेब / web : www.nhai.gov.in



NHAI/PIU-Amaravati/11013/13(OHE)/2020/Vol.1/755

14th May, 2025

To

The CGM(T) & Regional Officer,
National Highways Authority of India
Door No.41-29-45A, R.S.No.373/2A
NearKodandaramalayam
Chalasani Nagar, Ranigarithota
Krishnalanka
Vijayawada - 520 013

Sir,

Sub: NHAI, PIU - Amaravati - 6 laning of Chilakaluripet - Vijayawada section of NH-5 (New NH -16) - M/s. Jaipuria Beverages & Food Industries Pvt. Ltd., - Permission for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District, Andhra Pradesh- Approval Requested - Reg.

Ref: 1. M/s Jaipuria Beverages & Food Industries Pvt. Ltd., lr. no.Nill dated 24.02.2025
2. PIU lr. no. NHAI/PIU-Amaravati/11013/13(OFC)2020/Vol.1/409 dated 07.03.2025
3. IE lr. no. MSV_SriInfotech/103/KAZA/2025/NHAI/1774 dated 26.03.2025
4. PIU lr. no. NHAI/PIU-Amaravati/11013/13(OFC)2020/Vol.1/665 dated 25.04.2025
5. M/s Jaipuria Beverages & Food Industries Pvt. Ltd., lr. no.Nill dated 06.05.2025

It is to inform that M/s Jaipuria Beverages & Food Industries Pvt. Ltd, vide reference 1st & 5th cited requested permission for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District, Andhra Pradesh.

2. In this connection, PIU vide reference 2nd cited forwarded the proposal to IE, M/s MSV Intl. Inc. in association with M/s Sri Infotech, with a request to examine the proposal as per MoRTH guidelines and to furnish necessary comments/ recommendations.

3. Accordingly, IE, MSV Intl. Inc. In association with M/s Sri Infotech vide reference 3rd cited submitted as follows:

I. The width of the ROW at the location proposed is 39.00m on LHS and 39.00m on RHS from centreline.

II. As per the plan submitted, the applicant has proposed 33KV Over Head Electrical Line Crossing with M+12 Tower at Km.380+280.(Crossing length =78 m)

- III. The applicant has submitted Checklist, Drawings and other relevant documents as per NHAI guidelines.
- IV. The proposed site was checked with the checklist, drawings and other documents submitted by the applicant and all the items in the checklist are satisfying the guide lines of MoRTH circular F.No. RW-NH-33044/29/2015-S&R(R) dated 22.11.2016 & NH-36094/01/2022-S&R(P&B) (E-208825) dated 24.04.2023.
- V. The applicant has submitted all relevant undertakings such as:
- a. To furnish Performance Bank Guarantee calculated at the rate as per Ministry Circular per route Meter to NHAI for a period of one year initially.
 - b. To furnish a fresh Bank Guarantee or extend the Bank Guarantee for a period of one year, in case the work contemplated is not completed to the satisfaction of Authority, which has granted the permission within a period of 11 months from the date of issue of Bank Guarantee.
 - c. To Pay Licensee Fees/Lease Rental charges for granting License for use of Highway Land whenever charged by the Highway Administration as per point no. 5 of MoRTH guidelines dated 22.11.2016.
 - d. Not to damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.
 - e. To confirm all standard conditions of Ministry Circulars and NHAI Guidelines.
 - f. Indemnify NHAI against all damages and claims.
 - g. To Manage Traffic movement during laying of Utility line without hampering the traffic.
 - h. If any claim is raised by the Concessionaire/Contractor then the same will be paid by applicant.
 - i. Prior approval of the NHAI shall be obtained before undertaking of any work of installation, shifting or repairs or alterations of the Utility located in the National Highway right of way.
 - j. To bear expenditure, if any, incurred by NHAI for repairing any damage caused to the National Highway by the laying maintenance of shifting of the Utility line.
 - k. Text of the license deed is as per verbatim of MoRTH format (issued vide Ministry's Circular no. RW/NH-33044/29/2015/S&R (R) dated 22.11.2016).
 - l. To shall utility as and when asked by MoRTH/NHAI.
 - m. To manage traffic movement during laying of 33KV Electrical line.
 - n. If NHAI considers in necessary in future to move the utility line for any work of improvement or repairs to the road, it will be carried out as desired b NHAI

at the cost of the agency owning the utility line within a reasonable time (not exceeding 60 days) of the intimation given.

VI. Applicant has submitted Certificates such as,

- a. Laying of utility (Electrical Line) will not have any deleterious effects on any of the bridge components and roadway safety for traffic.
- b. This proposal implemented now will not affect any likely future improvement to geometries.
- c. The Proposal is in accordance with the Government of India specifications.
- d. We do undertake that, we will relocate the utility line at our own cost notwithstanding the permission granted within such time as will be stipulated by NHAI for future six-laning or any other development.
- e. We undertake that permission does not lead to the adverse impact on the safety and stability of the highway structures.

VII. The applicant has submitted detailed drawings and methodology for erecting 33KV Overhead line with M+12 tower.

4. While submitting the above, IE recommended the proposal of M/s Jaipuria Beverages & Food Industries Pvt. Ltd, for laying of Over Head Electrical line (33KV) with M+12 Tower for approval of Competent Authority as requested by the applicant.

5. In this connection, PIU vide reference 4th cited above communicated certain observations to M/s Jaipuria Beverages & Food Industries Pvt. Ltd that the proposal shall be submitted by concerned Electrical Department duly signing of checklist, License fee and undertakings as per MoRT&H Circular dated 22.11.2016 & 24.04.2023 and requested to submit the revised proposal duly complying the observations.

6. Accordingly, M/s Jaipuria Beverages & Food Industries Pvt. Ltd, vide reference 5th cited submitted the documents of check list, Licence fee and undertaking duly signed by the Executive Engineer Electrical Operational Tower-2 APCPDCL, Guntur and requested for laying of OH Electrical Line Crossing with M+12 Tower at Km 380.280 on Chilakaluripet-Vijayawada section of NH-16.

7. Further, it is to submit that the location falls under Chilakaluripet-Vijayawada section of NH-16 and the BoT(Toll) Concession period was completed on 21.07.2024. Hence, comments of the Concessionaire are not required.

8. The applicant has submitted calculation of license fee and Performance Bank Guarantee for Rs.12,624.77/- and Rs. 10,380/- respectively and the same have been verified as per MoRTH guidelines and found in order.

9. The proposal of laying of Over Head Electrical line (33KV) with M+12 Tower has been examined along with the comments of IE and found to be in line with guidelines issued vide MoRTH Circular dated 22.11.2016, subject to the following conditions:

- (i) Latest CEA Guidelines *compliance*
- (ii) Work shall be carried out in consultation with IE/PBMC Contractor.

In light of the above, the proposal along with the copies of all the above mentioned documents are herewith submitted with a request to communicate the approval of the Competent Authority for laying Utility Services on National Highways for laying Overhead Electrical Line Crossing with M+12 Towers at Km.380+280 on Chilakaluripet - Vijayawada section of NH-16 in Nadimpalem Village, Pathipadu Mandal, Guntur District, Andhra Pradesh, at an early date

Yours faithfully,

Encl: As above

T. Parvateesam 14/5/2025
(T. PARVATEESAM)
Project Director

CERTIFICATE

1. Undersigned has examined the proposal of the applicant for laying of Over Head Electrical line with M+12 Tower and confirms that all the standard conditions are satisfied as per guidelines of Ministry Circular No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016.
2. It is certified that any other location for utility line would be extremely difficult and unreasonably costly and installation of utility line within RoW will neither adversely affect the design, stability & traffic safety of highway nor the likely future improvement such as widening of the carriageway, easing of curve, etc.
3. It will be ensured that supervision of the work of laying of utility and ensured that the defects in road portion after laying of utility are corrected.
4. It will be notified /forfeit the Bank Guarantee for claims for damages done/disruption in working, if any.
5. It will be ensured that proposed permission is entered in the register of records.

T. Parvateesam 14/5/2025
(T PARVATEESAM)
Project Director
NHAI, PIU-Amaravati(AP)