



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

National Highways Authority of India

(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
(Ministry of Road Transport & Highways, Government of India)

परियोजना क्रियान्वयन इकाई - बागपत
Project Implementation Unit, Baghpat

फ्रेंड्स कॉलोनी, निकट पी.डब्ल्यू.डी गेस्ट हाउस, बड़ौत रोड, जिला-बागपत - 250609
Friend Colony, Near PWD Guest House, Baraut Road, District Baghpat - 250609

टेलीफोन: 0121-2222971, ई-मेल : piu.baghpat@gmail.com, piubaghpat@nhai.org Web.: www.nhai.gov.in



NHAI/PIU-BPT/1041/709B (Ch.48.296)/2025/D-17575

Date:24.07.2025

Invitation of Public Comments

Sub: NOC case for laying of electric cable (3X70 mm² 11kV U/g XLPE Double circuit Cable) of "M/s Krishi Cress" crossing at Km. 48.296 (LHS to RHS) (Total length 30.48m) on NH-709B (Baghpat to Shamli road), in the state of UP -Reg.

1. Authorized Signatory M/S Krishi Cress cables has submitted proposal for laying of electric cable (3X70 mm² 11kV U/g XLPE Double circuit Cable) of "M/s Krishi Cress" crossing at Km. 48.296 (LHS to RHS) (Total length 30.48m) on NH-709B (Baghpat to Shamli road), in the state of UP.
2. From the submitted proposal, it is seen that the proposal of laying the electric cable is crossing NH-709B at CH. 48.296 from LHS to RHS whose total length is 30. 48m. The depth of utility from ground level (as mentioned in checklist is 1.2 m and HDD method shall be adopted for the same.
3. As per the guidelines, issued by the Ministry vide OM no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).
4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach this office within 30 days from the date of publication, beyond which no comments shall be entertained.

The Project Director,
National Highways Authority of India
Project Implementation Unit - Baghpat
Friends Colony, Near PWD Guest house,
Baraut Road, District Baghpat - 250609

Encl: As above.

Project Director
NHAI, PIU Baghpat

Copy to:

1. The Regional Officer, RO Delhi for kind information.
2. Web Admin, NHAI HQ - with request to uploading on NHAI website.
3. The Technical Director, NIC, Transport Bhawan, New Delhi - with request for uploading on Ministry's website.
4. Authorized Signatory M/S Krishi Cress for information.