



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

NATIONAL HIGHWAYS AUTHORITY OF INDIA

(Ministry of Road Transport and Highways, Govt. of India)

क्षेत्रीय कार्यालय / REGIONAL OFFICE

ई-6/47, स्मृति परिसर, साईबोर्ड के पास, अरेरा कॉलोनी, भोपाल (म.प्र.)-462016

E-6/47, Smriti Parisar, Near Sai Board, Arera Colony, Bhopal (M.P.)-462016

दूरभाष/Phone: 0755-2426638, फ़ैक्स/Fax: 0755-2426698, ई-मेल/E-mail ID: robhopal@nhai.org



भाराराप्रा/क्षे.का.-म.प्र./आगरा-ग्वालियर/765 के.वी./2026/56290

दिनांक 02.01.2026

Invitation of Public Comments/ सार्वजनिक टिप्पणियों का आमंत्रण

विषय: उत्तर प्रदेश राज्य में तहसील-खेरागढ़, जिला-आगरा के सैया गांव के पास आगरा-ग्वालियर एनएच-44 के (चेनेज 129 किमी से 130 किमी तक) पर 765 केवी डी/सी दौसा-घिरोर टी/एल पार्ट-III (पीजीसीआईएल) की ओवरहेड क्रॉसिंग किए जाने की अनुमति बावत्।

संदर्भ: परियोजना निदेशक-ग्वालियर का ई-फाईल (कंप्यूटर) नं. 301918.

1. परियोजना निदेशक, पीआईयू-ग्वालियर, भाराराप्रा द्वारा ई-ऑफिस क्रमांक 301918 के माध्यम से उत्तर प्रदेश राज्य में तहसील-खेरागढ़, जिला-आगरा के सैया गांव के पास आगरा-ग्वालियर एनएच-44 के (चेनेज 129 किमी से 130 किमी तक) पर 765 केवी डी/सी दौसा-घिरोर टी/एल पार्ट-III (पीजीसीआईएल) की ओवरहेड क्रॉसिंग किए जाने हेतु प्रस्ताव प्रस्तुत किया है।

PD, PIU-Gwalior, NHAI vide e-office no. 301918 has submitted the proposal for **Permission for laying of overhead crossing of 765 KV D/C Dausa-Ghiror T/L Part-III (PGCIL) on NH-44 near Saiyan Village, Tehsil -Kheragarh, District - Agra (from chainage 129 km to 130 km) in the state of Uttar Pradesh.**

2. मंत्रालय के कार्यालय ज्ञापन संख्या OM No. RW/NH-33044 S&R (R) dated 22.11.2016 के अनुसार, दावे और आपत्तियां (सार्वजनिक असुविधा, सुरक्षा और सामान्य सार्वजनिक हित के आधार पर) मांगने के लिए आवेदन को 30 दिनों के लिए सार्वजनिक डोमेन में रखा जाएगा।

As per Ministry vide OM No. RW/NH-33044 S&R (R) dated 22.11.2016, the application shall be put out in public domain for **30 days** for seeking claims and objections (on ground of public inconvenience, safety and general public interest).

3. तदनुसार, दावे और आपत्तियां मांगने के लिए उपरोक्त प्रस्ताव (आवेदन की प्रति संलग्न) पर 30 दिनों के भीतर (यानी 02.02.2026 तक) सार्वजनिक पोर्टल (यानी MoRT&H की वेबसाइट (www.morth.nic.in)) पर जनता की टिप्पणियां आमंत्रित की जाती हैं, जिसके बाद किसी भी टिप्पणी पर विचार नहीं किया जाएगा। टिप्पणी आमंत्रित करने वाले प्राधिकारी का पता इस प्रकार है:

Shrawangee
02/01/2026

Accordingly, the public comments are hereby invited on the above proposal (copy of application enclosed) for seeking claims and objections within 30 days (i.e. by **02.02.2026**) on public portal (i.e. website of MoRTH (www.morth.nic.in)) beyond which no comments will be considered. The address of comments inviting authority is as under:

राजमार्ग प्रशासक, क्षेत्रीय अधिकारी कार्यालय भारतीय राष्ट्रीय राजमार्ग प्राधिकरण, ई-6/47, स्मृति परिसर, साई बोर्ड अरेरा कॉलोनी के पास, भोपाल (मप्र)-462016	The Highway Administrator O/o Regional Officer, National Highways Authority of India E-6/47, Smriti Parisar, Near Sai Board Arera Colony, Bhopal (MP)-462016
--	--

यह पत्र राजमार्ग प्रशासक सह क्षेत्रीय अधिकारी के अनुमोदन उपरान्त जारी किया जा रहा है।
This is being issued with the approval of Highway Administrator-cum-Regional Officer.

Shivangee
02/02/2026
(शिवांगी बरनवाल)
उप प्रबंधक (तक.)

संलग्न: उपरोक्तानुसार।

प्रतिलिपि:

1. **वेब एडमिन, भा.रा.रा.प्रा.,** मुख्यालय, नई दिल्ली की ओर सर्वजनिक टिप्पणियों के लिए भा.रा.रा.प्रा. की वेबसाइट पर अपलोड करने के अनुरोध के साथ।
2. **वरिष्ठ तकनीकी निदेशक, एनआईसी,** परिवहन भवन, नई दिल्ली की ओर सार्वजनिक टिप्पणियों के लिए सड़क परिवहन की वेबसाइट पर अपलोड करने के अनुरोध के साथ।
3. **परियोजना निदेशक, पकाई-ग्वालियर (म.प्र.)** की ओर सूचनार्थ प्रेषित।
4. **पावरग्रिड घिरोर ट्रांसमिशन लिमिटेड, एन आर-III- मैनपुरी (उ.प्र.),** की ओर सूचनार्थ प्रेषित।

CHECK- LIST**Annexure-03**

Guidelines for processing the proposal for laying of Utility line in the land along National Highways vested with NHAI/PWD/BRO.

General Information

Name and Address of the Applicant/Agency : Sr.GM (I/c-PGTL). 2A/216, Awash
Vikas Colony, Shikohabad,
Firozabad (Uttar Pradesh 283135).

1. National Highway No. : NH-44
2. State : Uttar Pradesh
3. Location : Vill- SAIYAN
4. Chain-age in km : 129+694 KM.
5. Length in m : 236.43 M
6. Width of available ROW in both side : 67 M
7. Side of NH : Across the National Highway
(left or right side of NH towards increasing
chainage/Km direction)
8. Name of Highway Authority of : NHAI PIU, Agra
9. NHAI/PWD/BRO : NHAI
10. Highway Administration address : PROJECT DIRECTOR
NHAI Division
A208,PHOOL VATIKA,
AGRA,KAMAL NAGAR AGRA
-282004 (Uttar Pradesh)

132

प्रबंधक (TECH.)
Manager (Tech.)
(PIU)-आ.रा.रा.प्र. (NHAI)
ए.का.ई.
प्रमुख (सि.प्र.)
PROJECT DIRECTOR
(PIU)-आ.रा.रा.प्र. (NHAI)
ए.का.ई.

S.No	Item	Measurement. Observations as per site conditions	MORTH Norms	Whether complying with MORTH Norms
1	Details of already laid utility service, if any	NO		Yes
2	Whether up gradation of the stretch in near future is proposed or not	NO		Yes
	(a) If yes, provision of utility adversely affect the plan of up-gradation	Not affect plan of up-gradation		Yes
3	Laying of the utility service along the National Highways.	NA It is across the N.H		Yes
3.1.	Location of proposed utility service along the stretch	NA		Yes
3.2	Depth of top of utility service from ground level	NA		Yes
3.3	Mechanism for crossing water channel	NA		Yes
3.4	Whether ROW is restricted in this stretch?	NA		Yes
3.4.1	If yes, whether provision of land acquisition is required to lay utility	NA		Yes
	(a) If yes, whether undertaking for land acquisition along with relevant L.A. details has been furnished	NA		Yes
3.4.2	Width of concrete duct, if utility services are proposed to be laid in concrete ducts	NA		Yes
4	Laying of utility services across the NH	YES, Overhead crossing		Yes
4.1	Whether Existing drainage structures is allowed to carry the utility lines.	NA		Yes
4.2	Proposed crossing of utility service	Overhead power line, perpendicular to NH		Yes
4.3	Type of casing pipe/conduit carrying the utility line.	Overhead AL-59 ZEBRA Conductor Crossing		Yes
4.4	Whether ends of the casing/conduit pipe are sealed from the outside	NA		Yes

SITE ENGINEER
NHAI, PIU,
Gwalior (M.P.)

प्रबंधक (सक.)
Manager (Tech.)
पु.का.सं. (PIU)-भा.रा.सं.भा. (NHAI)
गालियर (म.प्र.)

परियोजना प्रबंधक
PROJECT DIRECTOR
पु.का.सं. (PIU)-भा.रा.सं.भा. (NHAI)
गालियर (म.प्र.)

4.5	Length of casing/Transmission line crossing NH.	Crossing span length- 236.43m, line length over N.H. Boundary- 60 m. Row Of Transmission Line- 67m.		Yes
4.6	Depth of top of the casing/conduit pipe.	NA		
4.7	Crossing method in case of CC pavement.	NA		
4.8	Horizontal and vertical clearances in case utilities are allowed overhead,	23.88 M Vertical clearance Horizontal 93.88 m. & 119.94m. from outer edge of N.H		Yes
5	Document / Drawings enclosed with the proposal	Yes		Yes
5.1	Cross-Section showing the size of trench for open trenching method	NA		
	(a) Trench width	-		
	(b) Filling of trench	-		
	(c) location of trench	-		
5.2	Cross section showing the size of pit and location of conduit for HDD method	NA		
5.3	Strip plan/ Route plan showing utility line, chainage, width of ROW, distance of proposed utility from the edge of ROW, important mile stone, intersections, cross drainage works etc.	Profile Enclosed		Yes
5.4	Plan and profile drawing of stretch showing cross section of road at 20m distance along with ROW and proposed utility	Profile Enclosed		Yes
6	Methodology for laying of utility line	Enclosed	Enclosed	Yes
7	Draft License Agreement is as per Ministry guidelines vide letter No. RW/NH-34044/29/2015/S&R (R) dated 22.11.2016 and signed by two witnesses	Enclosed	Enclosed	Yes

SITE ENGINEER
NHAI, PIU,
GWALIOR

प्रमाणित (सि.प.)
Manager (Tech.)
प.का.ई. (PIU)-भारतवा. (NHAI)
गालियर (म.प्र.)

परियोजना निदेशक
PROJECT DIRECTOR
प.का.ई. (PIU)-भारतवा. (NHAI)
गालियर (म.प्र.)

BM

8	License fees in Favor of MoRTH	YES	As per Ministry vide circular no. RE/NH-33044/29/2015/S&(R)dated 22.11.2016	Yes
9	Whether Bank Guarantee has been obtained	YES	As per Ministry vide circular no. RE/NH-33044/29/2015/S&(R)dated 22.11.2016	
	(a) If yes, whether Confirmation of BG has been obtained as per MoRTH/NHAI guidelines	-		
10	Affidavit / Undertaking from the Applicant for			
10.1	Undertaking for not to damage other existing utility, if damaged then to pay the losses to either to MoRTH/NHAI or to the concerned agency.	Enclosed	Enclosed	
10.2	Undertaking for renewal of Bank Guarantees and when asked by NHAI/ MoRTH	Enclosed	Enclosed	
10.3	Undertaking for confirming all standard condition of MoRTH/NHAI guidelines.	Enclosed	Enclosed	
10.4	Undertaking for shifting of utility as and when asked by MoRTH/ NHAI within a month at their own cost.	Enclosed	Enclosed	
10.5	Undertaking for indemnity against all damages and claims.	Enclosed	Enclosed	
10.6	Undertaking for management of traffic movement during laying of utility line without hampering the traffic.	Enclosed	Enclosed	
10.7	Undertaking that If any claim is raised by the Concessionaire/contractor then the same has to be paid by the applicant	Enclosed	Enclosed	
10.8	Undertaking that the applicant has obtained various safety clearances from the representative authorities such as directorate of Electricity, Chief controller of Explosives, Petroleum and Explosive Safety Organization, Oil Industry Safety Directorate, State/Central Pollution Control Board and any other statutory clearances applicable, before applying to Highway Administration	Enclosed	Enclosed	

The Right of the Way(ROW) of the National Highway available at the proposed location from the center line of divided carriageway is (15) m (from center of ROW to edge of ROW towards proposed utility)

The above particulars along with the drawings and documents have been verified and certified as correct as per prevailing site conditions.

[Name Designation and signature of the authorized representative of applicant]

कुँवर क्षेमेन्द्र कुमार
मुख्य प्रबंधक (ट्रांसमिशन लाइन निर्माण)
पावरग्रिड घिरौर ट्रांसमिशन लिमिटेड
घिरौर, मैनपुरी (उ०प्र०)



[Name Designation and signature of concerned field authority of NHAI/PWD/BRO]

प्रबंधक (TECH.)
Manager (Tech.)
प.का.ई. (PIU)-भारत रा.प्र. (NHAI)
खालियर (म.प्र.)

SITE ENGINEER
NHAI, PIU,
GWALIOR (M.P.)

परियोजना निदेशक
PROJECT DIRECTOR
प.का.ई. (PIU)-भारत रा.प्र. (NHAI)
खालियर (म.प्र.)

CLIENT NAME: POWER GRID CORPORATION OF INDIA LIMITED																								
EXEC. AGENCY: BAJEL PROJECTS LIMITED																								
765KV DC DAUSA TOGHOR TRANSMISSION LINE Part III																								
CHECK SURVEY REPORT AP 134 TO AP 137																								
LENGTH = 0.907																								
AS PER CHECK SURVEY																								
SL NO	LOC NO	WZ	TYPE OF TOWER	RC	ANGLE OF DEVIATION	SPAN LENGTH (m)	SECTION LENGTH (m)	LOC. NO	WZ	TYPE OF TOWER	RC	ANGLE OF DEVIATION	SPAN LENGTH (m)	SECTION LENGTH (m)	CUMM. LENGTH (m)	WIND SPAN (m)	AD. SPAN (m)	CP1 COORDINATE UTM			CROSSINGS / REMARKS	VILLAGE NAME	TOWER HEIGHT (m)	
																		E	N	ELEV.				ZONE
8	AP 134	IV	DD60+3		0°47'06"LT	268.66	269	8	AP 134	IV	DD60+3	0°47'10"LT	269	2934	585.51	7920.071	25866247.54	163.9	43 R			DOUBLE TRACK ELECTRIFIED RAIL WAY CROSSING, 33KV LINE	BIRAI	73.72
9	AP 135	IV	DD60+0		28°24'31"RT	236.42	236	9	AP 135	IV	DD60+0	28°24'26"RT	236	3203	505.79	792216.16	25866288.96	163.84	43 R			NH 44 CROSSING 2NOS 1KV LINE, CATR TRACK, SISAM TREE	SAIVAN	70.72
10	AP 136	IV	DB1+0		0°40'24"LT	402	402	10	AP 136	IV	DB1+0	0°40'12"LT	402	3439	638.39	792568.47	25866209.89	163.88	43 R			CATR TRACK, SISAM TREE	SAIVAN	70.72
11	AP 137	IV	DB2+6		8°38'09"LT			11	AP 137	IV	DB2+6	8°38'21"LT		3841	801.46	792889.15	25866079.98	164.01	43 R				SAIVAN	76.72
TOTAL LENGTH IN KM 0.907															TOTAL LENGTH IN KM		0.907							

FOR BAJEL PROJECTS LTD.				FOR POWERGRID CORPORATION OF INDIA LTD.							
Bajel Projects Ltd.  ARINDAM SEN Asst. Manager (Survey)		 Abhishek Prasad		Bajel Projects Ltd.  APURBA PRAKASH Project Manager		 Kewar Kishore Kumar मुख्य प्रबंधक (दस्तावेज तैयारी निर्माण) पावरग्रिड सिस्टम इंजीनियरिंग लिमिटेड		 Kewar Kishore Kumar मुख्य प्रबंधक (दस्तावेज तैयारी निर्माण) पावरग्रिड सिस्टम इंजीनियरिंग लिमिटेड		प्रेम प्रकाश राय / Prem Prakash Rai परियोजना प्रभारी / Project In Charge पावरग्रिड सिस्टम इंजीनियरिंग लिमिटेड गजपति, गजपति, गजपति, गजपति (U.P.)	
SURVEYED BY		CHECKED BY		SUBMITTED BY		CHECKED BY		RECOMMENDED BY			



पावर ग्रिड कॉर्पोरेशन ऑफ इंडिया लिमिटेड
(पासा सरकार का चयन)
POWER GRID CORPORATION OF INDIA LIMITED
(A Government of India Enterprise)

संदर्भ/Ref : CC-ENGG-TB202314-1001973-T19731-842X64ZP 765KV WZ4 TSD

Date : 27/11/2024

From : Mani Shekhar
Senior DGM

To : M/S LARSEN And TOUBRO LIMITED
D, MANAPAKKAM, CHENNAI 600089
ECC DIVISION, MOUNT POONAMALLEE
Chennai-600089, Tamil Nadu

Cc : 0

Subject : 765kV D/C Bhadla-II PS-Sikar-II (2nd line)

LOA Ref : CC/T/W-TW/DOM/A02/23/01132/NOA-1/23-100339/01 Dated 20/03/2023

Please find enclosed following drawings/ documents for necessary action at your end.

Vendor Drg. No. : O22017-T-TL-0D-DC-0004

Orgn. Drg. No. : TB202314-1001973-T19731-842X64ZP 765KV WZ4 TSD

Revision No. : 05

Drg. Title : Tower Spotting Data for 765kV D/C (Hexa AL59 Zebra)-WZ-4

App. Category : CAT-I

Release Date : 27/11/2024



Scan to verify

Comments : OK

अनुमोदित श्रेणी/App. Category:

- I. फेब्रिकेशन/निर्माण/टाइप टेस्टिंग हेतु जारी।
Approved/released for fabrication/construction.
 - II. फेब्रिकेशन/निर्माण/टाइप टेस्टिंग हेतु अनुमोदित/जारी बशर्ते दिए गए टिप्पणियाँ एवं आशोधनों की सम्मिलित किया जाये। कृपया रिवाइज्ड दस्तावेज अनुमोदनार्थ प्रस्तुत करें।
Approved/released for fabrication/ construction subject to incorporation of comments and modification as noted. Revised drawing required for approval.
 - III. टिप्पणियाँ सम्मिलित करने के उपरांत दस्तावेज को अनुमोदनार्थ प्रस्तुत करें।
To be resubmitted for approval after incorporating the comments.
 - IV. सूचनार्थ एवं रिकार्ड हेतु।
For information and record.
- CATREL/ निर्माण हेतु जारी।
REL-CON Released for construction.

नोट/Note:

1. Approval/Comments conveyed herein neither relieve the contractor of his contractual obligations and his responsibilities, weights, quantities, design details assemble fits, performance particulars and conformity of the supplies with the Indian Statutory Laws as may be applicable, nor does it limits the purchaser's right under the contract.
2. The approval conveyed vide this letter does not cover the approval of make for sub-vendor items.

केन्द्रीय कार्यालय: "सौदामिनी", प्लॉट नंबर 2, सेक्टर-29, गुरुग्राम-122001, (हरियाणा), दूरभाष: 0124-2571700-719

Corporate Office: "Saudamini", Plot No. 2, Sector-29, Gurugram-122001, (Haryana) Tel.: 0124-2571700-719

पंजीकृत कार्यालय: बी-9, कृतुब इंस्टीट्यूशनल एरिया, कटवारिया सराय, नई दिल्ली-110016. दूरभाष: 011-26560112, 26560121, 26564812, 26564892, सीआईएन: L40101DL1989GOI038121

Registered Office: B-9, Qutab Institutional Area, Katwaria Sarai, New Delhi-110016. Tel: 011-26560112, 26560121, 26564812, 26564892, CIN : L40101DL1989GOI038121

Website: www.powergridindia.com

BAJEL PROJECTS LIMITED
THIS DOCUMENT/DRAWING IS ALSO TO BE USED FOR TL TRANSMISSION PACKAGE
TL03 FOR DAUSA - GHIROR 765 KV D/C LINE - PART-III ASSOCIATED WITH "TRANSMISSION
SYSTEM FOR EVACUATION OF POWER FROM RAJASTHAN REZ PH-IV (PART- 4: 3.5 GW):
PART A" THROUGH TARIFF BASED COMPETITIVE BIDDING (TBCB) ROUTE.
SPEC. NO.: CC/T/W-TW/DOM/A06/24/13269;
Ref. No.: CC/T/W-TW/DOM/A06/24/13269/ NOA-1/25-100948/01 DATED 23/01/2025

Handwritten signature for *Handwritten signature*

20.11.24	5	Revised as per Client's Comments received via Letter No. CC-ENGG-TB202314-1001973-T19731-842X64ZP 765KV WZ4 TSD Dated on 18.11.24	PAS	TRAMS	RJR
07.10.24	4	Revised to include the span details of DB2+12M, DC2+12M DD45+12, DD45+18/+25M and DD60/DE+12M extension	RV	TRAMS	RJR
05.02.24	3	Revised to include the span details of DD60/DE +30M/+35M & DB1+12M extension	RV	TRAMS	CSR
27.10.23	2	Revised as per Client's Comments received via Letter No CC-ENGG-TB202314-1001973-T19731-842X64ZP 765KV WZ4 TSD Dated on 26.10.23	RV	TRAMS	CSR
13.10.23	1	Revised to include the span details of DB1, DB2, DC2, DD60 tower Higher extensions	RV	TRAMS	CSR
28.03.23	0	First Submission for approval	CRV	TRAMS	CSR
DATE	REV.	DESCRIPTION	DESIGNED	CHECKED	APPROVED

REVISIONS



L&T CONSTRUCTION

POWER TRANSMISSION AND DISTRIBUTION IC

CLIENT :



BHADLA SIKAR TRANSMISSION LIMITED
[A 100% WHOLLY OWNED SUBSIDIARY OF POWERGRID]

PROJECT :

765KV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route)
TW01 -Part-I (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW01/G3/R
TW02 -Part-II (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW02/G3/R
TW03 -Part-III (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW03/G3/R

JOB No. O22017-T-TL

TOTAL NO. OF PAGES	19	TITLE :
NAME	DATE	TOWER SPOTTING DATA FOR 765KV D/C (HEXA AL59 ZEBRA - WZ-4)
DSGN	CRV	
CHKD	TRAMS	
APPD	CSR	

DOC. No.	0 2 2 0 1 7 - T - T L - 0 D - D C - 0 0 0 4	CODE	REV.
		IS	5

RELEASED FOR

☐ PRELIMINARY☐ TENDER☐ INFORMATION☒ APPROVALCONSTRUCTION ☐

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC											
PROJECT :		765KV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route)					DCC NO: O22017-T-TL-0D-0004		20.11.24		
TITLE :		TOWER SPOTTING DATA FOR 765KV D/C UPTO +9M (HEXA AL69 ZEBRA - WZ-4)					Prepared PAS		Checked TRAMS		
TOWER SPOTTING REQUIREMENTS		TOWER SPOTTING DATA FOR -3m, -1.5m, +0m, +1.5m, +3m, +4.5m, +6m, +7.5m & +9m BE NORMAL SPAN = 400 MTRS ALL SPANS ARE IN MTRS ALL LOADS ARE IN KGS									
Sl No	DESCRIPTION	TOWER TYPES									
		DA- SUSPENSION (0° - 2°)	DB1-TENSION (0° - 7°)	DB2-TENSION (7° - 15°)	DC1-TENSION (15° - 22°)	DC2-TENSION (22° - 30°)					
1	WEIGHT SPAN LIMITATIONS :										
	a) MAXIMUM WEIGHT SPAN (M) :										
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	600	600	600	600	600				
		BWG, EFFECT OF ONE SPAN	360	360	360	360	360				
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	600	600	600	600	600				
		BWG, EFFECT OF ONE SPAN	360	360	360	360	360				
	b) MINIMUM WEIGHT SPAN (M) :										
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	200	0	0	0	0				
		BWG, EFFECT OF ONE SPAN	100	-200	-200	-200	-200				
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	200	0	0	0	0				
		BWG, EFFECT OF ONE SPAN	100	-200	-200	-200	-200				
Sl No	DESCRIPTION	TOWER TYPES									
		DA- SUSPENSION (0° - 2°)	DB1-TENSION (0° - 7°)	DB2-TENSION (7° - 15°)	DC1-TENSION (15° - 22°)	DC2-TENSION (22° - 30°)					
		2	800	7	800	15	800	22	800	30	800
		1	821	6	845	14	845	21	844	29	844
		0	841	5	860	13	860	20	869	28	867
				4	935	12	934	19	933	27	931
				3	980	11	979	18	978	26	975
				2	1025	10	1024	17	1022	25	1019
				1	1070	9	1059	16	1067	24	1063
						8	1114	15	1112	23	1107
				0	1115	7 & BELOW	1159	14 & BELOW	1156	22	1152
										21 & BELOW	1196
2	PERMISSIBLE SUM OF ADJACENT SPANS FOR VARIOUS DEVIATION ANGLES (SUBJECT TO AVAILABILITY OF MINIMUM SPECIFIED GROUND CLEARANCES AND WEIGHT SPAN LIMITATION AT SL.NO 1). PERMISSIBLE ONE SPAN FOR VARIOUS DEVIATION ANGLES FOR TOWERS SHOULD NOT EXCEED 80% OF THE VALUE SHOWN FOR SUM OF ADJACENT SPANS. THE MENTIONED SPAN VALUES ARE APPLICABLE TO CONDUCTOR, EARTHWIRE AND OPGW. CONDUCTOR/EARTHWIRE/OPGW HAS BEEN CONSIDERED WHICHEVER GIVES LESSER OF THE SUM OF THE ADJACENT SPANS.										

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC					
PROJECT : 765kV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route)		DOC NO: 022017-T-TL-9D-DC-0004		20.11.24	
TITLE : TOWER SPOTTING DATA FOR 765KV D/C UPTO +9M (HEXA AL59 ZEBRA - WZ-4)		Prepared PAS		Checked TRAMS	
				SHEET	
		TOWER TYPES			
Sl No	DESCRIPTION	DD45 - TENSION (30° - 45°)	DD60 - TENSION (45° - 60°)	DD60-COMplete DEAD END 0° DEVIATION - (ONE SIDE)	DD60-DEAD END [0° TO 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE]
3	WEIGHT SPAN LIMITATIONS :				
	a) MAXIMUM WEIGHT SPAN (M) :				
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	600 360	000 300	300 80
	CONDUCTOR	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	600 360	600 300	300 80
	b) MINIMUM WEIGHT SPAN (M) :				
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	0 -300	0 -300	0 0
	CONDUCTOR	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	0 -300	0 -300	0 -300
		TOWER TYPES			
Sl No	DESCRIPTION	DD45 - TENSION (30° - 45°)	DD60-TENSION (45° - 60°)		
4	PERMISSIBLE SUM OF ADJACENT SPANS FOR VARIOUS DEVIATION ANGLES (SUBJECT TO AVAILABILITY OF MINIMUM SPECIFIED GROUND CLEARANCES AND WEIGHT SPAN LIMITATION AT SL NO 1).	45 44 43	800 842 884	60 59 58	800 838 879
	PERMISSIBLE ONE SPAN FOR VARIOUS DEVIATION ANGLES FOR TOWERS SHOULD NOT EXCEED 60% OF THE VALUE SHOWN FOR SUM OF ADJACENT SPANS.	42 41 40	926 968 1010	57 56 55	918 958 998
	THE MENTIONED SPAN VALUES ARE APPLICABLE TO CONDUCTOR, EARTHWIRE AND OPGW.	39 38 37	1053 1095 1138	54 53 52	1038 1078 1119
	CONDUCTOR/EARTHWIRE/OPGW HAS BEEN CONSIDERED WHICHEVER GIVES LESSER OF THE SUM OF THE ADJACENT SPANS.	35 & BELOW	1181	51	1159
			50 & BELOW		1200

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC																									
PROJECT :		765KV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCS route)					DOC NO: O22017-T-TL-0D-DC-0004		20.11.24																
TITLE :		TOWER SPOTTING DATA FOR 765KV D/C UPTO +9M (HEXA AL59 ZEBRA - WZ-4)					Prepared PAS		Checked TRAMS																
									SHEET																
SI No	DESCRIPTION	TOWER TYPES																							
		DA - SUSPENSION (0° - 2°)	DB1-TENSION (0° - 7°)	DB2-TENSION (7° - 15°)	DC1-TENSION (15° - 22°)	DC2-TENSION (22° - 30°)	DD45-TENSION (30° - 45°)	DD60-TENSION (45° - 60°)	DD60 - DEAD END 1) COMPLETE DEAD END(ONE SIDE) 2) 0° - 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION(BLACK) SIDE																
5 DESIGN WIRE TENSIONS (KG)																									
	GROUND WIRE : GSW	32°C & FULL WIND/32°C & 75% WIND		4115.3/3390.8																					
		32°C & NIL WIND		124 / 1																					
	OPGW	32°C & FULL WIND/32°C & 75% WIND		3793/3135.3																					
		32°C & NIL WIND		983.0																					
	CONDUCTOR :	32°C & FULL WIND/32°C & 75% WIND		BOTTOM CONDUCTOR - 7114.1 / 5823.8 MIDDLE CONDUCTOR - 7448.2 / 6097.4 TOP CONDUCTOR - 7701.4 / 6300.9																					
		32°C & NIL WIND		2422.9																					
SI No	DESCRIPTION	TOWER TYPES																							
		DA	DB1/DB2	DC1/DC2	DD45/DD60	DD60 - COMPLETE DEAD END (0° DEVIATION) - ONE SIDE	DD60-DEAD END (0° TO 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (BLACK) SIDE)																		
6	DESIGN WIND SPAN (M)	400	400	400	400	200	300																		
	NORMAL CONDITION (INTACT WIRE)	240	240	240	240	40	220																		
GENERAL NOTES :																									
1. All spans are in meter. 2. Maximum conductor temperature is 85°C for AL59 Zebra. 3. Maximum sum of adjacent spans for various angle of deviations are permitted subject to the condition that minimum live metal clearance and minimum ground clearance are available. 4. The clearances from buildings, trees, powerline crossings should be made in conforming with the CEA's Regulation 2023 (Measures Relating to Safety & Electric Supply). 5. DD45 tower is not designed for dead end condition and shall not be used for 400kV and above voltage level power line crossings and Railway crossings. DD60 tower has been designed for dead end condition which shall be used for such crossings. 6. ROAD CROSSING (i) At all road crossings, except National Highways the towers shall be fitted with normal suspension and tension insulator strings depending on the type of tower. However for all National Highway crossings tension type towers with tension insulator strings shall be used. (ii) Ground clearance at the roads under maximum temperature and in still air shall be such that even with conductor broken in adjacent span, ground clearance of the conductor from the road surfaces will not be less than the specified minimum ground clearances. (iii) At all national and state highways, Tension tower type with tension insulator strings shall be used and crossing span will not be more than 250 meters, unless higher span is permitted by national highways authority in case of highways having more lanes. (iv) Minimum ground clearance for national highway crossing shall be 18.8m. 7. MINIMUM CLEARANCE FOR POWER LINE CROSSING <table border="1"> <thead> <tr> <th>KV</th> <th>66KV</th> <th>132KV</th> <th>220KV</th> <th>400KV</th> <th>765KV</th> <th>500KV HVDC</th> <th>800KV HVDC</th> <th>1200KV</th> </tr> </thead> <tbody> <tr> <td>CLEARANCE(m)</td> <td>7.94</td> <td>7.94</td> <td>7.94</td> <td>7.94</td> <td>7.94</td> <td>7.94</td> <td>9.04</td> <td>10.44</td> </tr> </tbody> </table> (i) For Power line crossing of 400kV or above voltage level, large angle & dead end towers (i.e DD60) shall be used on either side of power line crossing (i.e DD-DD arrangement). (ii) The crossing of 220kV and 132kV lines shall be done using angle towers, depending upon the merit of the prevailing site condition and line deviation requirement.								KV	66KV	132KV	220KV	400KV	765KV	500KV HVDC	800KV HVDC	1200KV	CLEARANCE(m)	7.94	7.94	7.94	7.94	7.94	7.94	9.04	10.44
KV	66KV	132KV	220KV	400KV	765KV	500KV HVDC	800KV HVDC	1200KV																	
CLEARANCE(m)	7.94	7.94	7.94	7.94	7.94	7.94	9.04	10.44																	

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC				
PROJECT :	765kV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route)		DCC NO: O22017-T-TL-2D-DC-0004	20.11.24
TITLE :	TOWER SPOTTING DATA FOR 765KV D/C UPTO +9M (HEXA AL50 ZEBRA - WZ-4)		Prepared PAS	Checked TRAMS
SHEET				
(iii) Crossing of 66KV lines & below shall be done using suspension/tension towers, depending upon the merit of the prevailing site condition and line deviation requirement. (iv) In case of crossing with angle towers proper guying shall be provided to facilitate stringing of the power line crossing sections separately on obtaining line shutdown. (v) Minimum Ground Clearance from Power Conductor is 18m. 8. Electrical clearance for Rail way crossings (i) Prior approval of Railway Authority is to be obtained. (ii) Minimum clearance between lowest point of 765KV line conductor & above rail level shall be as per the following a) Vertical clearance for OHE other than high rise OHE - 21.86m (Above 500KV and upto 600KV). b) Vertical clearance for OHE high rise OHE - 23.86m (Above 500KV and upto 800KV). * - Applicable only for electrification of routes where double stack container having maximum height of 6809mm is plying (iii) For Electrified railways or railway proposed to be electrified, the clearance between the highest traction conductor and the crossing 765KV conductor shall not be less than 7.84m under maximum sag condition (Above 500KV and upto 800KV). (iv) The crossing span shall be limited to 300m or 80% of normal span for which the structure is designed, whichever is less. (v) The crossing shall normally be at right angle to the railway track. (vi) Crossing should be done with DD60 type tower on either side. However, approval of railway crossing from railway authority has to be obtained in each case. (vii) The minimum horizontal distance measured at right angles from the centre of nearest track to any part of the structure (all structures shall be rigid & well founded) carrying electrical conductors crossing a railways shall be equal to the height of the structure in meters above normal ground level plus 6 meters. (viii) No Crossing shall be located over a booster transformer, traction switching station, traction sub station, overlap section or a track cabin location in an electrified area. (ix) Notwithstanding the above, Minimum clearance for crossings as per Indian Railways Schedule of Dimensions (BG) Revised 2004 as amended from time to time. 9. RIVER CROSSING (i) In case of major river crossing, river crossing towers shall be of suspension type along with anchor towers of DD60 type tower on either side of the main river (ii) For navigable rivers, clearance required by navigation authority shall be provided. For non-navigable river, clearance shall be reckoned with respect to highest flood level (HFL). Minimum Ground Clearance from Power Conductor is 18m. (iii) For river crossing anchoring with longer wind span : 0 deg. deviation on crossing span side and 0deg to 30deg. deviation on other side. 10. TELECOMMUNICATION LINE CROSSING (i) The angle of crossing shall be as near to 90 deg as possible. However deviation of the extent of 30deg may be permitted under exceptionally difficult situation. (ii) For a crossing angle below 60deg, matter shall be referred the matter will be referred to the authority in charge of the telecommunication system. On a request from the contractor the permission of the telecommunication authority may be obtained by the Owner. (iii) In the crossing span, power line support will be as near the telecommunication line as possible, to obtain increased vertical clearance between the wires. 11 OIL PIPE LINE CROSSING (i) Wherever transmission line crosses an oil/gas pipeline, the angle of crossing shall be as near to 90 degree possible. (ii) Minimum separation of 25m should be maintained between pipe line and transmission line footings & pipe/counterpoise earthing. (iii) Wherever overhead line of voltage 33 kV or above or high voltage direct current intending to cross the right of way of a Petroleum or Natural Gas pipeline, the angle of crossing of crossing of the overhead line with respect to the pipelines shall preferably be at right angles and, in any case, the crossing angle shall not be less than seventy five degrees. 12. The number of consecutive spans between the section points shall not exceed 15 spans or 5KM in plain terrain and 10 spans or 3KM in hilly terrain. A section point shall comprise of tension point with DB and DC Type tower as applicable. 13. Tower type DB ^{DC} shall be used for transposition tower with modification of cross arm. 14. Way leave clearance 33.5m either side from the CL of the tower. 15. Vertical Loads of Individual Spans are acting downwards for suspension towers. 16. Tower Spotting shall be done by PLS-CADD using automatic sagging method. 17. Minimum ground clearance required 16000mm. 18. Maximum deviation of line for Dead End tower shall be 15 deg both side i.e line side & sub station side (slack span side)				

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC																
PROJECT :		765kV D/C Bhadia-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route) TW01 -Part-I (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW01/G3/R) TW02 -Part-II (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW02/G3/R) TW03 -Part-III (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW03/G3/R)								DOC NO: O22017-T-TL-0D-DC-0004		20.11.24				
TITLE :		TOWER SPOTTING DATA FOR 765KV D/C FOR DB2+15M, DB1/DB2+18/+25M, DC2+15M, DC2+18/+25M & DD60/DE+18/25M (HEXA AL59 ZEBRA - WZ-4)								Prepared PAS		Checked TRAMS				
		Normal span = 325m (for DB2+15m/DC2+15m) , Normal span = 300m (for DB1/DB2+18/+25m, DC2+18/+25M & DD60+18m/+25m) ALL SPANS ARE IN MTRS ALL LOADS ARE IN KGS														
SI No		TOWER SPOTTING REQUIREMENTS	TOWER TYPES													
			DB1 (0° - 7°) +18/+25M BE-TENSION		DB2 (0° - 13°) +15M BE-TENSION		DB2 (0° - 13°) +18M/+25M BE-TENSION		DC2 (15° - 28°) +15M BE-TENSION		DC2 (15° - 28°) +18/+25M BE-TENSION		DD60 (30° - 55°) +18/+25M BE-TENSION			
1	1	WEIGHT SPAN LIMITATIONS :														
		a) MAXIMUM WEIGHT SPAN (M) :														
		GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	600	600	600	600	600	600	600	600	600	600			
			BWC, EFFECT OF ONE SPAN	360	360	360	360	360	360	360	360	360	360			
		CONDUCTOR	NC, EFFECT OF BOTH SPANS	600	600	600	600	600	600	600	600	600	600			
			BWC, EFFECT OF ONE SPAN	360	360	360	360	360	360	360	360	360	360			
		b) MINIMUM WEIGHT SPAN (M) :														
		GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	0	0	0	0	0	0	0	0	0	0			
			BWC, EFFECT OF ONE SPAN	-200	-200	-200	-200	-200	-200	-200	-200	-200	-300			
		CONDUCTOR	NC, EFFECT OF BOTH SPANS	0	0	0	0	0	0	0	0	0	0			
			BWC, EFFECT OF ONE SPAN	-200	-200	-200	-200	-200	-200	-200	-200	-200	-300			
2		DESCRIPTION	TOWER TYPES													
			DB1 (0° - 7°) +18/+25M BE-TENSION		DB2 (0° - 13°) +15M BE-TENSION		DB2 (0° - 13°) +18M/+25M BE-TENSION		DC2 (15° - 28°) +15M BE-TENSION		DC2 (15° - 28°) +18/+25M BE-TENSION		DD60 (30° - 55°) +18/+25M BE-TENSION			
2		PERMISSIBLE SUM OF ADJACENT SPANS FOR VARIOUS DEVIATION ANGLES (SUBJECT TO AVAILABILITY OF MINIMUM SPECIFIED GROUND CLEARANCES AND WEIGHT SPAN LIMITATION AT SLNO 1). PERMISSIBLE ONE SPAN FOR VARIOUS DEVIATION ANGLES FOR TOWERS SHOULD NOT EXCEED 80% OF THE VALUE SHOWN FOR SUM OF ADJACENT SPANS.	7	600	13	650	13	600	28	650	28	600	55	600		
			6	642	12	692	12	642	27	692	27	641	54	635		
			5	683	11	735	11	683	26	733	26	681	53	675		
			4	725	10	778	10	725	25	775	25	722	52	712		
			3	767	9	820	9	766	24	817	24	763	51	750		
			2	809	8	863	8	808	23	859	23	804	50	787		
			1	851	7	905	7	850	22	901	22	845	49	825		
									21	944	21	886	48	864		
													47	902		
									15	492	30	548	30	501	46	940
									14	546	29	599	29	551	45	979
													60	377		
													59	421		
										58	466					
										57	511					
										56	556					

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC										
PROJECT :		765kV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route) TW01 -Part-I (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW01/G3/R) TW02 -Part-II (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW02/G3/R) TW03 -Part-III (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW03/G3/R)					DOC NO: 022017-TL-0D-DC-0004		20.11.24	
TITLE :		TOWER SPOTTING DATA FOR 765KV D/C FOR DB2+15M, DB1/DB2+18/+25M, DC2+15M, DC2+18/+25M & DD60/DE+18/25M (HEXA AL59 ZEBRA - WZ-4)					Prepared PAS		Checked TRAMS	
Sl No	DESCRIPTION		TOWER TYPES							
			DD60+18/+25M - COMPLETE DEAD END (0° DEVIATION) - ONE SIDE	DD60+18/+25M-DEAD END WITH 0° TO 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE						
1	WEIGHT SPAN LIMITATIONS :									
	a) MAXIMUM WEIGHT SPAN (M) :									
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	300	450						
		BWC, EFFECT OF ONE SPAN	60	330						
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	300	450						
		BWC, EFFECT OF ONE SPAN	60	330						
	b) MINIMUM WEIGHT SPAN (M) :									
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	0	0						
		BWC, EFFECT OF ONE SPAN	300	-300						
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	0	0						
		BWC, EFFECT OF ONE SPAN	-300	-300						
Sl No	3	DESCRIPTION		TOWER TYPES						
				DB1 (0° - 7°) / DB2 (0° - 11°) +18/+25M -BE	DB2+15M BE (0° - 14°)	DC2 (15° - 28°) +15M BE - TENSION	DC2 (15° - 28°) +18/+25M BE - TENSION	DD60 (30° - 55°) +18/+25M BE - TENSION	DD60+18/+25M - COMPLETE DEAD END (0° DEVIATION) - ONE SIDE	DD60+18/+25M-DEAD END WITH 0° TO 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE
3	DESIGN WIND SPAN (M)	NORMAL CONDITION (INTACT WIRE)	300	325	325	300	300	150	225	
		BROKEN WIRE	180	195	195	180	180	30	165	

L&T CONSTRUCTION

POWER TRANSMISSION AND DISTRIBUTION IC

PROJECT :

765kV D/C Bhadia-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route)
TW01 -Part-I (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW01/G3/R
TW02 -Part-II (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW02/G3/R
TW03 -Part-III (Specification No: TBCB/765kV/RAJ-PHASE-II-PART-E/TW03/G3/R

DOC NO:
022017-TL-0D-DC-0004

20.11.24

TITLE :

TOWER SPOTTING DATA FOR 765kV D/C FOR DB2+15M, DB1/DB2+18/+25M, DC2+15M, DC2+18/+25M & DD60/DE+18/25M (HEXA AL59 ZEBRA - WZ-4)

Prepared

Checked

PAS

TRAMS

SI No	4	DESCRIPTION	TOWER TYPES							
			DB1(0° - 7°) / DB2 (0° - 13°) +18/+25M -BE	DB2+15M BE (0° - 13°)	DC2 (15° - 28°) +15M BE - TENSION	DC2 (15° - 28°) +18/+25M BE - TENSION	DD60 (30° - 55°) +18/+25M BE - TENSION	DD60+18/25M - DEAD END 1) COMPLETE DEAD END(ONE SIDE) 2) 0° - 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION(SLACK) SIDE		
4		DESIGN WIRE TENSION (KG)								
		GROUND WIRE : GSW	32°C & FULL WIND/32°C & 75% WIND	4115.3/3390.8						
			32°C & NIL WIND	1247.7						
	OPGW		32°C & FULL WIND/32°C & 75% WIND	3778.3/3120.7						
			32°C & NIL WIND	983.0						
	CONDUCTOR :		32°C & FULL WIND/32°C & 75% WIND	BOTTOM CONDUCTOR - 7114.1 / 5829.8 MIDDLE CONDUCTOR - 7448.2 / 6097.4 TOP CONDUCTOR - 7701.4 / 6300.9						
			32°C & NIL WIND	2422.9						
SI No	5	DESCRIPTION	TOWER TYPES							
			DB1(0° - 7°) / DB2 (0° - 13°) +18/+25M -BE	DB2+15M BE (0° - 13°)	DC2 (15° - 28°) +15M BE - TENSION	DC2 (15° - 28°) +18/+25M BE - TENSION	DD60 (30° - 55°) +18/+25M BE - TENSION	DD60+18/25M - DEAD END 1) COMPLETE DEAD END(ONE SIDE) 2) 0° - 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION(SLACK) SIDE		
5		DESIGN WIND PRESSURE (KG/M2)								
		GROUND WIRE : GSW	32°C & FULL WIND/32°C & 75% WIND	284/212	276/207	276/207	284/213	284/213	284/210	
			32°C & FULL WIND/32°C & 75% WIND	284/213	276/207	276/207	284/213	284/213	284/213	
	CONDUCTOR :		32°C & FULL WIND/32°C & 75% WIND	TC-232/174 MC-225/168.75 BC-216/162	TC-226/169.5 MC-219/164.25 BC-206/154.5	TC-226/169.5 MC-219/164.25 BC-206/154.5	TC-232/174 MC-225/168.75 BC-216/162	TC-232/174 MC-225/168.75 BC-216/162	TC-232/174 MC-225/168.75 BC-216/162	

 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC						
PROJECT :	765kV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route) TW01 -Part-I (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW01/G3/R TW02 -Part-II (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW02/G3/R TW03 -Part-III (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW03/G3/R		DOC NO: 022017-T-TL-0D-DC-0004	20.11.24		
TITLE :	TOWER SPOTTING DATA FOR 765KV D/C (FOR DB1/+12M, DD60/DE+30/+35M) (HEXA AL59 ZEBRA - WZ-4)		Prepared	Checked		
			PAS	TRAMS		
TOWER SPOTTING REQUIREMENTS		Normal span = 325m(for DB1+12m) Normal span = 250m(for DD60+30m/+35m) ALL SPANS ARE IN MTRS ALL LOADS ARE IN KGS				
SI No	DESCRIPTION	TOWER TYPES				
		DB1 (0° - 7°) +12M BE-TENSION	DD60 (45°- 50°) +30/35M BE-TENSION	DD60+30/+35M - COMPLETE DEAD END (0°DEVIATION) - ONE SIDE	DD60+30/+35M - DEAD END WITH 0° TO 10° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE	
1	WEIGHT SPAN LIMITATIONS :					
	a) MAXIMUM WEIGHT SPAN (M) :					
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	600	600	300	450
		BWC, EFFECT OF ONE SPAN	360	360	60	330
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	600	600	300	450
		BWC, EFFECT OF ONE SPAN	360	360	60	330
	b) MINIMUM WEIGHT SPAN (M) :					
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS	0	0	0	0
		BWC, EFFECT OF ONE SPAN	-200	-300	-300	-300
	CONDUCTOR	NC, EFFECT OF BOTH SPANS	0	0	0	0
		BWC, EFFECT OF ONE SPAN	-200	-300	-300	-300
	DESCRIPTION	TOWER TYPES				
		DB1 (0° - 7°) +12M BE-TENSION	DD60 (45°- 50°) +30/35M BE-TENSION			
2	PERMISSIBLE SUM OF ADJACENT SPANS FOR VARIOUS DEVIATION ANGLES (SUBJECT TO AVAILABILITY OF MINIMUM SPECIFIED GROUND CLEARANCES AND WEIGHT SPAN LIMITATION AT SLNO 1). PERMISSIBLE ONE SPAN FOR VARIOUS DEVIATION ANGLES FOR TOWERS SHOULD NOT EXCEED 60% OF THE VALUE SHOWN FOR SUM OF ADJACENT SPANS.	7	650	50	500	
		6	689	49	533	
		5	728	48	566	
		4	767	47	599	
		3	806	46	632	
		2	845	45	666	
		1	884			
		0	923			



✓ 5/6

SI No	DESCRIPTION		TOWER TYPES			
			DB1 (0° - 7°) +12M BE-TENSION	DD60 (45°- 50°) +30/35M BE-TENSION	DD60+30/+35M - COMPLETE DEAD END (0°DEVIATION) - ONE SIDE	DD60+30/+35M- DEAD END WITH 0° TO 10° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE
3	DESIGN WIND SPAN (M)	NORMAL CONDITION (INTACT WIRE)	325	250	125	187.5
		BROKEN WIRE	195	150	25	137.5
SI No	DESCRIPTION		TOWER TYPES			
			DB1 (0° - 7°) +12M BE-TENSION	DD60 (45°- 50°) +30/35M BE-TENSION	DD60+30/+35M - COMPLETE DEAD END (0°DEVIATION) - ONE SIDE	DD60+30/+35M- DEAD END WITH 0° TO 10° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE
4	DESIGN WIRE TENSIONS (KG)					
	GROUND WIRE : GSW	32°C & FULL WIND/32°C & 75% WIND	4115.3/3390.8			
		32°C & NIL WIND	1247.7			
	OPGW	32°C & FULL WIND/32°C & 75% WIND	3778.3/3120.7			
		32°C & NIL WIND	963.0			
	CONDUCTOR :	32°C & FULL WIND/32°C & 75% WIND	BOTTOM CONDUCTOR - 7114.1 / 5829.8 // MIDDLE CONDUCTOR - 7448.2 / 6097.4 // TOP CONDUCTOR - 7701.4 / 6300.9			
		32°C & NIL WIND	2422.9			
SI No	DESCRIPTION		TOWER TYPES			
			DB1 (0° - 7°) +12M BE-TENSION	DD60 (45°- 50°) +30/35M BE-TENSION	DD60+30/35M - DEAD END 1) COMPLETE DEAD END(ONE SIDE) 2) 0° - 10° DEVIATION ON BOTH LINE SIDE AND SUB STATION(SLACK) SIDE	
5	DESIGN WIND PRESSURE (KG/M2)					
	GROUND WIRE : GSW	32°C & FULL WIND/32°C & 75% WIND	277/208	299/225.25	299/225.25	
		32°C & FULL WIND/32°C & 75% WIND	277/208	299/225.25	299/225.25	
	CONDUCTOR :	32°C & FULL WIND/32°C & 75% WIND	TC-226/170 MC-219/163.5 BC-205/153.75	TC-244/183 MC-236/177 BC-228/171	TC-244/183 MC-236/177 BC-228/171	

NOTE : For the dead condition +30/+35m Extn of DD60/DE tower the maximum angle of deviation is considered as 10 deg on line side as well as slack side


 L&T CONSTRUCTION POWER TRANSMISSION AND DISTRIBUTION IC											
PROJECT :		765KV D/C Bhadla-II PS - Sikar-II 2nd Transmission line associated with "Transmission scheme for evacuation of power from solar energy zones in Rajasthan (8.1 GW) under Phase II - Part-E through tariff based competitive bidding (TBCB route) TW01 -Part-I (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW01/G3/R) TW02 -Part-II (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW02/G3/R) TW03 -Part-III (Specification No: TBCB/765KV/RAJ-PHASE-II-PART-E/TW03/G3/R)						DOC NO: O22017-T-TL-00-DC-0004		20.11.24	
TITLE :		TOWER SPOTTING DATA FOR 765KV D/C (FOR DB2+12M, DC2+12M, DD45+12M, DD45+18/+25 AND DD60/DE+12M) (HEXA AL59 ZEBRA - WZ-4)						Prepared PAS		Checked TRAMS	
TOWER SPOTTING REQUIREMENTS		Normal span = 325m (for DB2+12m, DC2+12m, DD45+12m and DD60/DE+12m BE) Normal span = 300m (for DD45+18/+25)									
		ALL SPANS ARE IN MTRS ALL LOADS ARE IN KGS									
		TOWER TYPES									
Sl No	DESCRIPTION	DB2 (0° - 13°) +12M BE-TENSION	DC2 (15° - 28°) +12M BE-TENSION	DD45 (30° - 43°) +12M BE-TENSION	DDD45 (30° - 43°) +18M/+25M BE-TENSION	DD60 (30° - 55°) +12M BE-TENSION	DD60+12M BE - COMPLETE DEAD END(0°DEVIATION) - ONE SIDE	DD60+12M-DEAD END WITH 0° TO 15° DEVIATION ON BOTH LINE SIDE AND SUB-STATION (SLACK) SIDE			
1	WEIGHT SPAN LIMITATIONS :										
	a) MAXIMUM WEIGHT SPAN (M) :										
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	600 360	600 360	600 360	600 360	300 60	450 330			
	CONDUCTOR	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	600 360	600 360	600 360	600 360	300 60	450 330			
	b) MINIMUM WEIGHT SPAN (M) :										
	GROUND WIRE/OPGW	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	0 -200	0 -300	0 -300	0 -300	0 -300	0 -300			
	CONDUCTOR	NC, EFFECT OF BOTH SPANS BWC, EFFECT OF ONE SPAN	0 -200	0 -300	0 -300	0 -300	0 -300	0 -300			
	DESCRIPTION	TOWER TYPES									
		DB2 (0° - 13°) +12M BE-TENSION	DC2 (15° - 28°) +12M BE-TENSION	DD45 (30° - 43°) +12M BE-TENSION	DDD45 (30° - 43°) +18M/+25M BE-TENSION	DD60 (30° - 55°) +12M BE-TENSION					
2	PERMISSIBLE SUM OF ADJACENT SPANS FOR VARIOUS DEVIATION ANGLES (SUBJECT TO AVAILABILITY OF MINIMUM SPECIFIED GROUND CLEARANCES AND WEIGHT SPAN LIMITATION AT SLNO 1). PERMISSIBLE ONE SPAN FOR VARIOUS DEVIATION ANGLES FOR TOWERS SHOULD NOT EXCEED 60% OF THE VALUE SHOWN FOR SUM OF ADJACENT SPANS.	13	650	28	650	43	650	43	600	55	650
12		693	27	692	42	690	42	639	54	688	
11		735	26	733	41	730	41	678	53	726	
10		778	25	775	40	770	40	717	52	765	
9		821	24	817	39	811	39	757	51	804	
8		864	23	859	38	851	38	796	50	842	
7		907	22	901	37	892	37	836	49	881	
					36	933	36	875	48	921	
					35	974	35	915	47	960	
					34	1015	34	955	46	999	
					33	1056	33	995	45	1039	
					32	1097	32	1035			
					31	1138	31	1075			
					30	1180	30	1116			
15		540	30	549	45	554	45	506	60	421	
14		596	29	600	44	603	44	554	59	467	
									58	513	
									57	559	
									56	605	



POWER TRANSMISSION AND DISTRIBUTION IC

Scoring for 187 General Learning Index and 188

THIS IS PROPRIETARY ITEM AND DESIGN RIGHT IS STRICTLY RESERVED WITH POWERGRID. UNDER NO CIRCUMSTANCES
THIS DRAWING SHALL BE USED BY ANYBODY WITHOUT PRIOR PERMISSION FROM POWERGRID IN WRITING.



KEY SKETCH OF BODY EXTENSIONS FOR 765KV D/C WZ-4-DA TOWER



-3.0/-1.5/+0/+1.5/+3.0M BODY EXTNS AT BASIC BODY LEVEL.

+4.5/+6.0/+7.5/+9.0M BODY EXTNS AT NORMAL TOWER LEVEL.


13/28

NO.	1	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	2	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	3	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	4	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	5	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	6	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	7	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	8	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	9	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	10	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	11	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	12	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	13	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	14	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	15	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	16	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	17	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	18	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	19	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	20	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	21	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	22	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	23	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	24	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	25	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	26	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	27	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	28	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	29	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	30	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	31	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	32	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	33	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	34	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	35	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	36	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	37	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	38	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	39	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	40	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	41	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	42	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	43	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	44	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	45	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	46	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	47	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	48	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	49	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	50	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	51	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	52	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	53	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	54	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	55	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	56	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	57	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	58	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	59	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	60	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	61	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	62	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	63	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	64	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	65	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	66	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	67	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	68	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	69	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	70	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	71	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	72	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	73	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	74	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	75	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	76	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	77	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	78	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	79	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	80	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	81	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	82	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	83	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	84	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	85	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	86	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	87	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	88	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	89	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	90	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	91	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	92	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	93	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	94	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	95	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	96	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	97	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	98	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	99	REVISION	DATE	BY	CHKD	APPRD	REMARKS
NO.	100	REVISION	DATE	BY	CHKD	APPRD	REMARKS

THIS IS PROPRIETARY ITEM AND DESIGN RIGHT IS STRICTLY RESERVED WITH POWERGRID. UNDER NO CIRCUMSTANCES THIS DRAWING SHALL BE USED BY ANYBODY WITHOUT PRIOR PERMISSION FROM POWERGRID IN WRITING.



+25M BE ATTACHED TO NORMAL TOWER LEVEL



NOTES:
1. T.L.S. REFERRED TO TOWER INSULATOR STRING
2. ALL DIMENSIONS ARE IN MM. UNLESS OTHERWISE SPECIFIED.

SL. NO.	REVISION	DATE	BY	CHKD.	APPD.
01	As per design	20.03.2025	...	...	...
02	As per design	20.03.2025	...	...	...
03	As per design	20.03.2025	...	...	...
04	As per design	20.03.2025	...	...	...
05	As per design	20.03.2025	...	...	...
06	As per design	20.03.2025	...	...	...
07	As per design	20.03.2025	...	...	...
08	As per design	20.03.2025	...	...	...
09	As per design	20.03.2025	...	...	...
10	As per design	20.03.2025	...	...	...

REVISIONS

CLIENT: BHADLA SIKAR TRANSMISSION LIMITED
(A 100% WHOLLY OWNED SUBSIDIARY OF POWERGRID)

CONTRACTOR: L&T Construction
Power Transmission & Distribution IC

PROJECT: 765KV D/C Bhadla-II (P) - SSK-II 2nd Transmission line associated with Transmission extension for connection of power from solar energy zones in Rajasthan (S.T. 004) under Phase II - Part-I through and based competitive bidding (TSCB-040)

TOWER TYPE: TSCB-040
(765KV D/C HEXA AL35 7230RA)
(WIND ZONE - 4)

SCALE: VARES
SHEET NO. 14 OF 19


DATE: 01.03.2025

RELEASED FOR: ☐ PRELIMINARY ☐ TOWER ☐ INFORMATION ☐ APPROVAL ☐ CONSTRUCTION

JUMPER DETAILS & KEY SKETCH OF BODY EXTENSIONS FOR
765KV D/C WZ-4-DB1 TOWER


-3.0/-1.5/+0/+1.5/+3.0M BODY EXTNS AT BASIC BODY LEVEL.
+4.5/+0.0/+7.5/+9.0/+18.0M BODY EXTNS AT NORMAL TOWER LEVEL.

+QM LE/BE



JUMPER DETAILS & KEY SKETCH OF BODY EXTENSIONS FOR
765KV D/C WZ-4-DB2 TOWER
-3.0/-1.5/+0/+1.5/+3.0M BODY EXTNS AT BASIC BODY LEVEL.
+4.5/+6.0/+7.5/+9.0/+15.0M BODY EXTNS AT NORMAL TOWER LEVEL.

[illegible]




NOTES:

1. T.LS. REFERRED TO TENSION INSULATOR STRING
2. ALL DIMENSIONS ARE IN MM. UNLESS OTHERWISE SPECIFIED

131







1. T.E. REFERRED TO TENSION INSULATOR STRING.
P.I. REFERRED PILOT INSULATOR.

REV	DATE	BY	DESCRIPTION	APP	CHK	DATE	BY
01/01/20	01/01/20	SA	AS SUBMITTED FOR PRELIMINARY REVIEW	0101	0101	01/01/20	SA
02/01/20	01/01/20	SA	RE SUBMITTED FOR SUBMITTAL OF AMENDMENTS	0201	0201	01/01/20	SA
03/01/20	01/01/20	SA	FOR REVIEW	0301	0301	01/01/20	SA
04/01/20	01/01/20	SA	FOR REVIEW	0401	0401	01/01/20	SA
05/01/20	01/01/20	SA	FOR REVIEW	0501	0501	01/01/20	SA
06/01/20	01/01/20	SA	FOR REVIEW	0601	0601	01/01/20	SA
07/01/20	01/01/20	SA	FOR REVIEW	0701	0701	01/01/20	SA
08/01/20	01/01/20	SA	FOR REVIEW	0801	0801	01/01/20	SA
09/01/20	01/01/20	SA	FOR REVIEW	0901	0901	01/01/20	SA
10/01/20	01/01/20	SA	FOR REVIEW	1001	1001	01/01/20	SA
11/01/20	01/01/20	SA	FOR REVIEW	1101	1101	01/01/20	SA
12/01/20	01/01/20	SA	FOR REVIEW	1201	1201	01/01/20	SA
13/01/20	01/01/20	SA	FOR REVIEW	1301	1301	01/01/20	SA
14/01/20	01/01/20	SA	FOR REVIEW	1401	1401	01/01/20	SA
15/01/20	01/01/20	SA	FOR REVIEW	1501	1501	01/01/20	SA
16/01/20	01/01/20	SA	FOR REVIEW	1601	1601	01/01/20	SA
17/01/20	01/01/20	SA	FOR REVIEW	1701	1701	01/01/20	SA
18/01/20	01/01/20	SA	FOR REVIEW	1801	1801	01/01/20	SA
19/01/20	01/01/20	SA	FOR REVIEW	1901	1901	01/01/20	SA
20/01/20	01/01/20	SA	FOR REVIEW	2001	2001	01/01/20	SA
21/01/20	01/01/20	SA	FOR REVIEW	2101	2101	01/01/20	SA
22/01/20	01/01/20	SA	FOR REVIEW	2201	2201	01/01/20	SA
23/01/20	01/01/20	SA	FOR REVIEW	2301	2301	01/01/20	SA
24/01/20	01/01/20	SA	FOR REVIEW	2401	2401	01/01/20	SA
25/01/20	01/01/20	SA	FOR REVIEW	2501	2501	01/01/20	SA
26/01/20	01/01/20	SA	FOR REVIEW	2601	2601	01/01/20	SA
27/01/20	01/01/20	SA	FOR REVIEW	2701	2701	01/01/20	SA
28/01/20	01/01/20	SA	FOR REVIEW	2801	2801	01/01/20	SA
29/01/20	01/01/20	SA	FOR REVIEW	2901	2901	01/01/20	SA
30/01/20	01/01/20	SA	FOR REVIEW	3001	3001	01/01/20	SA
31/01/20	01/01/20	SA	FOR REVIEW	3101	3101	01/01/20	SA
32/01/20	01/01/20	SA	FOR REVIEW	3201	3201	01/01/20	SA
33/01/20	01/01/20	SA	FOR REVIEW	3301	3301	01/01/20	SA
34/01/20	01/01/20	SA	FOR REVIEW	3401	3401	01/01/20	SA
35/01/20	01/01/20	SA	FOR REVIEW	3501	3501	01/01/20	SA
36/01/20	01/01/20	SA	FOR REVIEW	3601	3601	01/01/20	SA
37/01/20	01/01/20	SA	FOR REVIEW	3701	3701	01/01/20	SA
38/01/20	01/01/20	SA	FOR REVIEW	3801	3801	01/01/20	SA
39/01/20	01/01/20	SA	FOR REVIEW	3901	3901	01/01/20	SA
40/01/20	01/01/20	SA	FOR REVIEW	4001	4001	01/01/20	SA
41/01/20	01/01/20	SA	FOR REVIEW	4101	4101	01/01/20	SA
42/01/20	01/01/20	SA	FOR REVIEW	4201	4201	01/01/20	SA
43/01/20	01/01/20	SA	FOR REVIEW	4301	4301	01/01/20	SA
44/01/20	01/01/20	SA	FOR REVIEW	4401	4401	01/01/20	SA
45/01/20	01/01/20	SA	FOR REVIEW	4501	4501	01/01/20	SA
46/01/20	01/01/20	SA	FOR REVIEW	4601	4601	01/01/20	SA
47/01/20	01/01/20	SA	FOR REVIEW	4701	4701	01/01/20	SA
48/01/20	01/01/20	SA	FOR REVIEW	4801	4801	01/01/20	SA
49/01/20	01/01/20	SA	FOR REVIEW	4901	4901	01/01/20	SA
50/01/20	01/01/20	SA	FOR REVIEW	5001	5001	01/01/20	SA
51/01/20	01/01/20	SA	FOR REVIEW	5101	5101	01/01/20	SA
52/01/20	01/01/20	SA	FOR REVIEW	5201	5201	01/01/20	SA
53/01/20	01/01/20	SA	FOR REVIEW	5301	5301	01/01/20	SA
54/01/20	01/01/20	SA	FOR REVIEW	5401	5401	01/01/20	SA
55/01/20	01/01/20	SA	FOR REVIEW	5501	5501	01/01/20	SA
56/01/20	01/01/20	SA	FOR REVIEW	5601	5601	01/01/20	SA
57/01/20	01/01/20	SA	FOR REVIEW	5701	5701	01/01/20	SA
58/01/20	01/01/20	SA	FOR REVIEW	5801	5801	01/01/20	SA
59/01/20	01/01/20	SA	FOR REVIEW	5901	5901	01/01/20	SA
60/01/20	01/01/20	SA	FOR REVIEW	6001	6001	01/01/20	SA
61/01/20	01/01/20	SA	FOR REVIEW	6101	6101	01/01/20	SA
62/01/20	01/01/20	SA	FOR REVIEW	6201	6201	01/01/20	SA
63/01/20	01/01/20	SA	FOR REVIEW	6301	6301	01/01/20	SA
64/01/20	01/01/20	SA	FOR REVIEW	6401	6401	01/01/20	SA
65/01/20	01/01/20	SA	FOR REVIEW	6501	6501	01/01/20	SA
66/01/20	01/01/20	SA	FOR REVIEW	6601	6601	01/01/20	SA
67/01/20	01/01/20	SA	FOR REVIEW	6701	6701	01/01/20	SA
68/01/20	01/01/20	SA	FOR REVIEW	6801	6801	01/01/20	SA
69/01/20	01/01/20	SA	FOR REVIEW	6901	6901	01/01/20	SA
70/01/20	01/01/20	SA	FOR REVIEW	7001	7001	01/01/20	SA
71/01/20	01/01/20	SA	FOR REVIEW	7101	7101	01/01/20	SA
72/01/20	01/01/20	SA	FOR REVIEW	7201	7201	01/01/20	SA
73/01/20	01/01/20	SA	FOR REVIEW	7301	7301	01/01/20	SA
74/01/20	01/01/20	SA	FOR REVIEW	7401	7401	01/01/20	SA
75/01/20	01/01/20	SA	FOR REVIEW	7501	7501	01/01/20	SA
76/01/20	01/01/20	SA	FOR REVIEW	7601	7601	01/01/20	SA
77/01/20	01/01/20	SA	FOR REVIEW	7701	7701	01/01/20	SA
78/01/20	01/01/20	SA	FOR REVIEW	7801	7801	01/01/20	SA
79/01/20	01/01/20	SA	FOR REVIEW	7901	7901	01/01/20	SA
80/01/20	01/01/20	SA	FOR REVIEW	8001	8001	01/01/20	SA
81/01/20	01/01/20	SA	FOR REVIEW	8101	8101	01/01/20	SA
82/01/20	01/01/20	SA	FOR REVIEW	8201	8201	01/01/20	SA
83/01/20	01/01/20	SA	FOR REVIEW	8301	8301	01/01/20	SA
84/01/20	01/01/20	SA	FOR REVIEW	8401	8401	01/01/20	SA
85/01/20	01/01/20	SA	FOR REVIEW	8501	8501	01/01/20	SA
86/01/20	01/01/20	SA	FOR REVIEW	8601	8601	01/01/20	SA
87/01/20	01/01/20	SA	FOR REVIEW	8701	8701	01/01/20	SA
88/01/20	01/01/20	SA	FOR REVIEW	8801	8801	01/01/20	SA
89/01/20	01/01/20	SA	FOR REVIEW	8901	8901	01/01/20	SA
90/01/20	01/01/20	SA	FOR REVIEW	9001	9001	01/01/20	SA
91/01/20	01/01/20	SA	FOR REVIEW	9101	9101	01/01/20	SA
92/01/20	01/01/20	SA	FOR REVIEW	9201	9201	01/01/20	SA
93/01/20	01/01/20	SA	FOR REVIEW	9301	9301	01/01/20	SA
94/01/20	01/01/20	SA	FOR REVIEW	9401	9401	01/01/20	SA
95/01/20	01/01/20	SA	FOR REVIEW	9501	9501	01/01/20	SA
96/01/20	01/01/20	SA	FOR REVIEW	9601	9601	01/01/20	SA
97/01/20	01/01/20	SA	FOR REVIEW	9701	9701	01/01/20	SA
98/01/20	01/01/20	SA	FOR REVIEW	9801	9801	01/01/20	SA
99/01/20	01/01/20	SA	FOR REVIEW	9901	9901	01/01/20	SA
100/01/20	01/01/20	SA	FOR REVIEW	10001	10001	01/01/20	SA

THIS IS PROPRIETARY ITEM AND DESIGN RIGHT IS STRICTLY RESERVED WITH POWERGRID. UNDER NO CIRCUMSTANCES
THIS DRAWING SHALL BE USED BY ANYBODY WITHOUT PRIOR PERMISSION FROM POWERGRID IN WRITING.



Appendix - II.



Δ M.S. PLATE-1.6MM THK.(MIN) AS PER S:1079 - 30477/60001-4010/1518

3. PHASE PLATE TO BE ENAMELED RED, YELLOW AND BLUE ON FRONT AND BACK.
4. GENERAL TOLERANCE $\pm 0\%$ UNLESS OTHERWISE SPECIFIED
5. PHASE PLATE SHALL BE AS PER ISSUES (PART-2).
6. BOLT / NUT TO BE GALVANIZED AS PER IS-1367 (P-12) ~ 1983.
7. QUANTITY PER SET: ONE PLATE EACH OF RED, YELLOW & BLUE.
8. ONE SET FOR EACH CIRCUIT IS TO BE SUPPLIED.

LIST OF 16mm BOLTS, NUTS & WASHERS
TO BE SUPPLIED WITH EACH SET

DETAILS	QTY
M-16x35MM LONG HRH BOLT AS PER S12427-2001 CLASS 5.8 AND NUT AS PER S1-384-1986 CLASS 5	3
2MM THK. LEAD WASHER	6

STANDARD DRIVING

POWER GRID CORPORATION
OF INDIA LIMITED
(A GOVERNMENT OF INDIA ENTERPRISE)

PROJECT: 765/400/220KV TRANSMISSION SYSTEM

TITLE: PYASE PLATE

M. J. Quinn

APPROVED	DATE	BY	CREATED BY

SCALE	DRAWING NO: CG-ENG-CTIACCP	REV.
KTS.		

[illegible]


REV. No.	DESCRIPTION	CASH	BANK
----------	-------------	------	------

66M(ENG-TL)


PGR(EN60-TL)

1

File No. HOUDIV-14012/122/2025-PIU Gwalior (Computer No. 301918)




1. ALL DIMENSIONS ARE IN MM.
2. ALL HOLES ARE 17.8MM Ø FOR 18MM Ø BOLTS.
3. BLANK HOLES AT GATE ARE TO RECEIVE BARBED WIRE.
4. STD. SPRING WASHER TO BE SUPPLIED WITH EACH BOLT AND SHALL CONFORM TO IS : 5052 Type B J481573 SERVICE GRADE.
5. ALL STEEL SHALL BE HOT-DIP GALVANIZED.
AS PER IS : 2829.
6. ALL STEEL SHALL CONFORM TO IS : 2082 GRADE "A".
7. GALVANIZED STEEL BARBED WIRE SHALL CONFORM TO A-1, IS : 378.
8. BOLT TO BE CONFORMING TO IS:12-27-2001 G: 5.6 & NUT CONFORMING TO IS:14394-1986 (G: 5).
9. BOLT / NUT TO BE HOT DIP GALVANIZED AS PER IS:1587 (P-13) - 1963.
10. BARBED WIRE SHALL BE GIVEN CHIRMATING DIP AS PER PROCEDURE LAD DOWN IN IS : 1340
11. MINIMAL LENGTH OF BARBED WIRE SHALL BE WORKED OUT AS PER FOLLOWING FORMULAE:
$$L = B + (X - 3.5) \times 2 \times \text{Tong} \times H$$
$$B = B/W \text{ Width at } 21^\circ \text{ for Normal Tower in Mtrs.}$$
$$H = \text{Height of Body Eave if any in Mtrs.}$$
$$N = \text{NUMBER OF BARBED WIRE TURNS}$$
$$C = \text{TOWER SLOPE}$$



VIEW ON B-B

METHOD OF WRAPPING BARBED WIRE



LIST OF BOLTS & NUTS / TOWER				
S.NO	SIZE			QTY
	STUD THICK(MM)	W-11	W-12	
1	LENGTH OF 1/16	45	50	60
2	BOLT (mm)	M-16 x 35LG		
3	18MM DIA 3.5MM THK SP WASHER	27		

BILL OF MATERIAL			
MARK NO	SECTION	LENGTH (mm)	QTY NOS
AC1	L 100x100x6	128	4+4=8
AC2	L 50x50x5	617	4
AC3	L 50x50x5	617	1
AC4	L 50x50x5	470	1
AC5	L 50x50x5	617	3

[illegible]

