

No. RO/Chennai/MoRTH/12017/NH-383/PER/15/2024-25

GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

Regional Office, Chennai.

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.

Email: cerochennai@morth@gmail.com, Tele Off: 24919341.

Date: 27.09.2024

Invitation of public comments

Subject:- Permission proposal for Erecting of 22-KV, 5-MV Overhead Electrical transmission in 3 lay Power Cables lines & poles along the National Highways from Km 11/376 to Km 13/356(RHS) and 1st cross the road at Km 11/376 LHS to RHS & 2nd across the road at Km 13/356 RHS to LHS on NH-383(Dindigul -Natham- Kottampatty section) in the state of Tamil Nadu -Regarding.

The proposal is regarding request for permission for Erecting of 22-KV, 5-MV Overhead Electrical transmission in 3 lay Power Cables lines & poles along the National Highways from Km 11/376 to Km 13/356(RHS) and 1st cross the road at Km 11/376 LHS to RHS & 2nd across the road at Km 13/356 RHS to LHS on NH-383(Dindigul -Natham- Kottampatty section) in the state of Tamil Nadu by M/s HYPKRT Power Private Limited, Erode submitted to this office by the SE (NH), Madurai vide letter No. 1699/2024/JDO-1/NH dated 13.08.2024(received on 16.08.2024). The proposal has been examined and the details are as under:

Stretch in Km	Length (m)	ROW (m)	Dist. of Prop. Overhead Electrical cable line from Centre of NH (m)	Overhead electrical line crossing the road vertical clearance from carriageway
RHS proposed 22KV-5MV overhead line with poles				
Km 11/376 to Km 13/356(RHS)	1980	Varies from 24.00m to 34.70m	Varies from 10.00m to 20.10m	-
Road Crossing the overhead line				
Km 11/376 LHS to RHS	34.70	34.70	-	19.5
Km 13/356 RHS to LHS	31.00	31.00	-	19.5

2. The Right of Way in the stretch of NH proposed for erecting overhead electrical cable line is varying from 24.00m to 34.700m. The carriageway width of stretch from Km 11/376 to Km 13/356(RHS) of NH-383 is 10.00m. M/s HYPKRT Power Private Limited, Erode has proposed to erect the overhead electrical cable line at edge of the ROW for a length of 1980m by adopting along the National Highway and across at Km 11/376 LHS to RHS & Km 13/356 RHS to LHS the National Highway. M/s HYPKRT Power Private Limited, Erode has proposed the overhead 22KV, 5MV line crossing the Right of Way will be 19.5m above the carriageway top as per the Ministry's guideline No. RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016.

Shap
27/09/2024

3. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

4. In view of above, comments of the public are invited if there is any objection/claim (on ground of public inconvenience, safety and general public interest) on the above proposal to the below mentioned address:

**The Regional Officer, Chennai,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090
E Mail. Id- rochennai.rth@gov.in**

Yours Sincerely,

- sd -

(Dhanapalan.K)
Executive Engineer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The SE, NH Circle, Madurai-for information please.

Dhanapalan
27/09/2024

(Dhanapalan.K)
Executive Engineer
For Regional Officer