



No. RO/Chennai/MoRTH/12017/NH-49extn/PER/04/2025-26

**GOVERNMENT OF INDIA
MINISTRY OF ROAD TRANSPORT & HIGHWAYS
Regional Office, Chennai.**

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.
Email:cerochennaiomorth@gmail.com, Tele Off: 24919341.

Date: 07.07.2025

Invitation of public comments

Subject:- Permission proposal for erection of 33KV overhead Transmission -Line along the road from Km 37/406 to Km 38/563(LHS) of Madurai- Cochin road NH-49Extn(New NH-85) in the state of Tamil Nadu by M/s Vijayanth Cosmic Power Private Limited-Reg.

The proposal is regarding request for permission for erection of 33KV overhead Transmission -Line along the road from Km 37/406 to Km 38/563(LHS) of Madurai- Cochin road NH-49Extn(New NH-85) in the state of Tamil Nadu by M/s Vijayanth Cosmic Power Private Limited resubmitted to this office by the SE (NH), Madurai vide letter No. 984/2025/JDO-1 dated 26.06.2025(received on 02.07.2025). The proposal has been examined and the details are as under:

Stretch in Km	Length (m)	ROW (m)	Dist. of Prop. Overhead Transmission line from Centre of NH (m)
RHS proposed 33KV overhead transmission line with poles			
from Km 37/406 to Km 38/563(LHS)	1157	Varies from 18.50m to 24.20m	Varies from 8.10m to 11.50m

2. The Right of Way in the stretch of NH proposed for erection overhead transmission-line is varying from 18.50m to 24.20m. The carriageway width of stretch from Km 37/406 & Km 38/563 of NH-85(Old NH 49Extn) is 10.00m. M/s Vijayanth Cosmic Power Private Limited has proposed to erect the overhead electrical cable line at edge of the ROW for a length of 1157m along the National Highway. M/s Vijayanth Cosmic Power Private Limited has proposed the overhead 33KV transmission line vertical clearance is 7.50m as per the Ministry's guideline No. RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016.

3. M/s Vijayanth Cosmic Power Private Limited has furnished an undertaking to the effect that they will remove the laid overhead transmission line in future if required by NH Authority/MoRTH, Government of India at any time for expansion of the NH at their own cost without claiming any compensation from NH Authority/MoRTH, Government of India and any right on the NH land. Further, mentioned that, M/s Vijayanth Cosmic Power Private Limited will also restore the ROW surfaces to its original condition soon after removal of the utility (EB posts). Also, certified that the proposed overhead line erection work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

[Handwritten signature]
07/07/2025

4. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 the application will be made available for public comments and the comments will be invited within 30 days from the day of uploading the same in the web site of Ministry of Road Transport & Highways for public comments.

5. In view of above, comments of the public are invited if there is any objection/claim (on ground of public inconvenience, safety and general public interest) on the above proposal to the below mentioned address:

**The Regional Officer, Chennai,
Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600 090
E Mail. Id- rochennai.rth@gov.in**

Yours Sincerely,



(Santhosh.P.N)
Technical Officer
For Regional Officer

To:

1. The NIC, Transport Bhavan, New Delhi - for uploading in the Ministry's website.
2. The SE, NH Circle, Madurai-for information please.



(Santhosh.P.N)
Technical officer
For Regional Officer