



# भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

## National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. Of India)

क्षेत्रीय कार्यालय, उ०प्र० (पूर्व) वाराणसी

Regional Office - U.P. (East), Varanasi

एस- 2/656, ए-3 बी, वरुणा विहार कालोनी, द्वितीय एवं तृतीय तल, वन प्लेस टावर

(जे०पी० मेहता सीनियर सेकेंडरी स्कूल के पीछे), सिक्राऊल, वाराणसी-221002 (उ०प्र०)

S-2/656, A-3B, Varuna Vihar Colony, 2nd & 3rd floor, one place Tower

(Behind J.P. Mehta Sr. Secondary School), Sikraul, Varanasi-221002 (U.P.)

No. 14011/42/RO/UP(E)/2020/1712

दूरभाष / Phone : 91-542-2280243

: 91-542-2280372

ई-मेल/E-mail : rolucknow09@gmail.com

: rolucknow@nhai.org

वेबसाइट/Website: www.nhai.org

Date: 18.03.2020

### Invitation of Public Comments

**Sub.: Proposal for granting permission for laying of Underground 2 Nos. 33 KV, 3X300 sqmm XLPE Aluminium Armoured insulated cable along NH from KM 18.080 to KM 18.780 (LHS) NH-28 (New NH-27), Lucknow-Ayodhya Section, village Mohammadpur Chowki, Tehsil-Nawabganj & District-Barabanki in the State of Uttar Pradesh.**

The Executive Engineer, Electricity Distribution Division, Madhyanchal Vidhyut Vitran Nigam Limited, Barabanki has submitted the proposal for granting permission for laying of Underground 2 Nos. 33 KV, 3X300 sqmm XLPE Aluminium Armoured insulated cable along NH from KM 18.080 to KM 18.780 (LHS), in the subject cited stretch.

2. From the submitted proposal, it is seen that the LHS ROW is 22.50m and RHS ROW is 22.50m from the centre line of the Highway. The HT cable is proposed to lay from KM 18.080 to KM 18.780 (LHS) along NH within available ROW. The Project at the utility laying location is 4-lane + service road and there is no utility land earthen/soft shoulder available. The HT Cable will be laid through HDD Method.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Application shall be put out in the Public Domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained

The Chief General Manager cum Regional Officer,  
National Highways Authority of India  
Regional Office, UP-East, Varanasi  
S-2/656, A-3B, Varuna Vihar Colony,  
2nd & 3rd Floor, One Place Tower,  
Behind J.P. Mehta Sr. Secondary School,  
Sikraul, Varanasi-221002  
Email: rovaransi@nhai.org

Encl: As above

Copy to:

- Web Admin, NHAI-HQ-with request for uploading on the NHAI website
- The Technical Director, NIC, Transport Bhawan, New Delhi - with request for uploading on the Ministry's website.
- The Executive Engineer, EDD, MVVNL, Barabanki-211002- for information please
- The Project Director, NHAI, PIU-Lucknow- for information & necessary action please.

(C.M.Dwivedi)  
General Manager (Tech.)