



Government of India

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010
Phone No. 079-26950705, Phone/Fax No. 079-26950705 Email-rogandhinagar@yahoo.in

RW/GNR/NH/EL/OFC/NOC/307/2021/1086

Date: 27th Jan 2023

Invitation of Public Comments

Subject: Permission for crossing of 66 KV overhead electric transmission line between km 124/200 to km 124/3000 of NH-47 (Ahmedabad Bagodara section) in the state of Gujarat.

Reference: Letter No. NHP-10-2022-481-M dated 18.07.2022


The Under Secretary, Roads and Building Department, Government of Gujarat vide letter cited under reference has recommended the subject cited proposal **Permission for crossing of 66 KV overhead electric transmission line between km 124/200 to km 124/3000 of NH-47 (Ahmedabad Bagodara section) in the state of Gujarat** for approval of Regional Officer, MoRT&H Gujarat.

2. As per Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of the above the comments of public are invited on captioned proposal and the same should reach to below mentioned address by 30 days beyond which no comments will be considered.

The Regional officer, Gandhinagar
Ministry of Road Transport & Highways
(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)
4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010
Email: rogandhinagar@yahoo.in

4. This issues with the approval Regional Officer, MoRT&H, Gandhinagar.


(Ganesh Shelar)
Executive Engineer
For Regional Officer Gandhinagar

Copy to:

1. The Senior Technical Director, NIC, Transport Bhawan, New Delhi-110001- for **uploading on Ministry's website.**
2. The Chief Engineer(NH) &AS, Roads and Building Department, Government of Gujarat.- for information.

3. The Executive Engineer, NH-Division Ahmedabad -For Information and necessary Action.

4. Sr. Manager/ Head of Project, SJVN Ltd.

- i. For information and with request to submit the license fees of Rs.91,773/- through online portal for NTRP collection i.e through BHARATKOSH (<https://bharatkosh.gov.in/>) within 15 days along with performance BG amounting to Rs. 03,00,000/-.(for six lane highway)
- ii. The receipt of online license fee deposition should be submitted to this office with intimation to the Executive Engineer, NH- Division, Ahmedabad. The BG should be in favor of the Executive Engineer, NH- Division, Ahmedabad (as per prevailing procedure in R&B Dept.) and to be submitted to Executive Engineer, NH- Division , Ahmedabad custodian of BG/s.

The details for payment for submission of license fees through NTRP of is as under:


Name of Ministry: ROAD TRANSPORT & HIGHWAYS

Pay & Account Office (PAO): 034650 -PAO(NH), Mumbai

Drawing & Disbursing Office(DDO): 234653, SE

Purpose: 'license fees for laying utility services'

'Processing fee for permission to access to NH' (only if above purpose is not available)


(Ganesh Shelar)
Executive Engineer
For Regional Officer Gandhinagar

Note: This document is not any kind of NOC.

Subject: Permission for crossing of 66 KV overhead electric transmission line between km 124/200 to km 124/3000 of NH-47 (Ahmedabad Bagodara section) in the state of Gujarat.

Details of the proposal are as under

1	Name of Applicant and Department	Sr. Manager/ Head of Project, SJVN Ltd.
2	NH No	NH-47
3	Width of ROW	45 mtr
4	Whether Service road is existing	No
5	Number of lane/s	6 lane
6	Purpose of utility	Overhead electric line
7	Dimension of pipelines	66 KV overhead electric line
8	Whether provisions of utility duct is available at propose location	No.
9	Whether a certificates as per para 4 of guidelines issued by MoRT&H vide letter dated 22.11.2016.	Not applicable
10	Location of Utility w.r.t NH	across NH-47 @km 124/246
11	Methodology for laying	The overhead electric line is supported by means of caged tower located at distance of 60 m (LHS) and 36 mt (RHS) from center line with clear vertical clearance of 15.230 which satisfies criteria of 6.1 m
12	Whether details of rent /license fees is given	Yes. As per para.4 above
13	Whether State R&B has recommended the proposal for access permission	Yeas, vide letter No. NHP-11-2023-11-M dated 13.01.2023