



सत्यमेव जयते

Government of India

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4<sup>th</sup> floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010

Phone No. 079-26950705, Phone/Fax No. 079-26950705 Email: rogandhinagar@yahoo.in

RW/GNR/NH/US/WL/NOC/273/2020/718

Date: 05<sup>th</sup> October 2021

Invitation of Public Comments

**Subject: Permission for accommodation of drinking water pipe line having dia 600 mm across NH-147 (old NH-8C) by HDD/push through method at chainage 13/640 in the state of Gujarat.**

**Reference: Letter No. NHP-11-2021-1023-M dated 23.09.2021**

The Under Secretary, Roads and Building Department, Government of Gujarat vide letter cited under reference has recommended the subject cited proposal for accommodation of drinking water pipe line having dia 600 mm across NH-147 (old NH-8C) by HDD/push through method at chainage 13/640 in the state of Gujarat for approval of Regional Officer, MoRT&H Gujarat.

2. As per Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of the above the comments of public are invited on captioned proposal and the same should reach to below mentioned address till 06.11.2021 beyond which no comments will be considered.

The Regional officer, Gandhinagar  
Ministry of Road Transport & Highways  
(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)  
4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010  
Email: rogandhinagar@yahoo.in


4. This issues with the approval Regional Officer, MoRT&H, Gandhinagar.

(Ganesh Shelar)  
Executive Engineer  
For Regional Officer Gandhinagar

Copy to:

1. The Senior Technical Director, NIC, Transport Bhawan, New Delhi-110001- for uploading on Ministry's website.
2. The Chief Engineer(NH) &AS, Roads and Building Department, Government of Gujarat.- for information.







3. The Executive Engineer, NH-Division Ahmedabad -For Information and necessary Action.
4. Executive Engineer, PH Works Division Gandhinagar.

- i. For information and with request to submit the license fees of Rs.02,43,243/- and requisite performance BG of Rs. 03,07,800.00 (Rs. 3,00,000/- for six lane Highway +7800) as worked out by the R&B Department of Government of Gujarat. The license fee shall be submitted through online portal for NTRP collection i.e through BHARATKOSH (<https://bharatkosh.gov.in/>) within 15 days and BG for restoration charges. The receipt of online license fee deposition should be submitted to this office with intimation to the Executive Engineer, NH- Division, Ahmedabad. The BG should be in favor of the Executive Engineer, NH- Division, Ahmedabad (as per prevailing procedure in R&B Dept.) and to be submitted to Executive Engineer, NH- Division , Ahmedabad custodian of BG/s under intimation to this office.

The details for payment for submission of license fees through NTRP of is as under:

**Name of Ministry: ROAD TRANSPORT & HIGHWAYS**

**Pay & Account Office (PAO): 034650 -PAO(NH), Mumbai**

**Drawing & Disbursing Office(DDO): 234653, SE**

**Purpose: 'license fees for laying utility services'**

**'Processing fee for permission to access to NH'** (only if above purpose is not available)



(Ganesh Shelar)  
Executive Engineer  
For Regional Officer Gandhinagar

**Note: This document is not any kind of NOC.**



100

8



**Subject: Permission for accommodation of drinking water pipe line having dia 600 mm across NH-147 (old NH-8C) by HDD/push through method at chainage 13/640 in the state of Gujarat.**

**Details of the proposal are as under**

1	Name of Applicant and Department	Executive Engineer, P. H> Works Division Gandhinagar
2	NH No	NH-147 (old NH-8C)
3	Width of ROW	80 mtr
4	Whether Service road is existing	Yes utility is placed in outer most corridor beyond service road
5	Number of lane/s	6 lane with service road
6	Purpose of utility	Drinking water pipe line
7	Dimension of pipelines	600 mm dia MS pipeline
8	Whether provisions of utility duct is available at propose location	No
9	Whether a certificates as per para 4 of guidelines issued by MoRT&H vide letter dated 22.11.2016.	Not required
10	Location of Utility w.r.t NH	across NH-147 at km 13/640 and will be laid 3.0 mt below GL (clear distance up to invert level is 1.80 mt.)
11	Methodology for laying water pipeline	HDD method for crossing Detailed methodology placed in file
12	Whether details of rent /license fees is given	Yes. As per para.4 above
13	Whether State R&B has recommended the proposal for access permission	Yes vide letter No. NHP-11-2021-1023-M dated 23.09.2021



