

Government of India
Ministry of Road Transport & Highways
(Chief Engineer - Regional Office, Lucknow)
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022
Ph.: (0522) - 2967112, 2738226 (Tele-Fax)

Dated: 17.08.2021

Invitation of public comments

Sub.: Proposal for NOC permission for laying of 80mm underground OFC (Optical Fiber Cable) from Barbar Police Chowki to Aurangabad on Mohammadi to Maigalganj road, from ch.6.000 to ch.16.812 on NH-730A.
(Total length 10.812 km.) in the State of Uttar Pradesh - Reg.

M/s Telesonic Networks Limited has submitted the proposal for laying of underground 80mm OFC (Optical Fiber Cable) through trenchless HDD method from ch.6.000 to ch.16.812 on NH-730A from Barbar Police Chowki to Aurangabad on Mohammadi to Maigalganj road in the State of Uttar Pradesh to Chief Engineer (NH), PWD, Lucknow for consideration.


2. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address:

The Chief Engineer-Regional Officer,
Ministry of Road Transport & Highways,
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,
Vikas Nagar, Lucknow - 226 022.

Yours faithfully,

Encl.: As above



(Raj Kumar)
Assistant Executive Engineer
for Chief Engineer - Regional Officer

Copy to:

- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), Public Works Department, Government of Uttar Pradesh, Nirman Bhavan, 96, M. G. Marg, Lucknow - 226 001.
- (iii) The Executive Engineer, NH Division, PWD, Bareilly.

(Raj Kumar)
Assistant Executive Engineer
for Chief Engineer - Regional Officer


Annexure -2

CHECK-LIST

Guidelines for processing the proposal for laying of utility line in the land across National Highways vested with NH-PWD/NH PWD/PWD BRO.

Ministry circular No-RW/NH 330044/29/2015/S&R(R) Dated 22/11/2016.


Sr.No.	Item	Information/ Status	Remarks
	General Information	Uttar Pradesh	
1	Name and Address of the Applicant / Agency	Telesonic Networks Limited Regd. Office: at bharti crescent, nelson mandela road, vasantkunj phase ii, new delhi – 110 07	Branch Office:
2	National Highway Number	NH -730A (Breilly)	
3	State	Uttar Pradesh	
4	Location	Barbar to Aurangabad	
5	(Chainage in km)		
6	Length in Meters	10812mtrs	
7	Width of available ROW in both side	More than 4 Mtrs.	
8	Side of NH (left or right side of NH towards increasing change /KM/ direction)		
9	Name of Highways Authority of NH-PWD/PWD/BRO	NH CD PWD	
10	Highway Administration Address	The Executive Engineer, National Highway Construction Division PWD, Bareilly	
11	Proposal to acquire land	Executive Engineer, NH-PWD Bareilly	




Project Director
NH CD PWD/NH-PWD

.....

 Executive Engineer
 N. H. Construction Division
 P. W. D. Bareilly


 J.R.


 A.B.

Annexure -2

Sr.	Item	Measurement observation as per site condition	MORT&H Norms	Whether complying with MORT&H Norms
1	Details of already laid utility service in any	No	Enclosed	Complying
2	Whether up gradation of the stretch in near future is proposed or not	N/A		N/A
	a. If yes provision of utility adversely affect the plan of up gradation	No	affect the plan of up gradation	N/A
3	Laying of the utility service along the National Highways			
3.1	Location of proposed utility service along the stretch	LHS extreme edge of the ROW	Utility duct / beyond the toe line of the embankment and drains , enclose to the extreme edge of the ROW	
3.2	Depth of the utility service from Ground level	2m-3m	0.6m	Complying
3.3	Mechanism for crossing for OFC	HDD	Through utility duct (if provision exist) or beneath the bed of water channel	N/A
3.4	Whether is ROW restricted in the stretch?	No		N/A
3.4.1	If yes whether provision of land acquisition is required to lay utility	N/A		N/A
	a. If yes whether undertaking for land acquisition along with relevant L.A detail has been furnished	N/A		N/A
3.4.2	With if concrete duct , in utility service are proposed to be laid in concrete ducts	N/A	Not less than one lane	N/A
4	Laying of utility Service across the NH			

J.E.

A.E.

Executive Engineer
N. H. Construction Division
P. W. D. Bareilly



Annexure -2

4.1	Whether existing drainage structures is allow to carry the utility lines.	No	Not to be allowed	N/A
4.2	Proposed crossing of utility service	NA	NA	NA
4.3	Type of casing pipe/conduit carrying the utility line	HDPE Duct	Steel , cast iron , or RCC and have adequate strength	Complying
4.4	Whether ends of the casing /conduit pipe are sealed from the outside	Sealed	Sealed	Complying
4.5	Length of crossing /conduit pipe crossing NH	NA	NA	NA
4.6	Depth of top of the casing /conduit pipe	2.0m-3.0m	At least 1.2m below the top of subgrade	Complying
4.7	Crossing method in case of CC pavement	HDD	Only boring method (HDD)	Complying
4.8	Horizontal and vertical clearances in case utilities are allowed overhead	N/A (Underground only)	In accordance with IRC codes.	N/A
5	Document/drawing enclosed with the proposal	Yes Enclosed		
5.1	Cross section showing in the site of trench for open trenching method	N/A	Enclosed, if applicable	Complying
5.	a. Trench width	OFC by HDD Method	(Trenchless Method)	Complying
	b. Filling of trench	As per Ministry circular No-RW/NH 30044/29/2015 /S&R(R) Dated 22/11/2016.	As per Ministry circular No-RW/NH 30044/29/2015/S&R(R) Dated 22/11/2016.	Complying
	c. Location of trench	Within 2.0m at the Extreme edge of the ROW	Extreme edge of the ROW	Complying
5.2	Cross section showing the size of pit and location of conduit for HDD method	Yes enclosed	Enclosed , if applicable	Complying

J.R.

A.R.

24/10/21
Executive Engineer
N. H. Construction Division
P. W. D. Bareilly



Annexure -2

5.3	Strip plan / Route plan showing utility line , chainage , width of ROW , distance of proposed utility from the edge of ROW , important mile stone , intersection , cross drainage works etc.	Yes Enclosed	Enclosed	Complying
5.4	Plan and profile drawing of stretch showing cross section of road at 20m distance along with ROW and proposed utility	Yes enclosed	Enclosed	Complying
6	Methodology for laying of utility line	Yes enclosed	Enclosed	Complying
7	Draft license agreement is as per Ministry circular No-RW/NH30044/29/2015/S&R(R) Dated 22/11/2016.and signed by two witness	Yes enclosed	Enclosed	Complying
8	License fee in favour of	Yes	As per Ministry circular No-RW/NH30044/29/2015/S&R(R) Dated 22/11/2016.	Complying
9	Whether bank guarantee has been obtained	Yes	As per Ministry circular No-RW/NH 30044/29/2015/S&R(R) Dated 22/11/2016.	
	a.If yes, whether confirmation of BG has been obtained as per MORT&H / NH-PWD guidelines	Shall be obtained		
10.1	Undertaking for not to damage other existing utility , if damaged then to pay the losses to either to MORT&H / NH-PWD to the cornered agency	Enclosed	Enclosed	Complying
10.2	Undertaking for renewal of bank guarantee and when asked by NH-PWD/MORT&H	Enclosed	Enclosed	Complying
10.3	Undertaking for conforming all standard condition of MORT&H / NH-PWD guidelines	Enclosed	Enclosed	Complying

J.B.

A.B.

04/01/21
Executive Engineer
N. H. Construction Division
P. W. D. Bareilly



Annexure -2

10.4	Undertaking for shifting of utility as and when asked by MORT&H /NH-PWD within a month at their own cost	Enclosed	Enclosed	Complying
10.5	Undertaking for indemnity against all damages and claim	Enclosed	Enclosed	Complying
10.6	Undertaking for management of traffic moment during laying of utility line without hampering the traffic.	Enclosed	Enclosed	Complying
10.7	Undertaking that if any claim is raised by the concessionaire/ contractor than the same has to be paid by the applicant	Enclosed	Enclosed	Complying
10.8	Undertaking that the applicant has obtained various safety clearances from the representative authorities such as directorate of electricity, chief controller of explosive safety of directorate , state / central pollution control board and any other statutory clearances applicable before applying to Highway Administration	NA	NA	NA

The ROW of the National Highway available at the proposed location from the central line of divided carriageway is 31.05 m from central of ROW edge of ROW towards proposed utility in Rural section & 26.80 m from central of ROW edge of ROW towards proposed utility in Urban section.


The above particular along with the drawing and documents has been verified and certified as correct as per prevailing site conditions.


Telesonic Networks Limited.

Name designations & Signature of the
Authorized representative of applicant concerned

Name designations & Signature of the
field authority of NH CD PWD/NH-PWD


J.E


A.E


Executive Engineer
N. H. Construction Division
P. W. D. Pareilly