

NHAI/15018/4.7/2019/RO Madurai/829

28th May, 2020

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, Tuticorin - Permission for laying water supply pipeline - Providing CWSS to 8 Rural Habitations around SIPCOT industrial complex in Thoothukudi District as 100% Deposit work - Laying of pumping main from Km 07/504 to 07/549 (RHS) along the road and across at Km 07/549 of NH-7A (New NH-138) in Tuticorin - Tirunelveli Section of NH-7A (New NH-138) - Invitation of public comments - Reg.

This proposal is regarding Permission for laying water supply pipeline (pumping main) from Km 07/504 to 07/549 (RHS) along the road and across at Km 07/549 in Tuticorin - Tirunelveli Section of NH-7A(New NH-138) in the State of Tamil Nadu for a length of 45m was submitted to this office by PD, PIU, Tuticorin vide letter No. NHAI/PIU/TUT/NH-7A/TWAD/2020/265 dated 22.05.2020 in accordance with Ministry's latest guidelines dated 22.11.2016.

2) The alignment proposed by the Executive Engineer, TWAD Board, Tuticorin for laying of water supply pipeline i.e. providing CWSS to 8 Rural Habitations around SIPCOT Industrial complex in Thoothukudi District from Km 07/504 to 07/549 (RHS) along the road and across at Km 07/549 in Tuticorin - Tirunelveli Section of NH-7A (New NH-138) is as detailed under:

Stretch in Km	Length (m)	ROW (m)	Distance of Proposed Pipeline from Centre of NH (m)
Along the road: Size of Pipe – 150mm dia			
Along the road : Km 07/504 to Km 07/549 (RHS)	45	45	16.65
Across @ Km 07/549 : Size of Pipe – 150mm dia & 323.90 mm dia MS Encasing pipeline			

3) The right of way is 45 m in the aforesaid stretch. The Executive Engineer, TWAD Board, Tuticorin has proposed to lay water pipeline at the extreme edge of the ROW for a length of 45 m. The laying of water supply pipeline is proposed to be laid at a distance of 16.65 m from the center line of the carriageway which is in conformity with Ministry's guidelines vide letter no. NHIII/P/66/76 dated 19.11.1976. Further, the Executive Engineer, TWAD Board, Tuticorin has given undertaking that the lay of water pipeline is proposed to lay by **Open Trench Method** for a distance of 16.65 m from the center line of the carriageway and Across at Km-07/549 by **Trenchless Method** at a depth of 1.32 m from the bottom of the ground.

Gnz

4) The Executive Engineer, TWAD Board, Tuticorin has furnished an undertaking to the effect that they will remove the laid of water pipeline in future if required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed laying of water supply pipeline work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5) As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal requiring may be invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No.2nd & 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007

Encl: As above

K. Govindasamy
(Govindasamy K) 26/05/2020
Deputy General Manager (Tech.)
For Regional Officer- Madurai

Copy to:

- 1) The NIC, New Delhi - for uploading in Ministry's website.
- 2) The PD, PIU, Tuticorin -for information

Encl: As above

(Govindasamy K)
Deputy General Manager (Tech.)
For Regional Officer- Madurai

Copy to:

- 1) The NIC, New Delhi - for uploading in Ministry's website.
- 2) The PD, PIU, Tuticorin -for information