

Government of India

Ministry of Road Transport & Highways

(Chief Engineer - Regional Office, Lucknow)

N.H. Bhawan, Biotech Chowk, Lucknow Ring Road, Vikas Nagar, Lucknow - 226 022

Ph.: (0522) - 2967112, 2738226 (Tele-Fax)

Dated: 23.12.2020

Invitation of public comments

Sub.: Proposal for NOC for overhead crossing of 132 KV D/C Soroan - Pratapgarh Lilo at Mandhata line over NH-96 (New NH - 330) at Km. 118.068 in the State of Uttar Pradesh - Reg.

The Executive Engineer, Electricity Transmission Division, UP Power Transmission Corporation Ltd., Pratapgarh has submitted the proposal for overhead crossing of 132 KV D/C Soroan - Pratapgarh Lilo at Mandhata line over NH-96 (New NH - 330) at Km. 118.068 to the Executive Engineer, NH Division-1, UP PWD, Prayagraj.

2. The proposal has been examined in light of Ministry's OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. From the submitted proposal, it is seen that the height of both the pylons on which the proposed overhead line is hanging is 42.025m. The pylons on either side are to be erected at distance of 65.00m & 160.00m from the nearest National Highway boundary. Further, it noted that the minimum clearance between the lowest conductor of the proposed line and NH carriageway is 18.00m. The proposed transmission line shall be crossing the National Highway at 84 degree.

3. As per the guidelines, issued by the Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of public on the above application (checklist enclosed) is invited to the below mentioned address:

The Chief Engineer - Regional Officer,  
Ministry of Road Transport & Highways,  
N.H. Bhawan, Biotech Chowk, Lucknow Ring Road,  
Vikas Nagar, Lucknow - 226 022.


Yours faithfully,

Encl.: As above

  
(Raj Kumar)  
Assistant Executive Engineer  
For Chief Engineer - Regional Officer

**Copy to:**


- (i) NIC, New Delhi - for uploading on the Ministry's website.
- (ii) The Chief Engineer (NH), Public Works Department, Government of Uttar Pradesh, Nirman Bhavan, 96, M. G. Marg, Lucknow - 226 001

  
(Raj Kumar)  
Assistant Executive Engineer  
For Chief Engineer - Regional Officer

## CHECK LIST

- 1- National Highway Number : NH-330
- 2- Name of crossing : PRAYAGRAJ-AYODHYA (NH-330)
- 3- Crossing at Chain age : Between KM-118/050 & KM-118/066
- 4- Position of tower : Outside the ROW of NH
- 5- Crossing span : 250MTR
- 6- Clearance over the road Level : 18 MTR
- 7- Angle of road crossing : 84°
- 8- Distance from NH boundary to : Tower no 05/0 (DC+10)
- Centre of tower : Tower no 06/0 (DC+10)
- 9- Perpendicular Distance from centre :
- Of tower to centre of road
- 10- Protection of assembly to the line : No Anti Climbing devices provided
- 11- No. of stay required : No Required
- 12- Minimum Factor of Safety : 2.0 (Normal Condition)
- 13- Size of power conductor mm. :
- 14- Size of earth wire : 7/3.66 +10.98mm. (Steel)

  
Assistant Engineer  
N. H. Div-I, P.W.D.  
PRAYAGRAJ

  
Executive Engineer  
N. H. Division-I, P.W.D.  
Prayagraj

  
EXECUTIVE ENGINEER  
Electricity Transmission Division  
220-KV S/S Bhupiamau  
Pratapgarh