



सत्यमेव जयते

Government of India

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010

Phone No. 079-26950705, Phone/Fax No. 079-26950705 Email-rogandhinagar@yahoo.in

RW/GNR/NH/US/EL/NOC/303/2022/ 849

Date: 15, November 2022

Invitation of Public Comments

Subject: Permission for accommodation of underground 132KV cable along NH-147 from km 32/900 to km 34/00(LHS) and from km 34/600 to km 34/800 (Kargil Petrol pump to Sola Bridge) in the state of Gujarat.

Reference: Letter No. NHP-11-2020-973-M dated 11.11.2022

The Under Secretary , Roads and Building Department, Government of Gujarat vide letter cited under reference has recommended the subject cited proposal for accommodation of underground 132KV cable along NH-147 from km 32/900 to km 34/00(LHS) and from km 34/600 to km 34/800 (Kargil Petrol pump to Sola Bridge) in the state of Gujarat or approval of Regional Officer , MoRT&H Gujarat.

2. As per Ministry vide OM No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the Highway Administration will make available the proposal seeking permission for utility laying for public comments for 30 days on ground of general public interest for seeking claims and objections.

3. In view of the above, the comments of public are invited on captioned proposal and the same should reach to below mentioned address till 14.12.2022 beyond which no comments will be considered.

The Regional officer, Gandhinagar

Ministry of Road Transport & Highways

(Regional Office, Gandhinagar, Dadra & Nagar Haveli and Daman & Diu)

4th floor, Block No. 14, New Sachivalaya, Regional Office, Gandhinagar, Gujarat-382010

Email: rogandhinagar@yahoo.in

4. This issues with the approval Regional Officer, MoRT&H, Gandhinagar.

(Ganesh Shelar)

Executive Engineer

For Regional Officer Gandhinagar

Copy to:

1. The Senior Technical Director, NIC, Transport Bhawan, New Delhi-110001- for uploading on Ministry's website.
2. The Chief Engineer (NH) &AS, Roads and Building Department, Government of Gujarat. - for information.
3. The Executive Engineer, NH-Division Ahmedabad -For Information and necessary Action.

4. Sh. L N Mishra ,VP (EHV), Ahmedabad Distribution, M/s Torrent Power Ltd.

- i. For information and with request to submit the license fees of Rs.72518/- through online portal for NTRP collection i.e through BHARATKOSH (<https://bharatkosh.gov.in/>) within 15 days along with performance BG amounting to Rs. 08,50,000/-.
- ii. The receipt of online license fee deposition should be submitted to this office with intimation to the Executive Engineer, NH- Division, Ahmedabad. The BG should be in favor of the Executive Engineer, NH- Division, Ahmedabad (as per prevailing procedure in R&B Dept.) and to be submitted to Executive Engineer, NH- Division , Ahmedabad custodian of BG/s.

The details for payment for submission of license fees through NTRP of is as under:


Name of Ministry: ROAD TRANSPORT & HIGHWAYS

Pay & Account Office (PAO): 034650 -PAO(NH), Mumbai

Drawing & Disbursing Office(DDO): 234653, SE

Purpose: 'license fees for laying utility services'

'Processing fee for permission to access to NH' (only if above purpose is not available)


(Ganesh Shelar)

Executive Engineer
For Regional Officer Gandhinagar

Note: This document is not any kind of NOC.

Subject: Permission for accommodation of underground 132KV cable along NH-147 from km 32/900 to km 34/00(LHS) and from km 34/600 to km 34/800 (Kargil Petrol pump to Sola Bridge) in the state of Gujarat.

Details of the proposal are as under

1	Name of Applicant and Department	Sh. L N Mishra , VP (EHV), Ahmedabad Distribution, M/s Torrent Power Ltd.
2	NH No	NH-147 (old NH-8C)
3	Width of ROW	60 mtr
4	Whether Service road is existing	Yes utility is placed in outer most corridor beyond service road
5	Number of lane/s	6 lane with service road
6	Purpose of utility	132 KV underground electric line
7	Dimension of pipelines	600 mm dia RCC protection pipe.
8	Whether provisions of utility duct is available at propose location	No
9	Whether a certificates as per para 4 of guidelines issued by MoRT&H vide letter dated 22.11.2016.	Not required
10	Location of Utility w.r.t NH	Along NH-147 -From km 32/900 to km to km 34/00(LHS) and - from km 34/600 to km 34/800 (LHS)
11	Methodology for laying pipeline	Open trench method for accommodation of utility along NH-147
12	Whether details of rent /license fees is given	Yes. As per para. 4 above.
13	Whether State R&B has recommended the proposal for access permission	Yes, vide Letter No. NHP-11-2020-973-M dated 11.11.2022