



Government of India  
Ministry of Road Transport & Highways  
Office of the Chief Engineer- Regional Officer, (Civil)  
No. 32, 2<sup>nd</sup> Floor, KSCFL Building, Race Course Road, BENGALURU-560 001  
Email: [robengaluru@gmail.com](mailto:robengaluru@gmail.com); Telephone: 080-22267457, 080-22265765

No.RW/BNG/PER.CASES/ HBL DVN/2020

Dated: 16.02.2026

Notice inviting Public Comments for Proposal of electrical pole crossing near Masabha Hanchinal village , Kukanoor taluk between Km 9 to Km 10 (i.e 9.452 of NH-367) NH crossing for “Construction of Gadag-II Koppal-II PS 400KV (Quad Moose) D/C Transmission line for integration of Renewable Energy Zone (Phase-II) in Koppal -II (Phase-A) and Gadag-II (Phase-A) in Karnataka”- Reg.

Reference: The EE, NH, Hubli Letter No. EE/NH/HBL/PB-3/PowerGrid/2025-26/2281 Dtd 04.02.2026.

The Executive Engineer, NH Division, Bangalore vide letter cited under reference above, has submitted Proposal of electrical pole crossing near Masabha Hanchinal village , Kukanoor taluk between Km 9 to Km 10 (i.e 9.452 of NH-367) NH crossing for “Construction of Gadag-II Koppal-II PS 400KV (Quad Moose) D/C Transmission line for integration of Renewable Energy Zone (Phase-II) in Koppal -II (Phase-A) and Gadag-II (Phase-A) in Karnataka”.

2. The proposal has been examined as per Ministry's Guidelines vide letter no.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 and dated 17.04.2023 is generally found in order.

3. In view of above, as per Ministry's said guidelines Para 4, public comments are invited on the above proposal making claims and raising objections (on grounds of public inconvenience, safety and general public interest) if any within 30 days on public portal i.e., website of Ministry of Road Transport and Highways (morth.nic.in) in Form-A (copy enclosed) for “Accommodation of Public and Industrial Utility Services along and across National Highways”.

Comment Inviting Authority

The Regional Officer-Civil  
Ministry of Road Transport & Highways  
No.32, 2nd Floor, Race Course Road, Bangalore-560 001  
Email: [robengaluru@gmail.com](mailto:robengaluru@gmail.com); Telephone: 080-22217457, 080-22105765

Encl:As above

*hdm2*  
(Sandesh.K)  
Asst. Engineer(C)  
for RO-MoRTH Bengaluru

Copy to: (i) The Senior Technical Director, NIC, Transport Bhawan, New Delhi- 110001 for uploading on Ministry's website.  
(ii) The Executive Engineer, National Highway Division, Hubli, for information.

*hdm2*  
(Sandesh.K)  
Asst. Engineer(C)  
for RO-MoRTH Bengaluru

## FORM A

Form for seeking claims and objections (on grounds of public inconvenience, safety and general public interest) on the application for Accommodation of Public and Industrial Utility Services along and across National Highways.

Subject: Proposal of electrical pole crossing near Masabha Hanchinal village , Kukanoor taluk between Km 9 to Km 10 (i.e 9.452 of NH-367) NH crossing for "Construction of Gadag-II Koppal-II PS 400KV (Quad Moose) D/C Transmission line for integration of Renewable Energy Zone (Phase-II) in Koppal -II (Phase-A) and Gadag-II (Phase-A) in Karnataka"- Reg.

The claims and objections (on grounds of public inconvenience, safety and general public interest) by the general public needs to be given within 30 days of uploading the online application for comments.

Sl. No	Item	Details
1	Name of the person who is desiring to give claims and objections (on grounds of public inconvenience, safety and general public interest)	
2	Address of the person	
3	Details of the application for Accommodation of Public and Industrial Utility Services along and across National Highways against which claims and objections are being given (name of applicant and other details like site address etc.) a) Application No. b) Name of applicant (who applied to Accommodation of Public and Industrial Utility Services along and across National Highways) c) Details of Application	
4	The claims and objections (on grounds of public inconvenience, safety and general public interest)	

Office of the Executive Engineer,  
National Highway Division,  
Vishweshwar Nagar, Hubli-32,  
Date : 04/02/2026  
0/o. THE CE-RC  
MORT&H, BENGALURU  
Diary No.: 3590  
Date: 06/02/2026

To,  
The Regional officer,  
MoRT&H ,No.32,  
2nd Floor KSCFL Building  
Race Course Road,Bangalore-560001.

Sir,

Sub: Construction of Gadag-II Koppal-II PS 400KV (Quad Moose) D/C  
Transmission line for integration of Renewable Energy Zone (Phase-II) in  
Koppal-II (Phase-A) and Gadag-II (Phase-A) in Karnataka  
Reg – compliance to overhead NH crossing.

Ref : The Regional officer, MoRTT & H, Bengaluru Office letter No: RW/BNG/  
PER.CASES/HUBLI DVN/2021/2077 Dated: 23-01-2026.

\*\*\*\*\*

With reference to the above subject, the “proposal seeking permission  
Construction of Gadag-II Koppal-II PS 400KV (Quad Moose) D/C Transmission line for integration  
of Renewable Energy Zone (Phase-II) in Koppal-II (Phase-A) and Gadag-II (Phase-A) in Karnataka” –  
Overhead NH Crossing vide reference above the proposal was returned to this office to comply  
observations. The details are as below:

Sl No.	Observation	Compliance
1	The original proposals are not enclosed with the compliance letter. Hence, the EE, NH Hubli, is requested to submit the original proposals in two sets, along with the License Agreement (two sets) and one copy, as per the Ministry's guidelines dated 22.11.2016, for taking further necessary action.	The original proposals in two sets, along with the License Agreement (two sets) and one copy, as per the Ministry's guidelines dated 22.11.2016 is enclosed for kind reference.
2	All the undertakings mentioned in the checklist, as per the Ministry norms, need to be submitted in original copies duly signed by the Executive Engineer, NH Division, Hubli.	Signed copies are enclosed for kind reference.
3	As per the Ministry guidelines, when the utilities are allowed overhead, the horizontal and vertical clearance in accordance with the IRC shall be maintained. As such the Executive Engineer NH Division Hubli is requested to confirm whether the proposal is in accordance with the IRC: 32-1969.	The Horizontal And Vertical clearance are in accordance with the IRC: 32-1969 (Compliance submitted vide this office ltr No367 Dated 27/05/2025, copy enclosed for kind reference)

Hence, the compliance to the observations is submitted herewith for kind information and  
further needful.

Encl: As above.

Yours faithfully,

  
Executive Engineer,  
N.H. Division, Hubli

B