



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai
दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मैलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



INVITATION OF PUBLIC COMMENTS

NHAI/15018/4.2/10/2022/RO-Madurai/E-127331/123

13.01.2021

Sub: NHAI, Madurai Region - PIU, Dindigul - Permission for erection of 33 KV Over Head Power Supply line along the road from Km 356/280 to Km 359/300 on RHS & across NH at Km 356/280 in Karur - Dindigul section of NH-44 in the State of Tamil Nadu - Proposal submitted - Reg.

The proposal received from PD, Dindigul vide letter No. NHAI/PIU/DGL/11014/08/OHL/Erection/2021/2514 dated 31.12.2021 thereby requesting permission for erection of 33 KV Over Head Power Supply line along the road from Km 356/280 to Km 359/300 on RHS & across NH at Km 356/280 in Karur - Dindigul section of NH-44 in the State of Tamil Nadu proposed by the Authorized Signatory, M/s Sri Matha Spinning Mills Pvt. Ltd., Dindigul in accordance with Ministry's latest guidelines dated 22.11.2016.

2) The alignment proposed by the Authorized Signatory, M/s Sri Matha Spinning Mills Pvt. Ltd., Dindigul requesting permission for erection of 33 KV Over Head Power Supply line along the road from Km 356/280 to Km 359/300 (RHS) & across NH at Km 356/280 in Karur - Dindigul section of NH-44 in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Available ROW (in Meter)		Distance of erection from C/L (in Meter)		Proposal
		LHS	RHS	LHS	RHS	
Along NH-44: Km 356/280 to Km 359/300 (RHS)	3020	30	30	-	28	RSJ Poles to be erected along NH at a distance of 28m from the centreline on RHS.
Across NH-44 At Km 356/280	60	30	30	-	-	M+9 Towers (1 No of tower on each side) are proposed to be erected at a distance of 28 m from centreline on BHS. The proposed Vertical Clearance is 16.50 m.

3) As mentioned in the proposal, the ROW is 60 m @ Km 356/280 i.e. 30 m on LHS and 30 m on RHS from the centreline. As observed from the drawing, the RSJ Poles are to be erected along NH from Km 356/280 to Km 359/300 at a distance of 28m from the centerline on RHS & 2 Nos. of M+9 towers are proposed to be erected across NH at Km 356/280 i.e. at a distance of 28m from the Centerline on BHS.

[Signature]

National Highways Authority of India

-2-

4) In this instant proposal, the proposed Vertical Clearance is 16.50 m which is satisfying the MoRTH Specifications.

5) The Authorized Signatory, M/s Sri Matha Spinning Mills Pvt. Ltd., Dindigul has furnished necessary undertaking to the effect that they will shift the power supply lines as and when requested by the NHAI at their own cost. It is also mentioned that, the proposed erection of 33 KV Over Head Power Supply line along & across NH work will not to damage any other utility, if damaged they will pay the losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.


6) Accordingly, the proposal is in conformity with Policy Guidelines issued by Ministry vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. Also, as per the above mentioned Policy Guidelines, the application is made on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.

Encl: As above.


(Govindasamy K) 13/01/2022
Deputy General Manager (Tech.,)
Regional office, Madurai.

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Dindigul - for information.