



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai
दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



INVITATION OF PUBLIC COMMENTS

NHAI/15018/3.6/08/2022/RO Madurai/E-149044/1448

17.05.2022

Sub: NHAI, Madurai Region - PIU, Trichy - Permission for erection of 22 KV HT line EB Pole along the road from Km 409/962 to Km 410/285 on LHS, from Km 410/285 to Km 410/400 on RHS & across NH at Km 410/285 at Paraipatti Village in Trichy - Dindigul section of NH-45 (New NH-83) in the State of Tamil Nadu - Proposal submitted - Reg.

The proposal received from PD, Trichy vide letter No. NHAI/PD/TRY/Utility/TNEB/NH 45/T-D/2022/781 dated 06.05.2022 thereby requesting permission for erection of 22 KV HT line EB Pole along the road from Km 409/962 to Km 410/285 on LHS, from Km 410/285 to Km 410/400 on RHS & across NH at Km 410/285 at Paraipatti Village in Trichy - Dindigul section of NH-45 (New NH-83) in the State of Tamil Nadu proposed by the Executive Engineer, South/TANGEDCO, Dindigul in accordance with Ministry's latest guidelines dated 22.11.2016.

2) The alignment proposed by the Executive Engineer, South/TANGEDCO, Dindigul requesting permission for erection of 22 KV HT line EB Pole along the road from Km 409/962 to Km 410/285 on LHS, from Km 410/285 to Km 410/400 on RHS & across NH at Km 410/285 at Paraipatti Village in Trichy - Dindigul section of NH-45 (New NH-83) in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Available ROW (in Meter)		Distance of erection from C/L (in Meter)		Proposal
		LHS	RHS	LHS	RHS	
Along NH-45: Km 409/962 to Km 410/285 (LHS)	323	30	30	29	-	EB Poles to be erected along NH at a distance of 29m from the centerline on BHS.
Along NH-45: Km 410/285 to Km 410/400 (RHS)	115	30	30	-	29	
Across NH-45 At Km 410/285	60	30	30	-	-	EB Poles (1 No of Pole on each side) are proposed to be erected at a distance of 29 m from Center line on BHS. The proposed Vertical Clearance is 11 m.

3) As mentioned in the proposal, the ROW is 60 m in the aforesaid stretch i.e. 30 m on LHS and 30 m on RHS from the Centerline. As observed from the drawing, the

S. Thirumala

National Highways Authority of India

-2-

EB Poles are to be erected along NH from Km 409/962 to Km 410/285 at a distance of 29m from the centerline on LHS, from Km 410/285 to Km 410/400 at a distance of 29m from the centerline on RHS & 2 Nos. of EB Poles are proposed to be erected across NH at Km 410/285 i.e. at a distance of 29m from the Centerline on BHS.

4) In this instant proposal, the proposed Vertical Clearance is 11 m which is satisfying the MoRTH Specifications.

5) The Executive Engineer, South/TANGEDCO, Dindigul has furnished necessary undertaking stating that they will relocate the HT line EB Poles as and when requested by the NHAI at their own cost and risk. It is also mentioned that, the proposed erection of 22 KV HT line EB Pole along & across NH work will not to damage any other utility, if damaged they will pay the losses either to NHAI or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

6) Accordingly, the proposal is in conformity with Policy Guidelines issued by Ministry vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. Also, as per the above mentioned Policy Guidelines, the application is made on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.

Encl: As above.


(S Thamizharasan)
Manager (Tech.,)
Regional office, Madurai.

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, PIU, Trichy - for information.