

दर्भाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई–मेल / E-mail : romadurai@nhai.org nhairomadurai@gmail.com भारतीय राष्ट्रीय राजमार्ग प्राधिकरण (सड़क परिवहन और राजमार्ग मंत्रालय) National Highways Authority of India (Ministry of Road Transport & Highways) क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai दूसरा व तीसरी तल, विजय कृष्ण प्लाजा, संख्या-1, लेक प्रिया, मेलूर मेन रोड, माहुतावनी, मदुरै-625 007 2rd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107



NHAI/15018/4.2/7/2020/RO-Madurai/1511

23rd October, 2020

INVITATION OF PUBLIC COMMENTS

Sub: NHAI, Madurai Region - PIU, Dindigul - Permission for laying water supply pipeline across NH at Km 12/310 in the section of Dindigul - Theni of NH-45(E) in the State of Tamil Nadu - Proposal submitted - Reg

The proposal is regarding permission for laying water supply pipeline across NH at Km 12/310 in the section of Dindigul - Theni of NH-45(E) in the State of Tamil Nadu submitted to this office by PD, PIU Dindigul vide letter No. NHAI/PIU/DGL/11014/02/Water Pipe Line/2020/1816 dated 12.10.2020 in accordance with Ministry's latest guidelines dated 22.11.2016.

2. The alignment proposed by the Executive Officer, Special Grade Town Panchayat, Chinnalapatti, Dindigul District for laying water supply pipeline across NH at Km 12/310 in the section of Dindigul - Theni of NH-45(E) in the State of Tamil Nadu i.e. in a length of 30 m as detailed under:

Stretch in Km	Dia of the pipe	Length in	Available (m) LHS		Distance to the casing pipe from the top of the sub grade (m)	Method of Laying of WSPL
Across NH-7 Km 12/310	800 mm dia MS Encasing Pipe (200 mm dia K7 water carring pipe)	30	15.00	15.00	2.00	HDD Method

3. The Right of Way is 30 m in the aforesaid stretch. The Executive Officer, Special Grade Town Panchayat, Chinnalapatti, Dindigul District has proposed to lay water supply pipeline across NH at Km 12/310 of NH-45(E) for a length of 30 m. Further, the Executive Officer, Special Grade Town Panchayat, Chinnalapatti, Dindigul District has given undertaking that the lay of supply pipeline is proposed to lay by *HDD Method* at a depth of 2.00 m distance to the casing pipe from the top of the sub grade which is in conformity with Ministry's latest guidelines dated 22.11.2016.

any

E:\GHK\Dindigul\Access Permission\Public comments\4.2.7\RO Ltr 1511- Public Comments Notice.docx

- 4. The Executive Officer, Special Grade Town Panchayat, Chinnalapatti, Dindigul District has furnished an undertaking to the effect that they will remove the laid of water supply pipeline in future if required by NH Authority at any time for expansion of the NH at their own cost without claiming any compensation from NHAI. Also, certified that, the proposed laying of water supply pipeline work will not affect the design, stability, traffic safety and future improvement of the proposed stretch.
- 5. As per the guidelines issued by the Ministry vide letter No. RW/NH-33044/29 /2015/S&R(R) dated 22.11.2016, the application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer
National Highways Authority of India
No.2nd& 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007

(Govindasamy K),23/10/2020

Deputy General Manager (Tech.), For Regional Officer