

No.RW-MD/TN/OFC/Per/NH 47 /2002

GOVERNMENT OF INDIA

MINISTRY OF ROAD TRANSPORT & HIGHWAYS

Chief Engineer cum Regional Officer,

C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.

Email: cerochennaimorth@gmail.com, Telefax Off: 24919341, 24916032.

Dated: 04.07.2019

Invitation of public comments

Subject:-Permission Proposal for Erection of 33KV 11KV HT Over Head line with pole along the NH from Km 107/720 to Km 109/920 (RHS), Km 109/970 to Km 115/314 (RHS), Km 115/400 to Km116/100 (RHS), Km 116/100 to Km 116/500 (LHS) and crossing at Km 116/100 & Erection of 33KV 11Kv HT underground cable along the NH from Km 109/920 to Km 109/970 (RHS), Km 114/560 to Km 115/314 (RHS) Chengapalli - Walayar section of NH-47 in the State of Tamil Nadu-Reg.

The proposal is regarding permission Proposal for Erection of 33KV 11KV HT Over Head line with pole along the NH from Km 107/720 to Km 109/920 (RHS), Km 109/970 to Km 115/314 (RHS), Km 115/400 to Km116/100 (RHS), Km 116/100 to Km 116/500 (LHS) and crossing at Km 116/100 & Erection of 33KV 11Kv HT underground cable along the NH from Km 109/920 to Km 109/970 (RHS), Km 114/560 to Km 115/314 (RHS) Chengapalli - Walayar section of NH-47 was submitted to this office by the PD, NHAI, Coimbatore vide letter No.NHAI/DGM(T)&PD/ NH-47/2019/1046 dated 10.06.2019 has submitted the proposal to this office in accordance with Ministry's latest guidelines dated 22.11.2016.

2. The alignment proposed by Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur had submitted the proposal for Erection of 33KV 11KV HT Over Head line with pole along the NH from Km 107/720 to Km 109/920 (RHS), Km 109/970 to Km 115/314 (RHS), Km 115/400 to Km116/100 (RHS), Km 116/100 to Km 116/500 (LHS) and crossing at Km 116/100 & Erection of 33KV 11Kv HT underground cable along the NH from Km 109/920 to Km 109/970 (RHS), Km 114/560 to Km 115/314 (RHS) Chengapalli - Walayar section of NH-47 i.e. in a length of 9448m as detailed under:

Stretch in Km	Length (Km)	ROW (m)	Dist. of Prop. Overhead EB line 292 nos from Centre line of NH (m)
RHS - size of pipe - 40 mm dia PLB Pipe			
Km 107/720 to Km 109/920	2.200	60.00	29.00
Km 109/970 to Km 115/314	5.344	60.00	29.00
Km 115/400 to Km116/100	0.700	60.00	29.00
LHS- size of pipe - 40 mm dia PLB Pipe			
Km 116/100 to Km 116/500	0.400	60.00	29.00
Across Km 116/100 - size- RCC Casing Pipe 150mm			
Stretch in Km	Length (Km)	ROW (m)	Dist. of Prop. Underground cable from Centre line of NH (m)
RHS - size of pipe - 40 mm dia PLB Pipe			
Km 109/920 to Km 109/970	0.050	60.00	
Km 114/560 to Km 115/314	0.754	60.00	

P.T.O

3. The right of way is 60M in the aforesaid stretch. The carriageway width of each side aforesaid stretch is 10.50m. Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur has proposed to lay the Optical fiber cable at the edge of the ROW for a length of 9448m. The entire length of 9448m the Erection of 33KV 11KV HT Over Head line with pole & Underground cable is proposed to be laid at a distance greater than 15m from the center line of the carriageway which is in conformity with Ministry's guidelines vide letter No. NHIII/P/66/76 dated 19.11.1976. Further, Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur has given undertaking that the Over Head line with pole & Underground cable is proposed to lay by **Trench Technology** to extent possible for distance greater than 15m from the center line of the carriageway by open trench method and across at Km 116/100 for a length of nearly 20m (Road crossing) by trenchless technology at a depth of 1.65m from the bottom of the road.

4. Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur has furnished an undertaking to the effect that Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur will remove the laid Erection of 33KV 11KV HT Over Head line with pole & Underground cable in future if required by NH wing of State Highways Department/MoRTH Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation from NH wing of Tamil Nadu/MoRTH Govt. of India and any right on the NH land. Further, mentioned that Assistant Engineer, TANGEDCO/TEDC, TM.Poondy, Tirupur will also maintenance thereof and against all claims, proceedings, damages, costs, charges and expenses whatsoever in respect thereof in relation there to restore the surfaces to its original condition soon after overhead construction of Erection of 33KV 11KV HT Over Head line with pole & Underground cable. Also, certified that the proposed of Erection of 33KV 11KV HT Over Head line with pole & Underground cable will not affect the design, stability, traffic safety and future improvement of the proposed stretch.

5. As per the guidelines issued by the Ministry vide letter No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 the relaxation application submitted by the applicant will be made available for public comments and the comments will be invited within 30 days from the day of uploading.


In view of the above, comments of the public on the above proposal requiring relaxation from distance criteria is invited to the below mentioned address:

Chief Engineer cum Regional Officer,
-Ministry of Road Transport & Highways,
C-1-A, Rajaji Bhavan, Besant Nagar, Chennai- 600090.
Email: cerochennaimorth@gmail.com, Telefax Off: 24919341, 24916032.

Encl: As Above.

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, NHAI, Coimbatore - for information

Yours Sincerely,

(Ellavarason)
Superintending Engineer
For Chief Engineer-RO


(Ellavarason)
Superintending Engineer
For Chief Engineer-RO