



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माडुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



NHA/15018/4.3/04/2023/RO Madurai/E:190377/ 659

19th April, 2023

INVITATION OF PUBLIC COMMENTS

Sub: NHA-PIU, Karaikudi- Laying of TWAD Water pipeline along the road from Km.129/000 to Km.130/200 (RHS), Km.130/200 to Km.131/400 (LHS) by Open Trench method & across the road in 4 locations at Km.129/160, Km.130/200, Km.130/750 & Km.131/300 by Trenchless Method on Karaikudi - Ramanathapuram section of NH 210 (New NH 536)- **Invitation of Public Comments - Reg.**

The proposal received from PD, Madurai vide letter No. PD, Karaikudi LrNo. NHA/PIU/Karaiudi/11024/TWAD/2023/156 dated. 10.02.2023. there by requesting permission for laying along the road from Km.129/000 to Km.130/200 (RHS), Km.130/200 to Km.131/400 (LHS) by Open Trench method & across the road in 4 locations at Km.129/160, Km.130/200, Km.130/750 & Km.131/300 by Trenchless Method on Karaikudi - Ramanathapuram section of NH 210 (New NH 536) in the State of TamilNadu proposed by, Executive Engineer, TWAD Board, Project Division, Karaikudi. in accordance with Ministry's latest guidelines dated 22.11.2016.

2) The alignment proposed by the, Executive Engineer, TWAD Board, Urban Division, Karaikudi. requesting permission for laying along the road from Km.129/000 to Km.130/200 (RHS), Km.130/200 to Km.131/400 (LHS) by Open Trench method & across the road in 4 locations at Km.129/160, Km.130/200, Km.130/750 & Km.131/300 by Trenchless Method on Karaikudi - Ramanathapuram section of NH 210 (New NH 536) in the State of TamilNadu detailed under;

Stretch in Km	Length in Meters	Dia of pipe	Available ROW (in Meter)	Remarks
Along NH-210 Km129/000 to Km 130/200(RHS)	1200	90 mm	Varying between 55.12-95.21	Laying of pipe line along the extreme edge of ROW at a distance of 0.5m from ROW edge at a depth of more than 1.2m from ground level.
Along NH-210 Km 130/200 to Km 131/400(LHS)	1200	90 mm	Varying between 30-36.32	Laying of pipe line along the extreme edge of ROW at a distance of 0.5m from ROW edge at a depth of more than 1.2m from ground level
Across NH-210 Km.129/160	62	300 mm	62.75	Laying of pipe line across by HDD Method at a depth of 1.50m below the ground level

(Signature)

Page 1 of 2

NHAI/15018/4.3/04/2023/RO Madurai/E:190377/ 659

19th April, 2023

Across NH-210 Km.130/200	90	300 mm	90.50	Laying of pipe line across by HDD Method at a depth of 1.50m below the ground level
Across NH-210 Km.130/750	29.5	300 mm	30	Laying of pipe line across by HDD Method at a depth of 1.50m below the ground level
Across NH-210 Km.131/300	29.5	300 mm	30	Laying of pipe line across by HDD Method at a depth of 1.50m below the ground level.

3) Executive Engineer, TWAD Board, Project sub Division, Karaikudi has mentioned that the Water supply pipeline along the NH by Open Trench Method at a minimum depth of 1.20m for along portion and by HDD at a depth of 1.50m for across portion.

4) Executive Engineer, TWAD Board, Project Division, Karaikudi, has furnished an undertaking to the effect that the applicant will remove the laid Water supply pipeline in future if required by NHAI/MoRTH, Govt. of India at any time for expansion of the NH at their own cost without claiming any compensation. Further, mentioned that Executive Engineer, TWAD Board, Project Division, Karaikudi will also restore the surfaces to its original condition soon after removal of the Water supply pipelines.

5) Accordingly, as per Policy Guidelines issued by Ministry vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016., the application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

The Regional Officer,
National Highways Authority of India,
No.2nd & 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

Yours Faithfully,


(Mahendra Meena),
Dy. Manager (Tech.,)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Karaikudi - for information.