



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
(सड़क परिवहन और राजमार्ग मंत्रालय, भारत सरकार)
National Highways Authority of India
(Ministry of Road Transport & Highways, Government of India)
क्षेत्रीय कार्यालय, मदुरै / Regional Office, Madurai

दूसरा व तीसरी तल, विजय कृष्ण प्लाज़ा, संख्या-1, लेक एरिया, मेलूर मेन रोड, माट्टुतावनी, मदुरै-625 007
2nd & 3rd Floor, Vijay Krishna Plaza, No.1, Lake Area, Melur Main Road, Mattuthavani, Madurai-625 107
दूरभाष / Tele : +91-452-258 8999 वेब / Website : www.nhai.gov.in ई-मेल / E-mail : romadurai@nhai.org



NHAI/15018/3.1/02/2023/RO-Madurai/661

19th April, 2023

INVITATION OF PUBLIC COMMENTS

Sub: NHAI -PIU Madurai - Operation and Maintenance of Madurai - Kanyakumari section from Km.0+000 Km.243.170 of NH-7 in the State of Tamil Nadu - Proposal submitted to Permission for Erection of 110KV Over Head Electrical Line crossing at Km.89+250 in Mullicewal Village in Madurai to Kanyakumari Section of NH-44(Old No:NH-7) in the state of Tamilnadu - In-Principle Approval Requested - Public Comments Invited - Reg.

The proposal received from PD, PIU-Madurai vide letter NHAI/PIU/MDU/NH-7/Utility/612 dated 03.03.2023. thereby requesting Permission for Erection of 110KV Tower line Crossing at Km.89+250 in Madurai - Kanyakumari Section of NH-44(Old No:NH-7) in the State of Tamil Nadu proposed by Superintending Engineer ,TANTRANSCO , GCC Madurai.

2) The alignment proposed by Superintending Engineer ,TANTRANSCO , GCC Madurai requesting Permission for Erection of 110KV Tower line Crossing at Km.89+250 in Madurai - Kanyakumari Section of NH-44(Old No:NH-7) in the State of Tamil Nadu as detailed under;

Stretch in Km	Length in Meters	Available ROW (in Meter)		Distance of erection from C/L (in Meter)		Remarks
		LHS	RHS	LHS	RHS	
Across NH-44: At Km 89+250	60	30	30	83.5	74.1	Over Head Line with minimum vertical clearance of 10.98m from MCW using EHT Tower.

3) As mentioned in the PD letter, the ROW is 60 m at Km 89+250. As observed from the drawing, the Overhead tower are to be erected across NH at Km 89+250

4) In this instant proposal, the as certified by PD, Madurai Vertical Clearance for the proposed erection overhead electrical 110KV overhead Transmission line is 10.98 m.

गैरस नोम

Transmission line and when requested by the NHA at their own cost. It is also mentioned that, the proposed erection work of 110KV Over Head Transmission line across NH will not cause damage to any other utility, if damaged they will pay the losses either to NHA or to the concerned agency as per Ministry Guidelines dated 22.11.2016.

6) Accordingly, As per the MoRTH guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016. The application is being uploaded on public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

In view of the above, comments of the public on the above proposal is invited to the below mentioned address:

The Regional Officer,
National Highways Authority of India,
No. 3rd Floor, Vijay Krishna Plaza,
No.1, Lake Area, Melur Main Road, Mattuthavani,
Madurai - 625 007.

This is issued with approval of Regional Officer-Madurai.


19/04/2023

(Mahendra Meena)
Dy. Manager (Tech)

Copy to:

1. The NIC, New Delhi - for uploading in the Ministry's website.
2. The PD, Tuticorin - for information.