



भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport & Highways, Govt. Of India)

क्षेत्रीय कार्यालय, उ०प्र०(पूर्व) वाराणसी

Regional Office - U.P. (East), Varanasi

एस- 2/656, ए-3 बी, वरुणा विहार कालोनी, द्वितीय एवं तृतीय तल, वन प्लेस टावर
(जे०पी० मेहता सीनियर सेकेंडरी स्कूल के पीछे), सिकरौल, वाराणसी-221002 (उ०प्र०)

S-2/656, A-3B, Varuna Vihar Colony, 2nd & 3rd floor, one place Tower

(Behind J.P. Mehta Sr. Secondary School), Sikraul Varanasi-221002 (U.P.)

No. 14011/42/RO/UP(E)/2019/1786



दूरभाष/Phone : 91-542-2280243

: 91-542-2280372

ई-मेल/E-mail : rovaranasi1@gmail.com

: rovaransi@nhai.org

वेबसाइट/Website : www.nhai.org

Date: 11.05.2020

Invitation of public comments

Sub.: Proposal for granting Permission for underground crossing of 2 Nos. 33KV, 3X 300 Sq mm XLPE insulated cable underground at KM 36.605 & laying from km 36.605 to km 36.418 on NH-28 (27), Lucknow-Faizabad Section at Massauli, Tehsil-Nawabganj, District-Barabanki by MVVNL-Barabanki.

The Executive Engineer, MVVNL, EDD-II (Vidyut Vitran Khand-II), Ramnagar, Barabanki has submitted the proposal for NOC for underground laying of 33KV line in the subject cited stretch.

2. From the submitted proposal, it is seen that the utility is crossing the NH at KM 36.605 & laying along NH from km 36.605 to km 36.418 through trenchless (HDD) method and will be laid at the extreme edge of ROW at the min depth of 1.65M from sub-grade level of road. The ROW at Ch. 36.605 from C/L is 19.870m on LHS and 30.250m on RHS. In this connection, MVVNL has confirmed that they will ensure all safety measures while executing the work.

3. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

4. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

The Chief General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-East, Varanasi
S-2/656, A-3B, Varuna Vihar Colony,
2nd & 3rd Floor, One Place Tower,
Behind J.P. Mehta Sr. Secondary School,
Sikraul, Varanasi-221002

This issue with the approval of CGM (Tech.)/RO.

Encl: As above

(C.M. Dwivedi)
General Manager (Tech.)

Copy to:

- Web Admin, NHAI-HQ- with request for uploading on the NHAI website
- The Technical Director, NIC, Transport Bhawan, New Delhi - with request for uploading on the Ministry's website.
- The Executive Engineer, MVVNL, EDD-II (Vidyut Vitran Khand-II), Ramnagar, Barabanki- for information please
- The Project Director, NHAI, PIU-Lucknow- for information please.