



सत्यमेव जयते

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291, टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org, rowestup@gmail.com



19001/1/RO-W-UP/K-A/NH-27/Ch.6.407-9.023/NOC/1914

Date:04.03.2023

Invitation of Public Comments

Sub: Proposal for the permission of laying of U/G XLPE cable at Ch.6.407 to Ch.6.88 & Ch.8.684 to 9.023 (LHS) (Total length-820m) along NH-27 at Saheed Path, District-Lucknow in the State of U.P.

The Authorized Signatory M/s Lulu Mall (Lulu India Shopping Mall Pvt. Ltd.) has submitted the NOC proposal for the permission of laying of U/G XLPE cable at Ch.6.407 to Ch.6.88 & Ch.8.684 to 9.023 (LHS) (Total length-820m) along NH-27 at Saheed Path, District-Lucknow in the State of U.P.

2. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

**The General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010**

This is issues with the approval of RO-West (UP).

Encl: As above.

**(Roopak Jain)
Manager (T)
For RO-West, UP**

Copy to:

1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. The Authorized Signatory, M/s M/s Lulu Mall (Lulu India Shopping Mall Pvt. Ltd.), Lucknow for information.
4. The PD, PIU-Lucknow for information.

CHECK LIST

Guidelines for Project Directors for processing the proposal of laying Optical fiber/HT cables/Sewer pipe line etc. by private parties in the land along National Highway with NHAI.

Relevant circulars

Check-list for getting approval for laying Optic fiber cable (OFC) line on NH land

Ministry Circular No. RW/NH-33044/29/2015/S&R (R) Dated 22.11.2016. Ministry
Circular No. RW/NH-33044/27/2005/S&R(R)(Pt.) Dated 06.08.2013

S. No.	Item	Information/Status	Remarks
1.	General Information		
1.1	Applicant/Agency	Lulu India Shopping Mall Pvt. Ltd.	
1.2	National Highway Number	NH-27	
1.3	State	Uttar Pradesh	
1.4	Location	District- Lucknow	
1.5	(Chainages in KM)	Ch.- 6.407 to Ch.- 6.888 & Ch.- 8.684 to Ch.- 9.023 (LHS) (Total Length- 820.00M)	
1.6	Length in Meters	820.00M	
1.7	Width of available ROW		
	(a) Left side from center line towards increasing chainage/km direction	30.00M	
	(b) Right side from center line towards increasing chainage/km direction	30.00M	
1.8	Proposal to lay the XLPE cable		
	(a) Left side from center line towards increasing chainage/ km direction	Ch.- 6.407 to Ch.- 6.888 & Ch.- 8.684 to Ch.- 9.023 (LHS) (Total Length- 820.00M)	Laying of XLPE Insulated cable
	(b) Right side from center line towards increasing chainage/km direction	N/A	
1.9	Proposal to acquire land		
	(a) Left side from center line.	Not required	
	(b) Right side from center line.	Not required	
1.10	Whether proposal is in the same side where land is not to be acquired	YES	
	If not then where to lay the cable	Within available ROW	
1.11	Details of already laid services, if any along the proposed route.	N/A	
1.12	Number of lanes (2/4/6/8 lanes) existing	4 Lane	

For S.A. Infrastructure Consultants Pvt. Ltd.



Highway Maintenance Engineer



प्रबंधक (तक.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
एन.ए.ए. लखनऊ (उ.प्र.)

1.13	Proposed Number of lanes (2 lanes with paved shoulder/4/6/8 lanes)	N/A	
1.14	Service road existing or not If yes then which side		
a	Left side from center line	N/A	
b	Right side from center line.	N/A	
1.15	Proposed Service Road		
a	Left side from center line	N/A	
b	Right side from center line.	N/A	
1.16	Whether proposal to lay cable is after the service road or between the service road and main carriageway.	Extreme edge of ROW	
1.17	The permission for laying OFC / HT cables/ water supply pipe line shall be considered for approval/rejection.	For approval	
	(i) Where the ROW is more than 45m then the duct cable shall be laid at the edge of right of way within the utility corridor of 2m width, duly keeping in view the future widening.	Not required	
	(ii) Where land is yet to be acquired for 4-laning and the position of new carriageway has been decided then the cable shall be laid at the edge of right of way within the utility corridor of 2m width, on that side of existing carriageway where extra land is not proposed to be acquired for 4-laning.	Not required	
	iii) Where the widening plan for 4-laning is not yet decided and available ROW is around 30m or less, a judicious decision would need to be taken for permitting the Laying of cable/duct. This could be Within 1.5m to 2 m of utility corridor at the edge of existing ROW, duly Keeping in view the possible Widening plans.	4-laning has been completed	
	(iv) Where row is restricted and adequate only to accommodate the carriageway, central verge, shoulders and drains (e.g., Highways in currying through hilly, rolling terrain) the cable shall be laid clear of the drain.	Plain terrain (edge of ROW)	
	(v) Where land strip for utility corridor cannot be conveniently earmarked (available ROW restricted to the toe of the embankment) for laying of cable/ducts, the permission may be refused.	Available	

For S A Infrastructure Consultants Pvt. Ltd.



Highway Maintenance Engineer



✓
प्रबंधक (तक.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
प.का.इ., लखनऊ (उ.प्र.)

1.18	Number of applicants of the same stretch	Single applicant	
1.19	Whether the case of multiple licenses	No	
1.20	If so, furnish a joint implement programmer to lay their respective ducts within stipulated time frame.	Not required	
1.21	If crossing of the road involved If yes, it shall only be through trench less technology	Yes, it shall only be through HDD method	
2	Document/drawing enclosed with the proposal.	Yes	
2.1	Cross section showing the size of trench for open trenching method (Is its normal size of 1.65m deep x0.5m wide)	Shown in the drawing	
2.2	Cross section showing the size of pit location of pipe line for HDD method	Yes	
2.3	Strip plan / Route Plan showing the OFC/pipe line, chainage, width of ROW, important mile stone, intersections, cross drainage works etc.	Shown in the drawing	
2.4	Mythology of laying of optical fiber cable	Enclosed	
2.4.1	Open trenching method. If, yes, methodology of refilling of trench.	Trench less	
2.4.2	Horizontal Directional Drilling (HDD) method	Yes	
2.4.3	Laying OFC/ HT cable through CD works and method of laying (Whether to be hung outside parapet)	Yes	
3	Draft license agreement signed by two witnesses	Yes	
4.	Performance Bank Guarantee	Yes	
5.	Affidavit/ Undertaking from the applicant for		
5.1	Not to Damage to other utility, if damaged then to pay the losses either to NHAI or to the concerned agency.	Yes, enclosed	
5.2	Renewal of Bank Guarantee.	N/A	
5.3	Confirmation all standard condition of NHAI guidelines.	Yes, enclosed	
5.4	Shifting of optical fiber cable as and when required by NHAI.	Yes, enclosed	
5.5	Shifting due to 6-laning / widening of NH.	Yes, enclosed	
5.6	Indemnity against all damages and claims clause (xxiv)	Yes, enclosed	
5.7	Traffic movement during laying of OFC to be managed by the applicant	Yes, enclosed	
5.8	If any claim is raised by the Concessionaries, then the same has to be paid by the applicant.	Yes, enclosed	

For S A Infrastructure Consultants Pvt. Ltd.



Highway Maintenance Engineer




प्रबंधक (तक.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
प.का.इ., लखनऊ (उ.प्र.)

5.9	Certificate for 6-laning from the applicant in following format. "We do undertake that I will relocate service road/approach road/utilities at my own cost not with standing the permission granted within such time as will be stipulated by NHAI for future six-lane or any other development."	Yes, enclosed	
6.	Affidavit /Power of Attorney in favor of authorized signatory.	Yes, enclosed	
7.	Copy of DOT license	No, XLPE insulated cable	
8.	Certificate from the Executive Engineer	N/A	
8.1	Certificate from confirming of all standard condition issued vide Ministry Circular No. RW/NH-33044/27/2005/S&R(R)(Pt.) dated 7/8/2013 & dated 22.11.2016	Yes	
8.2	Certificate for 2-laning from PD in the following format	Already 4- lane	
	(a) There feasibility is available "I do certify that there will be no hindrance to proposed 6-Waning base on the feasibility report considering proposed structure at the said location.	N/A	
	(b) In case feasibility report is not available I do certify that sufficient Ro Wia available at sight for accommodate proposed 6-laning.	N/A	
9.	As per guidelines license fee shall be charged.	Department will pay fee after issuing demand note	
10.	If NH section proposed to be taken up NHAI on BOT basis —a clause in para 17 to be inserted in the agreement. "The permitted Highway on which Licensee has been granted the right of way to the concessionaire under the concession agreement for uo- gradation of [.... Section From Km.....to Kmof NHAI No.....on Build, Operate and Transfer Basis]	N/A	
11.	Who will supervise the work of laying of OFC/Cable	Lulu india shopping Mall Pvt. Ltd., 3M floor, Plot No. T-5, T-4A, I.B.B.-2, Sushant Golf City, Lucknow, UP- 226030	
12.	Who will ensure that the defects in road portion after lay of OFC are corrected and if not corrected then what action will be	Lulu india shopping Mall Pvt. Ltd., 3M floor, Plot No. T-5, T-4A, I.B.B.-2,	

For S A Infrastructure Consultants Pvt. Ltd.



Highway Maintenance Engineer





प्रबंधक (तक.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
प.का.इ., लखनऊ (उ.प्र.)

	taken.	Sushant Golf City, Lucknow, UP- 226030	
13.	Who will pay the claims for damages done/ disruption in working of concessionaire if asked by the concessionaire.	Lulu India shopping Mall Pvt. Ltd., 3M floor, Plot No. T-5, T-4A, I.B.D.-2, Sushant Golf City, Lucknow, UP- 226030	
14.	A permission in the register of records Certificate from PD that he will enter the proposed of the permissions in the prescribed Performa (copy enclosed) issued vide Ministry Circular RW/NH-33044/29/2015/S&R(R)(Pt.) Dated 22/11/2016	Yes	
15.	If any previous approval is accorded for after lay of OFC then photocopy if register of records of permissions accorded as maintained by PD (as per Ministry Circular RW/NH-3044/29/2015/S&R(R)(Pt.) Dated:22/11/16 as referred in para 13 above is enclosed or not.	Not Required	

For S.A. Infrastructure Consultants Pvt. Ltd.



Highway Maintenance Engineer

✓
प्रबंधक (तक.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण
प.का.इ., लखनऊ (उ.प्र.)

