



सत्यमेव जयते

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण

(सड़क परिवहन एवं राजमार्ग मंत्रालय, भारत सरकार)

National Highways Authority of India

(Ministry of Road Transport and Highways, Government of India)

क्षेत्रीय कार्यालय-पश्चिम उ०प्र०, लखनऊ Regional Office - West UP, Lucknow.

3/248, विशाल खण्ड, गोमती नगर, लखनऊ-226010 (उ.प्र.)

3/248, Vishal Khand, Gomti Nagar, Lucknow-226010 (UP)

दूरभाष / Phone : 0522-4960291, टेलीफैक्स / Fax : 0522-4950680

ई-मेल / E-mail : rowestup@nhai.org, rowestup@gmail.com



19001/1/RO-W-UP/A-K/NH-91/Pkg-1/Ch.177+240 & 183+600/1926 Date: 10.03.2023

Invitation of Public Comments

Sub: Proposal for permission of Erection/laying of 11kV 02 Nos. U/G Road Crossing at Km.177+240 & Km.183+600 across NH-91 (New NH-34) under ADB project Hathras District in the State of Uttar Pradesh.

The Authorized Signatory M/s Executive Engineer, EDD-III, DVVNL, Hathras has submitted the NOC proposal for granting permission of Erection/laying of 11kV 02 Nos. U/G Road Crossing at Km.177+240 & Km.183+600 across NH-91 (New NH-34) under ADB project Hathras District in the State of Uttar Pradesh.

2. As per the guidelines, issued by the Ministry vide OM No.RW/NH-33044/29/ 2015/ S&R(R) dated 22.11.2016, the application shall be put out in the public domain for 30 days for seeking claims and objections (on grounds of public inconvenience, safety and general public interest).

3. In view of the above, comments of the public on the above application is invited to the below mentioned address, which should reach by this office within 30 days from the date of publication beyond which no comments shall be entertained.

**The Chief General Manager cum Regional Officer,
National Highways Authority of India
Regional Office, UP-West, Lucknow
3/248, Vishal Khand, Gomti Nagar
Lucknow-226 010**

This is issues with the approval of RO-West (UP).

Encl: As above.


(S.K. Sharma)
General Manager (T)
For RO-West, UP

Copy to:


1. Web Admin, NHAI-HQ- with request for uploading on the NHAI website.
2. The Technical Director, NIC, Transport Bhawan, New Delhi- with request for uploading on the Ministry's website.
3. The Authorized Signatory, M/s Executive Engineer, EDD-III, DVVNL, Hathras for information.
4. The PD, PIU-Aligarh for information.

CHECK - LIST

Guidelines for processing the proposal for laying of 11 KV Underground electrical cable/HDPE Pipe at Aligarh to Kanpur Road NH-91 km 177+240 & 183+600 across National Highway 91 (New 34) under ADB Project Hathras District State of Uttar Pradesh.


General Information

S.No.	Item	Information/Status
1	Name and Address of the Applicant/Agency	Executive Engineer, Dakshinanchal Vidyut Vitran Nigam Limited, EDD-III, 33/11 KV S/STN, Sasni, Hathras, Uttar Pradesh
2	National Highway Number	Aligarh Kanpur Road NH 91 (New 34)
3	State	Uttar Pradesh
4	Location	Near Village Husainpur & Sikandra Rao Railway Station
5	Chainage in Km	Chainage No- 177+240 & 183+600
6	Length in Meters	60 Mtr & 60 Mtr
7	Width of available ROW in both side	30 Meter each side
8	Side of NH (Left side of NH towards increasing chainage/Km direction)	Across the NH (HDD Method)
9	Highway Administration Address	Regional Officer, National Highways Authority of India, 2/248, Vishal Khand, Gomti Nagar, Lucknow



Executive Engineer
Electricity Distribution Division III
Sasni Distt.- Hathras

Executive Engineer
Electricity Distribution Division III




ओमेंद्र/OMENDRA
प्रबंधक (तक)/Manager (Tech.)

राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
परियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh


पी०के० कौशिक/P.K. KAUSHIK
परियोजना निदेशक/Project Director
राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
परियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh
Project Director
National Highways Authority of India
Project Implementation Unit-Aligarh

S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORTH Norms
1	Details of already laid services, if any	No	Enclosed	N/A
2	Whether up-gradation of the stretch in near future is proposed or not.	No		N/A
	(a) If yes, provision of utility adversely affect the plan of up-gradation	No	Not affect plan of up-gradation	N/A
3	Laying of the utility service along the National Highways.			
3.1	Location of proposed utility service along the stretch	No	Utility Duct/beyond the toe line of the embankment and drains, and close to the extreme edge of the RoW.	N/A
3.2	Depth of the top of utility Service from ground level	No	0.6 Meter	N/A
3.3	Mechanism for crossing water channel	No	Through utility duct (if provision exists) or beneath the bed of water channel	N/A
3.4	Whether ROW is restricted in this stretch?	No		N/A
3.4.1	If yes, whether provision of land acquisition is required to lay utility	No		N/A
	(a) If yes, whether undertaking for land acquisition along with relevant LA details has been furnished.	No		N/A
3.4.2	Width of concrete duct, if utility services are proposed to be laid in concrete ducts	No	Not less than one lane	N/A
4	Laying of utility services across the NH			
4.1	Whether Existing drainage structures is allowed to carry the utility lines.	No	Not to be allowed	Complying

पी०के० कौशिक/P.K. KAUSHIK

परियोजना निदेशक/Project Director

भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
प्रियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh

Electricity Distribution Division III
Hathras



ओमेंद्र/OMENDRA
प्रबंधक (तकनीकी)/Manager (Tech.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
प्रियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh

S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORT&H Norms
4.2	Proposed crossing of utility service.	Across the NH	Perpendicular to NH	Complying
4.3	Type of casing pipe/conduit carrying the utility line.	HDPE Pipe	Steel, cast iron, or reinforced cement concrete and have adequate strength	Complying
4.4	Whether ends of the casing/conduit pipe are sealed from the outside	Sealed	Sealed	Complying
4.5	Length of casing/coduit pipe crossing NH	60 Mtr.	Extend from drain to drain in cuts and toe to toe of slope in the fills	Complying
4.6	Depth of top of the casing/conduit pipe.	1.2 m	At least 1.2m below the top of subgrade	Complying
4.7	Crossing method in case of CC pavement.	HDD	Only boring method (HDD)	Complying
4.8	Horizontal and vertical clearance in case utilities are allowed overhead,	No	In accordance with IRC codes	Complying
5	Document / Drawings enclosed with the proposal			
5.1	Cross-Section showing the size of trench for open trenching method.	NA	Enclosed, if applicable	
	(a) Trench width	NA	More than 30 cm and less than 60 Cm wider than the outer diameter of the utility pipe	
	(b) Filling of trench		as per Ministry guidelines vide letter No. RW/NH-34044/29/2015/S&R (R) dated 22.11.2016	



पी०के० काशिक/P.K. KAUSHIK
 परियोजना निदेशक/Project Director
 भारतीय राष्ट्रीय राजमार्ग प्रविधिक/Ministry of National Highways Authority of India
 इरिगेशन कार्यालय इवाई-अलगाथ/Project Implementation Unit-Aligarh

Executive Engineer
 Electricity Distribution Division III

ओमेंद्र/OMENDRA
 प्रबंधक (तक०)/Manager (Tech.)
 भारतीय राष्ट्रीय राजमार्ग प्रविधिक/Ministry of National Highways Authority of India
 इरिगेशन कार्यालय इवाई-अलगाथ/Project Implementation Unit-Aligarh

S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORT&H Norms
	(c) location of trench	NA	extreme edge of the ROW	
5.2	Cross section showing the size of pit and location of conduit for HDD method	Yes	Enclosed, if applicable	Complying
5.3	Strip plan/Route plan showing utility line, chainage, width of ROW, distance of proposed utility from the edge of ROW, important mile stone, intersections, cross drainage works etc.	Yes	Enclosed	Complying
5.4	Plan and profile drawing of stretch showing cross section of road at 20m distance along with ROW and proposed utility	Yes	Enclosed	Complying
6	Methodology for laying of electrical cable	Yes, Enclosed (By HDD Method)	Enclosed	Complying
7	Draft License agreement is as per Ministry guidelines vide letter No. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016 signed by two witnesses.	Yes, Enclosed	Enclosed	Complying
8	License fees in favor of MoRTH RPAO Lucknow	To be submitted, as per demand by NHAI	As per Ministry vide circular no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016	Complying
9	Wheather Bank Guarnatee has been obtained.	To be submitted, as per demand by NHAI	As per Ministry vide circular no. RW/NH-33044/29/2015/S&R(R) dated 22.11.2016	Complying
	a. If yes, whether confirmation of BG has been obtained as per MoRTH/NHAI guidelines.	Shall be obtained		Complying
10	Affidavit / Undertaking from the Applicant for			

पी०के० काशिक/P.K. KAUSHIK
परियोजना निदेशक/Project Director
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
परियोजना कार्यान्वयन इकाई-अलगाथ/Project Implementation Unit-Aligarh

Executive Engineer
Electricity Distribution Division III
Hathras



ओमेंद्र/OMENDRA
प्रबंधक (तकनीकी)/Manager (Tech.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
सुरक्षा, पर्यावरण, स्वच्छता/Protection, Environment, Cleanliness Unit-Aligarh


S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORT&H Norms
10.1	Undertaking for not to damage other existing utility, If damaged then to pay the losses to either to MoRTH/NHAI or to the concerned agency.	Yes, Enclosed	Enclosed	Complying
10.2	Undertaking for renewal of Bank Guarantee and when asked by NHAI/MoRTH.	Yes, Enclosed	Enclosed	Complying
10.3	Undertaking for confirming all standard condition of MoRTH/NHAI guidelines.	Yes, Enclosed	Enclosed	Complying
10.4	Undertaking for shifting of utilities as and when asked by MoRTH/NHAI within a month at their own cost.	Yes, Enclosed	Enclosed	Complying
10.5	Undertaking for Indemnity against all damages and claims.	Yes, Enclosed	Enclosed	Complying
10.6	Undertaking for management of traffic movement during laying of utility line without hampering the traffic.	Yes, Enclosed	Enclosed	Complying
10.7	Undertaking that if any claim is raised by the Concessionaire/contractor then the same has to be paid by the applicant	Yes, Enclosed	Enclosed	Complying
10.8	Undertaking that the applicant has obtained various safety clearances from the representative authorities such as directorate of Electricity, Chief controller of Explosives, Petroleum and Explosive Safety organization, Oil Industry Safety Directorate, State/Central Pollution Control Board and any other statutory clearance's applicable, before applying to Highway Administration.	Yes, Enclosed	Enclosed	Complying

The Right of the Way (ROW) of the National Highway available at the proposed location from the centre line of divided carriageway is 30m (from centre of ROW to edge of ROW towards proposed utility)

The above particulars along with the drawings and documents have been verified and certified as correct as per prevailing site conditions.

प्रीति कौशिक/P.K. KAUSHIK
परियोजना निदेशक/Project Director
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
प्रोजेक्ट कार्यालय इकाई-अल्लगढ़/Project Implementation Unit-Allgarh

Executive Engineer
Electricity Distribution Division III




ओमेंद्र/OMENDRA
प्रबंधक (सकरो)/Manager (Tech.)
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
प्रोजेक्ट कार्यालय इकाई-अल्लगढ़/Project Implementation Unit-Allgarh

S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORT&H Norms
-------	------	---	-------------	-------------------------------------

Executive Engineer Electricity Distribution Division III Sasni Distt. Hathras	Project Director National Highway Authority of India Project Implementation Unit-Aligarh
--	---





पी०के० काशिक/P.K. KAUSHIK
 परियोजना निदेशक/Project Director
 राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
 परियोजना कार्यालय इकाई-अलीगढ़/Project Implementation Unit-Aligarh


ओमेंद्र/OMENDRA
 प्रबंधक (तक०)/Manager (Tech.)
 राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
 परियोजना कार्यालय इकाई-अलीगढ़/Project Implementation Unit-Aligarh

S.No.	Item	Measurement observation as per site condition	MORTH Norms	Whether complying with MORT&H Norms
9	Who will supervise the work of laying of UG Electrical Cable/HDPE Pipe			
	(a) On behalf of the Applicant	Executive Engineer, Dakshinanchal Vidyut Vitran Nigam Limited, EDD-III, 33/11 KV S/STN, Sasni, Hathras		Complying
	(b) On behalf of NHAI	Suervision Consultant/NHAI		Complying
10	Who will ensure that the defects in road portion after laying of UG Cable electrical line are corrected and if not corrected then what action will be taken.			
	(a) On behalf of the Applicant	Executive Engineer, Dakshinanchal Vidyut Vitran Nigam Limited, EDD-III, 33/11 KV S/STN, Sasni, Hathras		Complying
	(b) On behalf of NHAI	Suervision Consultant/NHAI		Complying
11	Who will pay the claims for damages done / disruption in working of concessionalre if asked by the concessionalre	Executive Engineer, Dakshinanchal Vidyut Vitran Nigam Limited, EDD-III, 33/11 KV S/STN, Sasni, Hathras		Complying
12	A certificate from Project Director that he will enter the proposed permission in the register of records of the permission in the prescribed proforma (copy enclosed).	-		
13	If any previous approval is accorded for laying of UG electrical cable then photocopy of register of records of permissions accorded as maintained by Project Director may be enclosed	NA		

The Right of the Way (ROW) of the National Highway available at the proposed location from the centre line of divided carriageway is 30m (from centre of ROW to edge of ROW towards proposed utility)

The above particulars along with the drawings and documents have been verified and certified as correct as per prevailing site conditions.

Executive Engineer Electricity Distribution Division III Sasni Distt.- Hathras  आभयन्ता विद्युत वितरण खण्ड - तृतीय सामनी, हाथरस	 Project Director National Highway Authority of India Project Implementation Unit-Aligarh पी०के० कौशिक/P.K. KAUSHIK परियोजना निदेशक/Project Director भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India परियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh
--	---

प्रबंधक (तकनीकी)/Manager (Tech.)
आमैंद्र/OMENDRA
भारतीय राष्ट्रीय राजमार्ग प्राधिकरण/National Highways Authority of India
परियोजना कार्यान्वयन इकाई-अलीगढ़/Project Implementation Unit-Aligarh